



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

6/6/2022

SUBJECT: SFD2105-0076
SINGLE FAMILY DWELLING

To: Gitto Enterprises

Here are the results of all Inspections located at **2929 RAWLS CHURCH RD:**

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time:
Completed Date/Time:
Inspector: CP Bucket
Result:
Remarks:
Notes:

Inspection Type: TAX INSPECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Tax Inspection
Result:
Remarks:
Notes:

Inspection Type: RESIDENTIAL FIRE WALL
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:

Inspection Type: APPROVED W/EXC
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: APPROVED W/EXC
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: FOOTING SFD STEMWALL
Scheduled Date/Time: 10/1/2021
Completed Date/Time: 10/1/2021
Inspector: Ray Holder
Result: APPROVED
Remarks:
Notes:

Inspection Type: T-POLE
Scheduled Date/Time: 10/19/2021
Completed Date/Time: 10/19/2021
Inspector: Ray Holder
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/12/2021 5:24 PM Gitto Enterprises

Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

10/18/2021 9:58 AM Gitto Enterprises

Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

No premise number in file



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUNDATION SFD STEMWALL
Scheduled Date/Time: 10/19/2021
Completed Date/Time: 10/19/2021
Inspector: Ray Holder
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/12/2021 5:25 PM Gitto Enterprises

Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

10/18/2021 9:59 AM Gitto Enterprises

Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

Inspection Type: INSULATION SFD STEMWALL
Scheduled Date/Time: 10/19/2021
Completed Date/Time: 10/19/2021
Inspector: Ray Holder
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/18/2021 9:59 AM Gitto Enterprises

Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ADDRESS
Scheduled Date/Time: 10/19/2021
Completed Date/Time: 10/19/2021
Inspector: GIS Bucket
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/18/2021 9:58 AM Gitto Enterprises

Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

2929 RAWLS CHURCH RD FUQUAY VARINA 27526.

Inspection Type: UNDER SLAB TRADES SFD STEMWALL
Scheduled Date/Time: 10/25/2021
Completed Date/Time: 10/25/2021
Inspector: Ray Holder
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/22/2021 12:08 PM Gitto Enterprises

Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

Inspection Type: SLAB SFD STEMWALL
Scheduled Date/Time: 10/26/2021
Completed Date/Time: 10/26/2021
Inspector: Ray Holder
Result: APPROVED W/EXC
Remarks: eTRAKiT Inspection Request
Notes: 10/25/2021 8:52 AM Gitto Enterprises

Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

Dewater vapor barrier before pour.





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN SFD STEMWALL
Scheduled Date/Time: 2/1/2022
Completed Date/Time: 2/1/2022
Inspector: Ray Holder
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/31/2022 9:55 AM Gitto Enterprises
access code- 7383
Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

1) grout concrete floor in master bath. 2) front and rear doors not installed. 3) no plumbing test on house.

Inspection Type: ROUGH IN SFD STEMWALL
Scheduled Date/Time: 2/8/2022
Completed Date/Time: 2/8/2022
Inspector: Brad Sutton
Result: FAIL W/ PENALTY
Remarks: eTRAKiT Inspection Request
Notes: 2/6/2022 6:52 PM Gitto Enterprises
Plumbing test should be good call Pete at 919-809-2860
Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

None of the previous violations are corrected. Housewrap is hanging off right side of house.

Inspection Type: ROUGH IN SFD STEMWALL
Scheduled Date/Time: 2/14/2022
Completed Date/Time: 2/14/2022
Inspector: Justin Ryan McLeod
Result: APPROVED W/EXC
Remarks: eTRAKiT Inspection Request
Notes: Front and rear doors need foaming around jams.



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN SFD STEMWALL
Scheduled Date/Time: 2/17/2022
Completed Date/Time: 2/17/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: code 7383 lock box on front door

Inspection Type: INSULATION
Scheduled Date/Time: 2/17/2022
Completed Date/Time: 2/17/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes: code 7383 lock box on front door

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 4/6/2022
Completed Date/Time: 4/6/2022
Inspector: James T Hall
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 4/5/2022 1:23 PM Gitto Enterprises
code- 7383
phone-919-809-2860
Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 4/6/2022
Completed Date/Time: 4/6/2022
Inspector: James T Hall
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 4/5/2022 1:23 PM Gitto Enterprises
code- 7383
phone-919-809-2860
Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

Inspection Type: SLAB SFD STEMWALL
Scheduled Date/Time: 5/9/2022
Completed Date/Time: 5/9/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 5/5/2022 3:38 PM Gitto Enterprises
No inspection needed. Passed earlier. Just putting in for inspection
Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

This was Approved by Ray holder on 10/26/21

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 5/11/2022
Completed Date/Time: 5/11/2022
Inspector: James T Hall
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 5/9/2022 9:17 PM Gitto Enterprises
Code is 7383
Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ENVIR OPERATIONS PERMIT
Scheduled Date/Time: 5/25/2022
Completed Date/Time: 5/25/2022
Inspector: Andrew Currin
Result: APPROVED
Remarks:
Notes: Pump and Alarm Pending

Inspection Type: FINAL SFD STEMWALL**
Scheduled Date/Time: 5/31/2022
Completed Date/Time: 5/31/2022
Inspector: Justin Ryan McLeod
Result: DISAPPROVED
Remarks:
Notes: 1. Foundation block by hvac condenser needs repair, . 2. Energy certificate (located under island sink) is not complete

Inspection Type: FINAL SFD STEMWALL**
Scheduled Date/Time: 6/3/2022
Completed Date/Time: 6/3/2022
Inspector: Brad Sutton
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 6/1/2022 7:13 PM Gitto Enterprises
Code is 7383
Contact Name: Gitto Enterprises
Site Address: 2929 RAWLS CHURCH RD
Phone: 9198092860
e-Mail: gittopm@gmail.com

