

June 15<sup>th</sup>, 2021

ph: 910-893-7547

fax: 910-893-9371

Watermark Homes  
196 Annette Drive  
Benson, NC 27504

**Re: Status of Permit Application-SFD2105-0091-414 Joseph Alexander**

**To whom it may concern,**

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

**1. Use pink flags to mark property lines and irons that are Set by surveyor need to be visible. (\$25.00 Fee incurred)**

2. Use orange flags to mark house box.

3. Directions not clear to property (*\$25.00 fee incurred*)

4. Property needs cleared

5. Driveway not shown on site plan (Revision Required)

6. Backhoe pits required

**7. Other- No available space, home is placed in septic system area.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart III R.E.H.S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

JEM/kh

Copy: Central Permitting