Howerton Services, PLLC License # P-1716

3513 Cathedral Bell Road Raleigh, NC 27614 (919) 270-3460

May 2, 2024

Subject: 404 Ponchartrain Street

Fuquay Varina, NC 27526 Plan Revision Letter

Harnett County Permit #: SFD2106-0010

Based on the request of the Contractor, 1 item on the plans will be revised. My assessment and recommendations are as follows:

- Item 1 – The continuous footings for this project will be modified. The new continuous footings will be 19"x 8". All other footings shown in the plans will remain the same. The revised footings are acceptable.

The footing revision noted above meets all the requirements of the 2018 North Carolina Building Code for Residences.

