

September 28th, 2021

ph: 910-893-7547

fax: 910-893-9371

Stand Sure Custom Homes Inc
Po Box 1072
Coats, NC 27521

Re: Status of Permit Application-SFD2106-0028

To whom it may concern,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are Set by surveyor need to be visible. (\$25.00 Fee incurred)
- 2. Use orange flags to mark house box.
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs cleared
- 5. Driveway not shown on site plan (Revision Required)
- 6. Backhoe pits required

7. Other- SFD shall be shifted back 15ft-20ft to accommodate 4-bedroom front yard septic area. Revise site plan and confirm when ready.

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy: Central Permitting