


# AA TAKLA ENGINEERING, PLLC

## Consulting. Design. Efficiency.

Atef A. Takla, PE | 919-358-1758 | ateftakla@taklaengr.com

NC Firm License No. P-1446  
418 Vivaldi Dr. Durham, NC 27712

Project: 351 Pendergraft RD  
Lot #10 PGR  
Location: Bunnlevel, NC  
Date: 9/1/21  
Company: A & G Homes  
Care Of: Chad.



As Requested, A. Takla prepared this report  
to address the following item:-

- (A) Completed repairs (overexcavated Footings  
Trench, Lined w/ Fabric and Backfilled  
with #57 stone) at Footing of  
the above referenced property  
are adequate. No further repairs  
are needed.

**Limitations of Inspection:** Services provided are in accordance with the standard of practice for structural engineering and within the limits imposed by scope, schedule and budget. The determinations contained in this report are based on conditions observed at the time of the evaluation. No guarantees or warranties, expressed or implied, under this Agreement or otherwise, shall be construed in connection with services provided. Sequencing, shoring, means and methods of construction are considered beyond the scope of this report.