



= 2nd Level Wall

| | | LVL | | | |
|--------|--------|----------------------------|-------|---------|----------|
| PlotID | Length | Product | Plies | Net Qty | Fab Type |
| DB1 | 8-0-0 | 1-3/4"x 9-1/4" LVL Kerto-S | 2 | 2 | FF |
| | | | | | |

NA

16d/3-1/2" | 16d/3-1/2"

HUS26

USP 8

Truss Placement Plan SCALE: 1/4"=1'

LOAD CHART FOR JACK STUDS (BASED ON TABLES R502.5(1) & (b))
NUMBER OF JACK STUDS REQUIRED @ EA END OF
HEADER/GIRDER END REACTION (UP TO) REQ'D STUDS FOR (3) PLY HEADER END REACTION (UP TO) REQ'D STUDS FOR (4) PLY HEADER 1700 1 3400 2 3400 1 2550 1 5100 2 6800 2 5100 3 7650 3 10200 3 6800 4 10200 4 13600 4 8500 5 12750 5 17000 5 10200 6 15300 6 11900 7 13600 8 15300 9

| BUILDER | A & G Residential | CITY / CO. | Harnett County / Harnett | THIS IS A These trusse the building c sheets for eac is responsible the overall st walls, and co regarding bra |
|-----------|---------------------------------|--------------------------|--------------------------|--|
| JOB NAME | Lot 10 Pendegraft Rd. | ADDRESS | Lot 10 Pendegraft Rd. | |
| PLAN | Hampton B RF2, 2nd Car Grg., RP | MODEL | Roof | or online @ : Bearing rea prescriptive |
| SEAL DATE | 3/12/2020 | DATE REV. | // | (derived fro foundation than 3000# be retained |
| QUOTE# | B1020-4904 | DRAWN BY Marshall Naylor | | specified in retained to |
| JOB# | J0621-4013 | SALES REP. | Marshall Naylor | Signatu |

HIS IS A TRUSS PLACEMENT DIAGRAM ONLY.
hese trusses are designed as individual building components to be incorporated into e building design at the specification of the building designer. See individual design elects for each truss design identified on the placement drawing. The building designer responsible for temporary and permanent bracing of the roof and floor system and for e overall structure. The design of the truss support structure including headers, beams, algarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Marshall Naylor

Marshall Naylor



🛕 = Indicates Left End of Truss

(Reference Engineered Truss Drawing)

Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444