

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: ^{Warren} Bobbitt Applicant:

Address: ^{Trubank Ln} SFD

Proposed Facility: SFD

Location of Site:

Water Supply: Public Individual Well Spring Other

Evaluation Method: Auger Boring Pit Cut

Type of Wastewater: Sewage Industrial Process Mixed

Date Evaluated: 7-2-21
 Design Flow (.1949): 480 GPD

Property Size:

SFD 2106 - 0067

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS					Profile Class & LTAR	
			.1941		.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz			
			.1941 Structure/ Texture	.1941 Consistence Mineralogy							
1	L	0-24	LS	Gr	Fr/np/ns/xp	10yr 7/1	>48"	-	-	PS. 4 Group III	
	2-5%	24-48	scr	SDh	Fr/np/sp/xp		≥ 40"				
2	L	0-40	LS	Gr			>48"	>48"	-	-	PS. 8 Group I
	2-5%	40-48	scr	SDh							
3	L	0-20	LS	Gr		10yr 7/1			-	-	PS. 4 Group III
	2-5%	20-48	scr	SDh			≥ 36"	>48"			

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: M. G. Horn REHR Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	25% rad	25% rad	
Site LTAR	.4	.4	

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND		FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
FS-FOOT SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM		SP-SLIGHTLY STICKY	
CC-CONCLAVE SLOPE		CL-CLAY LOAM		P-PLASTIC	
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM		VP-VERY PLASTIC	
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			


STRUCTURE

- SG-SINGLE GRAIN
- M-MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)



Tree bank (n → TO WEST Rd →)