



= 1st Level Wall
 = 2nd Level Wall

HUS26	USP	17	NA	16d/3-1/2"	16d/3-1/2"
JUS26	USP	11	NA	10d/3"	10d/3"

LVL's						
PlotID	Length	Product	Plies	Net Qty	Fa	
Front GDH	21-0-0	1-3/4"x 11-7/8" LVL Kerto-S	3	3	FF	
3rd Car GDH	12-0-0	1-3/4"x 11-7/8" LVL Kerto-S	2	2	FF	
BM1	20-0-0	1-3/4"x 23-7/8" LVL Kerto-S	2	2	FF	

Truss Placement Plan
SCALE: 1/4"=1'

LOAD CHART FOR JACK STUDS
BASED ON TABLE 10.18.10.1 OF THE IBC

SPACING	1600 LBS	2000 LBS	2400 LBS
1700	1	2550	3400
1800	2	3100	4200
1900	3	3750	5100
2000	4	4500	6100
2100	5	5300	7200
2200	6	6200	8400
2300	7	7200	9700

BUILDER	Onsite Homes, LLC	CITY / CO.	
JOB NAME		ADDRESS	
PLAN	Berton B 3C	MODEL	Roof
SEAL DATE	11/7/15	DATE REV.	04/19/21
QUOTE #	Quote #	DRAWN BY	Marshall Naylor
JOB #	J0221-0921	SALES REP.	Marshall Naylor

Bearing reactions less than or equal to 2000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (detail # on the prescriptive Code requirements) to determine the minimum foundation size and number of tie rods required to support reactions greater than 2000# but not greater than 1500#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 1500#.


ROOF & FLOOR TRUSSES & BEAMS
 Rellly Road Industrial Park
 Fayetteville, N.C. 28309
 Phone: (910) 864-8787
 Fax: (910) 864-4444