

August 3, 2021

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Red Door Homes  
12809 US 70 BUS  
Clayton, NC 27520

ph: 910-893-7547  
fax: 910-893-9371

**Re: Status of Improvement Permit Application: SFDS2107-0050**

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. *(\$25.00 fee incurred)*
- 2. Use orange flags to mark house corners *(\$25.00 fee incurred)*
- 3. Directions not clear to property *(\$25.00 fee incurred)*
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Lot not ready – 3/4 irons not marked nor visibly located. Property lines shall be flagged based on irons. Onsite setbacks measurements do not match site plan. Land use is for 5-Bedroom SFD. 3/4 Bedroom Approval Max. Septic proposal shall be required for 5-Bedroom home. (1) Prepare lot adequately, (2) revise land use and site plan accordingly, and (3) reconfirm when ready.**

Your application will be put on hold until the selected items above have been addressed. When completed, **please call 910-893-7547 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc  
Copy: Central Permitting