

RJB, P.E., P.A.

C-0269

ROBERT J. BRACKEN  
ENGINEER + SURVEYOR

3768 Caribnton Road • Sanford, North Carolina 27330

March 31, 2022

Harnett County Inspections  
P.O. Box 65  
Lillington, NC 27546


Ref: Residential Building Inspection  
Stick Built Roof System  
Randy Chambers Residence  
200 Gilchrist Rd  
Cameron, NC 28326  
Chuck Smith, Contractor

Dear Sir/ Madam,

I made an onsite visit to the residential building site referenced above on March 30, 2022. The purpose of the visit was to examine the "stick built" roof system placed instead of the roof trusses as shown on the approved plans. The reason for the substitution was a delivery issue with the Trusses. After a thorough investigation, I approve the Stick built roof system as placed. The roof will resist the wind loads and support the live and dead loads associated with this area as specified in the North Carolina State Residential Building Code. 2018,ed.

If you have any questions please feel free to call me at 919-774-6074. or  
E mail: [bjbracken@windstream.net](mailto:bjbracken@windstream.net)

Sincerely,



Robert J. Bracken, PE

