Enoch ngineers, P.A.

Joe E. Godwin Sr., P.E., P.L.S. Joe E Godwin Jr., P.E.

Jason E. Godwin, P.L.S.

Consulting Engineers & Surveyors

1403 NC Highway 50 South Benson, North Carolina 27504 Phone: (919) 894-7765

www.enochengineers.com

Email: general@enochengineers.com

October 26, 2021

Matthew Taylor 165 Oak St. Lillington, NC 27546

RE:

5923 South River Rd.

Lillington, NC

Permit # SFD2108-0004

Subject:

Footing issue

To Whom It May Concern:

Our office has performed an evaluation of the situation pertaining to organic material found in and under the proposed footing at the above referenced project. Based on my observation, it was recommended that all organic matter encountered should be entirely removed under the footing areas impacted. The newly excavated area should be backfilled with #57 stone, or a similar, uniformly graded aggregate. Based on my observation, these measures have been completed as of the date of this letter, and the allowable bearing in the impacted areas should meet or exceed the minimum bearing capacity of 2,000 psf.

If you have any question or concerns regarding this matter, or if we may be of further assistance, please do not hesitate to contact us.

Respectfully,

Joe E Godwin Jr., P.E.

Enoch Engineers, P.A.