Joe E Godwin Sr., P.E., P.L.S.

Joe E Godwin Jr., P.E.

Jason E Godwin, P.L.S.



Email: general@enochengineers.com

www.enochengineers.com

## MATERIALS & TEST DIVISION

## FIELD REPORT

PROJECT							
CLIENT:	MOSS HOME BUILDERS		DATE:	6.21.22			
PROJECT:	RESI STEM WALL FILL		CONRACTOR:	ALLAN MOSS			
ADDRESS:	858 MCNEILL MILL RD		TECHNICIAN	: BH			
LOT #:	BROADWAY NC						

## TEST SHIMMARY

PERFORMED STEM WALL FILL MATERIAL EVALUATION AT SITE NOTED ABOVE. STEM WALL FOUNDATION FILLED WITH WASHED #57 STONE THROUGHOUT CONFIRMED A SUITABLE MATERAIL. NDT COMPACTION TESTING CANNOT BE PERFORMED. #57 STONE CONFIRMED A BEARING CAPACITY OF 2000 PSF THROUGHOUT INTERIOR OF FOUNDATION.

TESTING RESULTS						
SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %	

RETURN VISIT	REQUIRED?	
YES NO		8EAL P = 009517
TECHNICIAN:	Disclaimer:	NONEER ST

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 60 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.