## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 2927 Hobson Road (SR 1712) ISSUED TO: JRT Managing Properties LLC SUBDIVISION REPAIR Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 3-Bedroom 32'x64' SFD Proposed Wastewater System Type: 25% Reduction Sys. Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number of Occupants: 6 No. Basement Yes Pump Required: Yes X No May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: Five years No expiration Permit conditions: 09/23/2021 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958 and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance ISSUED TO: JRT Managing Properties LLC PROPERTY LOCATION: 2927 Hobson Road (SR 1712) SUBDIVISION Facility Type: 3-Bedroom 32'x64' SFD Expansion Basement Fixtures? Yes No Basement? Yes × No Type of Wastewater System\*\* 25% Reduction System (Initial) Wastewater Flow: 360 (See note below, if applicable ) 25% Reduction System Number of trenches 4 or 3 Installation Requirements/Conditions Trench Spacing: Feet on Center Septic Tank Size 1000 gallons Exact length of each trench 75 or 100 feet Trenches shall be installed on contour at a Pump Tank Size \_\_\_\_\_ gallons Maximum Trench Depth of: 20 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) ft. TDH vs. inches below pipe Pump Requirements: inches above pipe Aggregate Depth: Conditions: GLADITY TO D-BOX EGUAL DISTIBUTION inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 9/23/2021
Construction Authorization Expiration Date: 9/23/2020 Authorized State Agent:

ANDREW

## Harnett County Department of Public Health Site Sketch

