



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

8/2/2022

SUBJECT: SFD2108-0042
SINGLE FAMILY DWELLING

To: DRAUGHN JULIUS MELVIN

Here are the results of all Inspections located at **7232 ELLIOTT BRIDGE RD:**

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time:
Completed Date/Time:
Inspector: CP Bucket
Result:
Remarks:
Notes:

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 12/15/2021
Completed Date/Time: 12/15/2021
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: Inspector SPG changed the inspection assignment from SPG to SBL
Missing footer at garage





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOOTING
Scheduled Date/Time: 1/4/2022
Completed Date/Time: 1/4/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time: 1/4/2022
Completed Date/Time: 1/4/2022
Inspector: Slade Burton Lawson III
Result: FAIL W/ PENALTY
Remarks:
Notes: Work not complete

Inspection Type: FOUNDATION
Scheduled Date/Time: 1/6/2022
Completed Date/Time: 1/6/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes: Inspector SPG changed the inspection assignment from SPG to SBL

Inspection Type: T-POLE
Scheduled Date/Time: 1/10/2022
Completed Date/Time: 1/10/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes: Inspector SPG changed the inspection assignment from SPG to SBL

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 1/10/2022
Completed Date/Time: 1/10/2022
Inspector: Slade Burton Lawson III
Result: APPROVED W/EXC
Remarks:
Notes: Inspector SPG changed the inspection assignment from SPG to SBL
Need compaction front porch unless engineer stone





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 4/1/2022
Completed Date/Time: 4/1/2022
Inspector: Slade Burton Lawson III
Result: DISAPPROVED

Remarks:

Notes: Inspector SPG changed the inspection assignment from SPG to SBL
Anchors wing walls, upset headers garage, seal around plumbing fixtures garage, water distribution down, missing insulation baffles, secure tub surrounds, strap stud columns 4 or more, 3 kings headers 4 or or more, DO NOT INSULATE.

Inspection Type: ROUGH IN
Scheduled Date/Time: 4/14/2022
Completed Date/Time: 4/14/2022
Inspector: James T Hall
Result: FAIL W/ PENALTY

Remarks:

Notes: Still no water test on water line need 100 psi

Inspection Type: ROUGH IN
Scheduled Date/Time: 4/19/2022
Completed Date/Time: 4/19/2022
Inspector: Steven Gazlay
Result: DISAPPROVED

Remarks:

Notes: Address items from first inspection. Missing king studs.

Inspection Type: ROUGH IN
Scheduled Date/Time: 4/26/2022
Completed Date/Time: 4/26/2022
Inspector: Slade Burton Lawson III
Result: APPROVED

Remarks:

Notes: Inspector SPG changed the inspection assignment from SPG to SBL

Inspection Type: INSULATION
Scheduled Date/Time: 5/2/2022
Completed Date/Time: 5/2/2022
Inspector: James T Hall
Result: APPROVED

Remarks:

Notes: lock box is 0000



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ENVIR OPERATIONS PERMIT
Scheduled Date/Time: 6/23/2022
Completed Date/Time: 6/23/2022
Inspector: Mark Osborne
Result: APPROVED
Remarks:
Notes:

Inspection Type: ADDRESS
Scheduled Date/Time: 7/21/2022
Completed Date/Time: 7/21/2022
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 7232 ELLIOTT BRIDGE RD SPRING LAKE 28390.

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 7/21/2022
Completed Date/Time: 7/21/2022
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 7/21/2022
Completed Date/Time: 7/21/2022
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL SFD CRAWL**
Scheduled Date/Time: 7/21/2022
Completed Date/Time: 7/21/2022
Inspector: James T Hall
Result: CANCELLED
Remarks:
Notes: Cancel Pami



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 7/22/2022
Completed Date/Time: 7/22/2022
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL SFD CRAWL**
Scheduled Date/Time: 7/27/2022
Completed Date/Time: 7/27/2022
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: 1. Missing both crawl space doors. 2. Remove test caps on three plumbing vents on back roof.
3. Missing light on back right corner of soffit.

Inspection Type: FINAL SFD CRAWL**
Scheduled Date/Time: 7/29/2022
Completed Date/Time: 7/29/2022
Inspector: John B Kokoszka
Result: APPROVED
Remarks:
Notes: