## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: On Top Building Company LLC  PROPERTY LOCATION: 36 ROCK Ridge Place (Bill Avery Rd SK.)  SUBDIVISION James E Johnson III LOT # 5
NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:
Type of Structure: 60x60 (3bed/2.5ba) SFD
Proposed Wastewater System Type: 25% Reduction Sys.
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement Ves 🗵 No
Pump Required: Tes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: Five years
Permit conditions: No expiration
AND THE REPORT OF THE PARTY OF
Authorized State Agent:: Date: Date: Date: SEE ATTACHED SITE SKETCH  The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This
site is subject to revocation of the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.
Construction Authorization
(Required for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.
ISSUED TO: On Top Building Company LLC PROPERTY LOCATION: 36 Rock Ridge Place (Bill Avery Rd SI
SUBDIVISION James E Johnson III LOT # 5
00 00 (0) 1(0 5) 1 0 55
Basement? Yes No Basement Fixtures? Yes No
Type of Wastewater System** 25% 15000700 S787500 (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable )
20% Repair
Installation Requirements/Conditions Number of trenches
Septic Tank Size 1000 gallons Exact length of each trench 80 feet Trench Spacing: 9 Feet on Center
Pump Tank Sizegallons
Maximum Trench Depth of:inches (Maximum soil cover shall not exceed
(Trench bottoms shall be level to $\pm /-1/4$ " 36" above the trench bottom)
in all directions)
Pump Requirements: ft. TDH vsGPM inches below pipe
Aggregate Depth: inches above pipe
Conditions: GRAVITY TO DIBOX FEWER D'STRIBUTION Inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.
**If applicable: 1 understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: Date:
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
All and a
Authorized State Agent: Date: 09/30/2021
Control Add 100 Control Day 69/20/2021
Construction Authorization Expiration Date: 2773073626

## Harnett County Department of Public Health Site Sketch

Property Location: 36 Rock Ridge Place (Bill Avery Rd. - SR 1563) Issued To: On Top Building Company LLC Lot # 5 09/30/2021 Authorized State Agent: HOUSE 10' SIDE AUILDING SETBACK 10" SIDE BUILDING 165.30