Joe E Godwin Sr., P.E., P.L.S.

Joe E Godwin Jr., P.E.

Jason E Godwin, P.L.S.



Email: general@enochengineers.com

www.enochengineers.com

## MATERIALS & TEST DIVISION

## FIELD REPORT

		PROJECT		
CLIENT:	WATERMARK HOMES		DATE:	3.1.22
PROJECT:	BALLARD WOODS S/D		CONRACTOR:	JT
ADDRESS:	445 JOSEPH ALEXANDER		TECHNICIAN:	ВН
LOT #:	157			

## TEST SUMMARY

PERFORMED NDT ON SOIL BACKFILL INSIDE STEM WALL USING A TARGET DENSITY OF 115 PCF. SOILS CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95%.

	TESTING RESULTS					
SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %	
NDT	1	100+	119.1	124.5	4.5	

TECHNICIAN:

DocuSigned by:

| CAROLUMAN |

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 60 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying