




---

1731 Round Rock Drive, Raleigh, NC 27615 • (919) 872-3250 • fax (919) 877-5775 • [www.flsamerica.com](http://www.flsamerica.com)

# OAKHAVEN LOT 7

## HYDRAULIC CALCULATIONS

8/25/2021



Hydraulic calculations using HydraCALC

Fire & Life Safety America  
1731 Roundrock Drive  
Raleigh, NC 27615  
P: (919) 872-3250  
F: (919) 877-5775

Job Name : Oakhaven Lot 07 - Bedroom #3  
Drawing : FP1  
Location : 276 Oakhaven Drive  
Remote Area : RA1  
Contract : 21NC1531  
Data File : RA1.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** Oak Haven Lot 07  
**Location:** 276 Oakhaven Drive  
**Drawing no:** FP1  
**Date:** 8/23/2021

**Design**

**Remote area number:** RA1  
**Remote area location:** Bedroom #3  
**Occupancy classification:** Residential  
**Density:** .05 - Gpm/SqFt  
**Area of application:** 165 - SqFt  
**Coverage per sprinkler:** 400 - SqFt  
**Type of sprinklers calculated:** VK494  
**No. of sprinklers calculated:** 1  
**In-rack demand:** N/A - GPM  
**Hose streams:** 3 - GPM  
**Total water required (including hose streams):** 23.03 - GPM @ 30.45 - Psi  
**Type of system:** WET  
**Volume of dry or preaction system:** N/A - Gal

**Water supply information**

**Date:** 4/21/2021  
**Location:** NC 42, NC 27540  
**Source:** Fire & Life Safety America

**Name of contractor:** Fire & Life Safety America  
**Address:** 1731 Roundrock Drive / Raleigh, NC 27615 / P: (919) 872-3250  
**Phone number:** F: (919) 877-57  
**Name of designer:** H. WEYANT  
**Authority having jurisdiction:** Harnett County  
**Notes: (Include peaking information or gridded systems here.)**

# Water Supply Curve C

Fire & Life Safety America  
Oakhaven Lot 07 - Bedroom #3


Page 2  
Date 8/23/2021

### City Water Supply:

C1 - Static Pressure : 54.5  
C2 - Residual Pressure: 13.5  
C2 - Residual Flow : 417

### Demand:

D1 - Elevation : 2.599  
D2 - System Flow : 20.024  
D2 - System Pressure : 30.451  
Hose ( Demand ) : 3  
D3 - System Demand : 23.024  
Safety Margin : 23.856



# Fittings Used Summary

Fire & Life Safety America  
Oakhaven Lot 07 - Bedroom #3

Page 3  
Date 8/23/2021

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'EII Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

## Units Summary

Diameter Units                   Inches  
Length Units                     Feet  
Flow Units                        US Gallons per Minute  
Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

Fire & Life Safety America  
 Oakhaven Lot 07 - Bedroom #3

Page 4  
 Date 8/23/2021

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	54.5	13.5	417.0	54.307	23.02	30.451

## NODE ANALYSIS


<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S101	9.0	4.9	16.7	20.02	
101	10.0		17.32		
M101	10.0		19.17		
M102	10.0		22.31		
TOR	8.0		24.04		
BOR	3.0		27.53		
UG1	3.0		28.32	3.0	
UG2	-3.0		32.99		
UG3	-3.0		33.02		
TEST	3.0		30.45		

# Final Calculations : Hazen-Williams

Fire & Life Safety America  
Oakhaven Lot 07 - Bedroom #3

Page 5  
Date 8/23/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S101 to 101	9 10	4.90	20.02	1	2N	14.0 0.0	1.500 14.000	150	16.700 -0.433			
			20.02	1.101		0.0	15.500	0.0682	1.057	Vel =	6.75	
101			0.0 20.02						17.324	K Factor =	4.81	
101 to M101	10 10		20.02	1	N O	7.0 5.0	15.000 12.000	150	17.324 0.0			
			20.02	1.101		0.0	27.000	0.0682	1.841	Vel =	6.75	
M101			0.0 20.02						19.165	K Factor =	4.57	
M101 to M102	10 10		20.02	1	N	7.0 0.0	39.083 7.000	150	19.165 0.0			
			20.02	1.101		0.0	46.083	0.0682	3.143	Vel =	6.75	
M102 to TOR	10 8		0.0	1	N	7.0 0.0	5.750 7.000	150	22.308 0.866			
			20.02	1.101		0.0	12.750	0.0682	0.869	Vel =	6.75	
TOR			0.0 20.02						24.043	K Factor =	4.08	
TOR to BOR	8 3		20.02	1	Ball N	4.303 7.0	8.000 11.303	150	24.043 2.166			
			20.02	1.101		0.0	19.303	0.0682	1.316	Vel =	6.75	
BOR to UG1	3 3		0.0	1	2E	7.65 0.0	4.000 7.650	150	27.525 0.0			
			20.02	1.101		0.0	11.650	0.0682	0.795	Vel =	6.75	
UG1 to UG2	3 -3	H3	3.00	1.25	T 2E	9.523 9.523	55.000 19.046	150	28.320 2.599			
			23.02	1.394		0.0	74.046	0.0280	2.071	Vel =	4.84	
UG2 to UG3	-3 -3		0.0	6	2G 3E	9.25 64.749	1538.750 95.581	150	32.990 0.0			
			23.02	6.09	2F	21.583	1634.331	0	0.035	Vel =	0.25	
UG3 to TEST	-3 3		0.0	6	T 2E	43.037 40.168	1000.000 87.509	140	33.025 -2.599			
			23.02	6.16	G	4.304	1087.509	0	0.025	Vel =	0.25	
TEST			0.0 23.02						30.451	K Factor =	4.17	



Hydraulic calculations using HydraCALC

Fire & Life Safety America  
1731 Roundrock Drive  
Raleigh, NC 27615  
P: (919) 872-3250  
F: (919) 877-5775

Job Name : Oak Haven Lot 07 - RA2  
Drawing : FP1  
Location : 276 Oakhaven Drive  
Remote Area : RA2  
Contract : 21NC1531  
Data File : RA2.WXF



---

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** Oak Haven Lot 07

**Location:** 276 Oakhaven Drive

**Drawing no:** FP1

**Date:** 8/23/2021

**Design**

**Remote area number:** RA2

**Remote area location:** Bonus Room

**Occupancy classification:** Residential

**Density:** .05 - Gpm/SqFt

**Area of application:** 328 - SqFt

**Coverage per sprinkler:** 256 - SqFt

**Type of sprinklers calculated:** VK494

**No. of sprinklers calculated:** 2

**In-rack demand:** N/A - GPM

**Hose streams:** 3 - GPM

**Total water required (including hose streams):** 29.45 - GPM @ 29.22 - Psi

**Type of system:** WET

**Volume of dry or preaction system:** N/A - Gal

**Water supply information**

**Date:** 4/21/2021

**Location:** NC 42, NC 27540

**Source:** Fire & Life Safety America

**Name of contractor:** Fire & Life Safety America

**Address:** 1731 Roundrock Drive / Raleigh, NC 27615 / P: (919) 872-3250

**Phone number:** F: (919) 877-57

**Name of designer:** H. WEYANT

**Authority having jurisdiction:** Harnett County

**Notes: (Include peaking information or gridded systems here.)**

# Water Supply Curve C

Fire & Life Safety America  
Oak Haven Lot 07 - RA2


Page 2  
Date 8/23/2021

## City Water Supply:

C1 - Static Pressure : 54.5  
C2 - Residual Pressure: 13.5  
C2 - Residual Flow : 417

## Demand:

D1 - Elevation : 6.496  
D2 - System Flow : 26.448  
D2 - System Pressure : 29.218  
Hose ( Demand ) : 3  
D3 - System Demand : 29.448  
Safety Margin : 24.977



# Fittings Used Summary

Fire & Life Safety America  
Oak Haven Lot 07 - RA2

Page 3  
Date 8/23/2021

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'EI Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

## Units Summary

Diameter Units                      Inches  
 Length Units                        Feet  
 Flow Units                            US Gallons per Minute  
 Pressure Units                       Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

**SUPPLY ANALYSIS**

<b>Node at Source</b>	<b>Static Pressure</b>	<b>Residual Pressure</b>	<b>Flow</b>	<b>Available Pressure</b>	<b>Total Demand</b>	<b>Required Pressure</b>
TEST	54.5	13.5	417.0	54.196	29.45	29.218

**NODE ANALYSIS**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
S201	18.0	4.9	7.0	12.96	
S202	18.0	4.9	7.57	13.48	
201	19.0		6.81		
202	19.0		7.4		
M201	19.0		7.14		
M202	19.0		7.69		
M203	10.0		14.17		
M204	10.0		16.0		
TOR	8.0		20.16		
BOR	3.0		24.53		
UG1	3.0		25.86	3.0	
UG2	-3.0		31.72		
UG3	-3.0		31.78		
TEST	3.0		29.22		

# Final Calculations : Hazen-Williams

Fire & Life Safety America  
Oak Haven Lot 07 - RA2

Page 5  
Date 8/23/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S201 to 201	18 19	4.90	12.96 12.96	1 1.101	N	7.0 0.0 0.0	1.000 7.000 8.000	150	7.000 -0.433 0.244		Vel = 4.37	
201			0.0 12.96						6.811		K Factor = 4.97	
S202 to 202	18 19	4.90	13.48 13.48	1 1.101	N	7.0 0.0 0.0	1.000 7.000 8.000	150	7.572 -0.433 0.262		Vel = 4.54	
202			0.0 13.48						7.401		K Factor = 4.96	
201 to M201	19 19		12.96 12.96	1 1.101	N	7.0 0.0 0.0	3.667 7.000 10.667	150	6.811 0.0 0.325		Vel = 4.37	
M201			0.0 12.96						7.136		K Factor = 4.85	
202 to M202	19 19		13.48 13.48	1 1.101	O	5.0 0.0 0.0	3.667 5.000 8.667	150	7.401 0.0 0.285		Vel = 4.54	
M202			0.0 13.48						7.686		K Factor = 4.86	
M201 to M202	19 19		12.96 12.96	1 1.101		0.0 0.0 0.0	18.000 0.0 18.000	150	7.136 0.0 0.550		Vel = 4.37	
M202 to M203	19 10		13.49 26.45	1 1.101	N	7.0 0.0 0.0	15.667 7.000 22.667	150	7.686 3.898 2.586		Vel = 8.91	
M203 to M204	10 10		0.0 26.45	1 1.101	N	7.0 0.0 0.0	9.000 7.000 16.000	150	14.170 0.0 1.825		Vel = 8.91	
M204 to TOR	10 8		0.0 26.45	1 1.101	O 2N	5.0 14.0 0.0	9.917 19.000 28.917	150	15.995 0.866 3.300		Vel = 8.91	
TOR			0.0 26.45						20.161		K Factor = 5.89	
TOR to BOR	8 3		26.45 26.45	1 1.101	N Ball	7.0 4.303 0.0	8.000 11.303 19.303	150	20.161 2.166 2.202		Vel = 8.91	
BOR to UG1	3 3		0.0 26.45	1 1.101	2E	7.65 0.0 0.0	4.000 7.650 11.650	150	24.529 0.0 1.329		Vel = 8.91	
UG1 to UG2	3 -3	H3	3.00 29.45	1.25 1.394	T 2E	9.523 9.523 0.0	55.000 19.046 74.046	150	25.858 2.599 3.266		Vel = 6.19	
UG2 to UG3	-3 -3		0.0 29.45	6 6.09	2G 3E 2F	9.25 64.749 21.583	1538.750 95.581 1634.331	150	31.723 0.0 0.055		Vel = 0.32	
UG3 to TEST	-3 3		0.0 29.45	6 6.16	T 2E G	43.037 40.168 4.304	1000.000 87.509 1087.509	140	31.778 -2.599 0.039		Vel = 0.32	

# Final Calculations : Hazen-Williams

Fire & Life Safety America  
Oak Haven Lot 07 - RA2

Page 6  
Date 8/23/2021

Node1	Elev1	K	Qa	Nom	Fitting		Pipe	CFact	Pt			
to					or		Ftngs		Pe	*****	Notes	*****
Node2	Elev2	Fact	Qt	Act	Equiv	Len	Total	Pf/Ft	Pf			
			0.0									
TEST			29.45						29.218		K Factor =	5.45