Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit


IKEUED TO Adams Hamas	PROPERTY LOCATION: 43 Red Fine Ct (SR 1209)
ISSUED TO: Adams Homes NEW REPAIR EXPANSION	SUBDIVISION Cameron Woods LOT # 20
Type of Structure: 49' x 62' SFD	Site Improvements required prior to Construction Authorization Issuance:
Proposed Wastewater System Type: Pump to 25% reduction	
Projected Daily Flow: 480 GPD	
Number of bedrooms: 4 Number of Occupants: 8	max
Basement Yes X No	IIIdA
Pump Required: No May be required based on final!	ocation and elevations of facilities
Type of Water Supply: Community Public Well Distai	
Permit conditions:	No expiration
Authorized State Agent:: Ald WREH	Date: 02-04-22 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other	r permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This
	Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.	
<u> </u>	- 1 - 1 - 1 - 2 - 2 - 2 - 2 - 2 - 2 - 2
Consti	uction Authorization
(Re	quired for Building Permit)
The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957	.1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.	
ISSUED TO: Adams Homes	PROPERTY LOCATION: 43 Red Pine Ct (SR 1209)
1330ED 10. Maariis Fromes	
10' v 62' SED	
Facility Type: 49' x 62' SFD New	Expansion Repair
Basement? Yes No Basement Fixtures? Yes	⊠ No
Type of Wastewater System** Pump to 25% reduction	(Initial) Wastewater Flow: 480 GPD
(See note below, if applicable)	
Pump to 25% reduction	
Installation Requirements/Conditions Number of trend	hes <u>1</u>
Septic Tank Size 1000 gallons Exact length of	each trench 300feet
Pump Tank Size 1000 gallons Trenches shall be	installed on contour at a Soil Cover: 6inches
Maximum Trench	Depth of: 24inches (Maximum soil cover shall not exceed
	shall be level to +/-1/4" 36" above the trench bottom)
in all directions)	The second secon
Pump Requirements:ft. TDH vsGPM	inches below pipe
7 disp requirements	
Conditions:	
Conditions.	
WITTO LIVES (WELLIAMS INDICATED AND ASSESSMENT OF THE PROPERTY	
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM A	
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD ARE	1.
** If applicable: I understand the system type specified is different from	the type specified on the application. I accept the specifications of this permit.
applicable. I understand the system type specified is different from	the type specified on the application. Taccept the specifications of this permit.
Oursell and Barrandaire Simon	
Owner/Legal Representative Signature:	Date:
	changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This
Construction Authorization is subject to compliance with the provisions of the laws and Rules for	Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH
1/1/1 1/2 2	-//-
Authorized State, Agent:	Date: 02-04-22
Construction Authorization Expiration Date: Q2-Q4-27	

Harnett County Department of Public Health Site Sketch

Property Location: 43 Red Pine Ct (SR 1209)

Issued To: Adams Homes Subdivision Cameron Woods Lot # 20

Authorized State Agent: Date: 02-04-22



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.