


**PIEDMONT  
GEOTECHNICAL**



1669 Jimmie Kerr Rd., Haw River, NC 27258  
336-516-8634, NC Firm No. C-1634

May 5, 2022

Adams Homes  
149 US Hwy 70 West  
Garner, NC

Attention Matt Galvin 919-903-0735, Matt matt.galvin@adamshomes.com, raleighadmin@adamshomes.com,  
raleighpermits@adamshomes.com, bjohnson@adamshomes.com



Engineering - Field Observation, Stem Wall Backfill Testing  
Lot 9 Cameron Woods Subdivision  
196 Western Pine Way, Sanford NC  
Project No. 22PG-0327-D-1 (22PG-0503-E), Harnett County, Permit No. SFD-2108-0087

Dear Mr. Galvin,

Thank you for using Piedmont Geotechnical. The site was visited on May 3, 2022 to test the subgrade/fill for the footprint of the proposed home. The subgrade/fill soils consisting of red tan silty sands were tested with a Dynamic Cone Penetrometer (DCP) testing in general accordance with (ASTM) special publication 399. Testing has been conducted to about 4 feet below the bottom of slab elevation.

Based on the observation and testing, the subgrade has been adequately compacted to support the proposed loads (2000 psf) of the slab.

Sincerely,

  
022595  
May 5, 2022  


D. Allen Hughes, P.E., President  
Piedmont Geotechnical, Inc., P.A.