

October 20th, 2023

Joshua Becker
817 Cokesbury Park Lane
Fuquay Varina, NC 27526

Re: Notice of Intent to Revoke: Joshua Becker 145 Stonemason Dr Permit/Construction Authorization – Application # SFD2108-0100

To whom it may concern,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are Set by surveyor need to be visible. (\$25.00 Fee incurred)
- 2. Use orange flags to mark house corners (\$25.00 fee incurred)
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs undergrowth cleared, do not disturb the soil
- 5. Driveway not shown on site plan
- 6. Backhoe pits required

7. Other- The Harnett County Department of Public Health inspected the site for the on-site wastewater system located at 145 Stonemason Dr. for compliance with the Laws (Article 11 of Chapter 130A of the North Carolina General Statutes), Rules (15A NCAC 18A .1900 et seq.), and Improvement Permit/Construction Authorization #28630, application #15-5-37645 soil depth conditions. As a result of this inspection, the Department has determined the following Violations: Lot has been scraped out septic system cannot be installed as permitted. Will need a Soil Scientist Layout to proceed.

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7525 ext. 1 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation. Any questions I can be reached at **910-893-7547** between 8-9 AM Monday-Friday.

Sincerely,



James Manhart R.E.H.S.
Environmental Health Program Specialist
Harnett County Department of Public Health

JM/kh