



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

6/29/2022

SUBJECT: SFD2109-0012
SINGLE FAMILY DWELLING

To: G.C. Adams Construction, Inc.

Here are the results of all Inspections located at **251 PLACID POND DR:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 12/6/2021
Completed Date/Time: 12/6/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 12/1/2021 12:08 PM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: T-POLE
Scheduled Date/Time: 12/6/2021
Completed Date/Time: 12/6/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 12/1/2021 12:09 PM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com

Inspection Type: FOUNDATION
Scheduled Date/Time: 12/15/2021
Completed Date/Time: 12/15/2021
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 12/14/2021 11:33 AM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com

Inspector SPG changed the inspection assignment from SPG to SBL

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 1/5/2022
Completed Date/Time: 1/5/2022
Inspector: Scott Guy
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/3/2022 3:06 PM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com

Inspector SBL changed the inspection assignment from SBL to TSG



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time: 1/12/2022
Completed Date/Time: 1/12/2022
Inspector: Kimberly Gibbons
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 1/27/2022
Completed Date/Time: 1/27/2022
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/26/2022 7:27 AM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com

Plumbing pressure test down. Duct work must be r-8. Header cased opening. Ok to side and insulate.

Inspection Type: GAS PIPING
Scheduled Date/Time: 1/27/2022
Completed Date/Time: 1/27/2022
Inspector: Steven Gazlay
Result: CANCELLED
Remarks: eTRAKiT Inspection Request
Notes: 1/26/2022 7:28 AM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 2/1/2022
Completed Date/Time: 2/1/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/31/2022 1:38 PM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com

Inspector SPG changed the inspection assignment from SPG to SBL

Inspection Type: INSULATION
Scheduled Date/Time: 2/1/2022
Completed Date/Time: 2/1/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/31/2022 1:39 PM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com

Inspector SPG changed the inspection assignment from SPG to SBL

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 5/12/2022
Completed Date/Time: 5/12/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 5/11/2022 2:04 PM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 5/12/2022
Completed Date/Time: 5/12/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 5/11/2022 2:03 PM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 5/12/2022
Completed Date/Time: 5/12/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 5/11/2022 2:04 PM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.
Site Address: 251 PLACID POND DR
Phone: 9198687700
e-Mail: cameron.adams1087@gmail.com

Inspection Type: ENV OPERATIONS PERMIT
Scheduled Date/Time: 5/23/2022
Completed Date/Time: 5/23/2022
Inspector: Oliver Tolksdorf
Result: APPROVED
Remarks:
Notes: EOP



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL SFD CRAWL**
Scheduled Date/Time: 6/17/2022
Completed Date/Time: 6/17/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 6/16/2022 1:59 PM G.C. Adams Construction, Inc.

Contact Name: G.C. Adams Construction, Inc.

Site Address: 251 PLACID POND DR

Phone: 9198687700

e-Mail: cameron.adams1087@gmail.com