



HANGER LEGEND

◆ = USP THF25140 / Single I-Joist Hanger

Beam Legend

PlotID	Length	Product	Plies	Net Qty	Fab Type
BM4	11' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	4	FF
BM3	7' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	4	FF
BM2	6' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	2	FF
GDH	22' 0"	1-3/4"x 11-7/8" LVL Kerto-S	3	3	FF
BM1	20' 0"	1-3/4"x 18" LVL Kerto-S	3	3	FF

I-Joist Legend

PlotID	Length	Product	Plies	Net Qty	Fab Type
IJ1	39' 8 13/16"	14" NI-40x	1	5	FF
IJ2	28' 3"	14" NI-40x	1	10	FF
IJ3	17' 5 7/16"	14" NI-40x	1	2	FF
IJ4	11' 4 1/2"	14" NI-40x	1	2	FF
IJ5	11' 0 3/4"	14" NI-40x	1	10	FF
IJ6	8' 3"	14" NI-40x	1	1	FF
IJ7	3' 9"	14" NI-40x	1	1	FF
IJ8	3' 5 5/8"	14" NI-40x	1	1	FF
RIM1	12' 0"	1 1/8" x 14" Rim Board	1	14	FF
	2' 11"	Backer Blocks (14" NI-40x)	1	2	Other
	2' 0 3/4"	Backer Blocks (14" NI-40x)	1	2	Other
	1' 3 1/4"	Backer Blocks (14" NI-40x)	1	2	Other
	1' 2 1/2"	Backer Blocks (14" NI-40x)	1	2	Other
	1' 0 3/4"	Backer Blocks (14" NI-40x)	1	2	Other
	1' 0"	Backer Blocks (14" NI-40x)	1	12	Other
		Web Stiffeners (14" NI-40x)	1	51	Other

Truss Placement Plan
SCALE: 1/4" = 1'

LOAD CHART FOR JACK STUDS
(BASED ON TABLES R502.5(1) & (2))
NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADERS

END REACTION (UP TO) (DOWN TO) (TOTAL) (BY HEADER)	END REACTION (UP TO) (DOWN TO) (TOTAL) (BY HEADER)	END REACTION (UP TO) (DOWN TO) (TOTAL) (BY HEADER)
1700	2550	3400
3400	5100	6800
5100	7650	10200
6800	10200	13600
8500	12750	17000
10200	15300	
11900		
13600		
15300		

BUILDER	Cates Building, Inc.	CITY / CO.	Cameron / Harnett
JOB NAME	Lot 702 Lexington Plantation	ADDRESS	Lot 702 Lexington Plantation
PLAN	CC-2560 / 2ND FLOOR I-JOIST	MODEL	31500
SEAL DATE	2/1/21	DATE REV.	08/18/21
QUOTE #	B1020-4961	DRAWN BY	Curtis Quick
JOB #	J0821-4966	SALES REP.	Scot Duncan

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.
These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature: Curtis Quick
Curtis Quick

comTECH

ROOF & FLOOR TRUSSES & BEAMS

Reilly Road Industrial Park
Fayetteville, N.C. 28309
Phone: (910) 864-8787
Fax: (910) 864-4444