
## Harnett County Department of Public Health

## Improvement Permit A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION, 44 Glenmont Creek Place (US 401S) ISSUED 10 H&H Constructors SUBDIVISION Williams Farm NEW X REPAIR [ EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 40' x 53' SFD Proposed Wastewater System Type: pump to 25% reduction \_ GPD Projected Daily Flow. 480 Number of bedrooms: 4 Number of Occupants: 8 max Basement Yes Type of Water Supply: Community Public Well Distance from well feet Permit valid for: X Five years No expiration Date \_\_\_ SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met Systems shall be installed in accordance ISSUED TO H&H Constructors PROPERTY LOCATION: 44 Glenmont Creek Place (US 401S) SUBDIVISION Williams Farm Facility Type: 40' x 53' SFD Expansion Repair Basement fixtures? Yes Basement? Yes ⋉ No X No Type of Wastewater System\*\* pump to 25% reduction (Initial) Wastewater Flow: 480 (See note below, if applicable 1 pump to 25% reduction Installation Requirements/Conditions Number of trenches 3 Septic Tank Size 1000 Exact length of each trench 50 Trench Spacing: 9 Feet on Center Pump Tank Size 1000 Trenches shall be installed on contour at a Soil Cover: 6 \_\_\_\_\_inches gallons Maximum Trench Depth of: 18"-22" inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft TDH vs GPM inches below pipe Aggregate Depth: inches above pipe inches total Conditions WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. "Il applicable | understand the system type specified is different from the type specified on the application I accept the specifications of this permit Owner/Legal Representative Signature: This Construction Authorization is subject to resociation of the site offer over or the intended are charges. The construction Authorization shall not be triansferred when there is a charge in ownership of the site. This Construction Authorization is subject to compliance with the processor, of the Japan and Rule, for Newage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Date: . . Construction Authorization Expiration Date:

## Harnett County Department of Public Health Site Sketch



GLENMONT CREEK PLACE

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.