## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 1533 McArthur Rd (SR1280) ISSUED TO: Lamco Custom Builders SUBDIVISION REPAIR 🗍 Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 53' x 58' SFD Proposed Wastewater System Type: Pump to 25% reduction Projected Daily Flow: 360 GPD Number of bedrooms: 3\_ Number of Occupants: 6 Basement Yes May be required based on final location and elevations of facilities Pump Required: XYes No Type of Water Supply: Community 🗵 Public 🗌 Well Distance from well \_\_\_\_\_\_\_feet Permit valid for: X Five years No expiration Permit conditions: \_\_\_ Date: 10-25-21 Authorized State Agent::

Date: 10-25-21

SEE ATTACHED SITE SKEICH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 1533 McArthur Rd (SR1280) ISSUED TO: Lamco Custom Builders SUBDIVISION Repair Facility Type: 53' x 58' SFD ✓ New Expansion Basement Fixtures? Yes Basement? Yes No Pump to 25% reduction (Initial) Wastewater Flow: 360 GPD Type of Wastewater System\*\* (See note below, if applicable ) Pump to 25% reduction Number of trenches 2 Installation Requirements/Conditions Trench Spacing: 9 Feet on Center Exact length of each trench 90 Septic Tank Size 1000 gallons Soil Cover: 6 \_\_\_\_inches Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 26" - 16" inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_\_ft. TDH vs. \_\_\_\_\_ WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the layes and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 10-25-21 Authorized State Agent: Construction Authorization Expiration Date: 10-25-26

## Harnett County Department of Public Health Site Sketch

sued To: Lamco Custom Builders	Subdivision		Lot #
uthorized State Agent: Mol	MREH	Date:	)-25-21
		•	
	FUTUR 25 % Sorduction Repair Arm		# STANT Trem @ 26" + E.
O'SETBACK	Repair Arm	10'SETBACK	- Makes S
· <del> </del>	12.0' 24.7'  PORCH ** 16.5'  PROPOSED DWELLING	49.0'	of Cover of Dain (
44.3	PROPOSED DWELLING BROOKLYN PLAN	5 /	

- Medrihur Rd ->

PORCH &

GARAGE

47.32