Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

Revised for Curtain Drain + Plumbing Location

PROPERTY LOCATION 369 Peach Farm Rd (SR1251) ISSUED 10: Jonathan Prevette CHRDIVISION Site Improvements required prior to Construction Authorization Issuance: EXPANSION | REPAIR Type of Structure: 69' x 86 SFD Proposed Wastewater System Type: 25% reduction Projected Daily Flow: 480 GPD Number of bedrooms: 4 Number of Occupants: 8 Basement Tres Pump Required: Yes No May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well leet X Five years Permit valid for: No expiration Permit conditions: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met Systems shall be installed in accordance with the attached tystem layout PROPERTY LOCATION: 369 Peach Farm Rd (SR1251) ISSUED TO: Jonathan Prevette SUBDIVISION Repair facility Type: 69' x 86 SFD Expansion X New Basement? Yes X No Basement Fixtures? Tes (Initial) Wastewater Flow: 480 GPD 25% reduction Type of Wastewater System** (See note below, if applicable) 25% reduction Number of trenches 4 Installation Requirements/Conditions Trench Spacing: 9 Feet on Center Exact length of each trench 75 Septic Tank Size 1000 gallons Soil Cover: 6 Trenches shall be installed on contour at a Pump Tank Size Maximum Trench Depth of: 18" - 24" inches (Maximum soil cover shall not exceed 36" above the trench bottom) (Trench bottoms shall be level to +/-1/4" in all directions) inches below pipe Pump Requirements: ft. TDH vs. ____ Aggregate Depth: ______ inches above pipe inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to comphance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit 4-12-23 4-12-28

Construction Authorization Expiration Date: _

Harnett County Department of Public Health Site Sketch

