



BARTLETT
ENGINEERING & SURVEYING, PC

1906 Nash Street North Wilson, NC 27893-1726
Phone: (252) 399-0704 Fax: (252) 399-0804
robert@bartletteng.com

February 11, 2022

REFERENCE: 1037 Atkins Rd
Wake County

To whom it may concern:

I, Robert S Bartlett, hereby certify that I evaluated the footing excavations for the foundation for the residence at 1037 Atkins Road. There is a small amount of ground water in some areas of the footing excavations. A pump will be used to remove water as much as practical. It is understood that some residual water will remain, but this will not be detrimental to the structural integrity. The footings will support the design loads and are in compliance with the intent of the applicable building codes.

Note that subsurface geotechnical investigations were not performed beyond hand probe depth and therefore unknown subsurface conditions may exist.

If you have any questions or need additional information, please call.

Sincerely,

Bartlett Engineering & Surveying, PC



Robert S Bartlett, PE