



BARTLETT
ENGINEERING & SURVEYING, PC

1906 Nash Street North Wilson, NC 27893-1726
Phone: (252) 399-0704 Fax: (252) 399-0804
robert@bartletteng.com

March 3, 2022

REFERENCE: 1037 Atkins Rd
Wake County

To whom it may concern:

I, Robert S Bartlett, hereby certify that I evaluated the concrete foundation footings for the foundation for the residence at 1037 Atkins Road. Specifically, the concrete footings are 24" wide and project a minimum of 4" beyond each side of the CMU block stem wall. The footings will support the design loads and are in compliance with the intent of the applicable building codes.

Note that subsurface geotechnical investigations were not performed beyond hand probe depth and therefore unknown subsurface conditions may exist.

If you have any questions or need additional information, please call.

Sincerely,

Bartlett Engineering & Surveying, PC



Robert S Bartlett, PE