## Harnett County Department of Public Health


Improvement Permit A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 1037 Atkins Road (SR 1448) ISSUED TO: Cunningham Construction Group LLC SUBDIVISION Site Improvements required prior to Construction Authorization Issuance: REPAIR EXPANSION Type of Structure: 4-Bedroon 96'x69' SFD Proposed Wastewater System Type: 25% Reduction Sys. Projected Daily Flow: 480 GPD Number of Occupants: 8 Number of bedrooms: 4 Basement Yes May be required based on final location and elevations of facilities Pump Required: Yes × No Type of Water Supply: Community Public Well Distance from well 50+ Permit valid for: X Five years No expiration Permit conditions: 11/01/2021 SEE ATTACHED SITE SKETCH Authorized State Agent:: \_ The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Cunningham Construction Group L PROPERTY LOCATION: 1037 Atkins Road (SR 1448) LOT # 7A SUBDIVISION Facility Type: 4-Bedroon 96'x69' SFD Expansion Repair Basement Fixtures? Yes Basement? Yes ☐ No 25% Reduction System (Initial) Wastewater Flow: 480 Type of Wastewater System\*\* GPD (See note below, if applicable ) 25% Reduction System Number of trenches 3 Installation Requirements/Conditions Exact length of each trench 90 Septic Tank Size 1250 Trench Spacing: 9 Feet on Center gallons Trenches shall be installed on contour at a Soil Cover: 14 inches Pump Tank Size \_\_\_\_\_ Maximum Trench Depth of: 26 (Maximum soil cover shall not exceed \_inches (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) NA inches below pipe Pump Requirements: \_\_\_\_\_\_ft. TDH vs. \_ Aggregate Depth: NA inches above pipe NA Conditions: Gravity to D-Box Equal Distribution inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Construction Authorization Expiration Date: 11/01/2026

Authorized State Agent:

ANDREW CUMIN

## Harnett County Department of Public Health Site Sketch



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.