
## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 64 Simply Country Ln. (US 401 N.) ISSUED TO: Stephenson Builders Inc. SUBDIVISION Morgan Farm EXPANSION | REPAIR Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 61x56 sfd, 3 beds 2.5 baths Proposed Wastewater System Type: 25% Reduction Sys. Projected Daily Flow: 360 GPD Number of Occupants: 6 Number of bedrooms: 3 Basement Yes May be required based on final location and elevations of facilities Pump Required: XYes No Public Well Distance from well NA feet Permit valid for: X Five years Type of Water Supply: Community No expiration Permit conditions: 11/09/2021 Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Stephenson Builders Inc. PROPERTY LOCATION: 64 Simply Country Ln. (US 401 N.) subdivision Morgan Farm Facility Type: 61x56 sfd, 3 beds 2.5 bat Expansion Basement Fixtures? Yes Basement? Yes Type of Wastewater System\*\* 25% TEDUCTION (Initial) Wastewater Flow: 360 GPD (See note below, if applicable ) 25% ENGTON STS. Installation Requirements/Conditions Number of trenches Septic Tank Size 1000 gallons Exact length of each trench Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 20 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM inches below pipe inches above pipe RUMP TO MEDIUM D-BOX EWAL DISTUBUTION NA inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Date: 11/09/2021 ANDREW CURRIN Construction Authorization Expiration Date:

## Harnett County Department of Public Health Site Sketch

Property Location: 64 Simply Country L	n. (US 401 N.)		
Issued To: Stephenson Builders Inc.	Subdivision Morgan Farm		Lot # 27
Authorized State Agent:	AMPREN CORRIED	Date: _	11/05/2021



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.

SIMPLY CONTY LN.