

Products Plies Net Qty Fab Type PlotID Length Product 9-0-0 1-3/4"x 9-1/4" LVL Kerto-S FF Cased Opening USP HJC26 Varies 16d/3-1/2" 10d/3" Front GDH 20-0-0 1-3/4"x 11-7/8" LVL Kerto-S 3

5-3-0

V1

J1(11)

||1-11-8||2-0-0||2-q-0||2-0-0||2-0-0||2-0-0||2-0-0||2-0-0||

Front GDH

19-8-0

A11

A12

13-1-0

🛕 = Indicates Left End of Truss (Reference Engineered Truss Drawing) Do NOT Erect Truss Backwards

Truss Placement Plan SCALE: 1/4"=1'											
	LOAD CHART FOR JACK STUDS (BASED ON TABLES R502.5(1) & (b)) NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADER/GRDER										
	END REACTION (UP TO)	REQ D STUDS FOR (2) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (3) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (4) PLY HEADER			
	1700	1		2550	1		3400	1			
	3400	2		5100	2		6800	2			
	5100	3		7650	3		10200	3			
	6800	4		10200	4		13600	4			
	8500	5		12750	5		17000	5			
	10200	6		15300	6						
	11900	7									
	13600	8									
	15300	9									

2-0-0 6

2-0-0

B2

B2

B1

2-0-0

BUILDER	Signature Home Builders	CITY / CO.	Erwin / Harnett	THI The the i
JOB NAME	Lot 11 Wildwood	ADDRESS	Lot 11 Wildwood	is re the d walls rega
PLAN	Dorchester C GR3C	MODEL	Roof	Bear pres
SEAL DATE	4/28/20	DATE REV.	09/24/21	four than be re
QUOTE#	B0819-3803	DRAWN BY	Marshall Naylor	retai
JOB#	J0821-5062	SALES REP.	Anthony Williams	

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.

These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

2-0-0 2-0-0 2-0-0 2-0-0 2-0-0 2-0-0

12-0-0

J2

2-9-8

2-0-0

Searing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables derived from the prescriptive Code requirements) to determine the minimum oundation size and number of wood studs required to support reactions greater han 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be etained to design the support system for all reactions that exceed 15000#.

Marshall Naylor

TRUSSES & BEAMS Fayetteville, N.C. 28309 Marshall Naylor

Reilly Road Industrial Park Phone: (910) 864-8787 Fax: (910) 864-4444

соттесн

ROOF & FLOOR