

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: *WATER HOUSE INC*
 Address: *3032 MATTHEW MILL* (Date Evaluated: *11/25/2021*)
 Proposed Facility: _____ Design Flow (.1949): *260 GPD*
 Location of Site: *3rd St* Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

LOT 3

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
<i>1,3</i>	<i>L 3%</i>	<i>C-1B</i>	<i>GL LS</i>	<i>VM NSMP</i>					<i>PS</i>
		<i>B-44</i>	<i>OL SL</i>	<i>OL SSSP</i>	<i>7.5" @ 42"</i>	<i>44</i>			<i>C. 375</i>
<i>2</i>	<i>L 3%</i>	<i>C-1B</i>	<i>GL LS</i>	<i>VM NSMP</i>					<i>PS</i>
		<i>B-42</i>	<i>M SIL</i>	<i>FN SSSP</i>	<i>7.5" @ 30"</i>	<i>42</i>			<i>C. 375</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PROVISIONALLY SUITABLE</i> Evaluated By: Others Present: <i>ANDREW CUMMINGS</i>
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<i>25/6" ID</i>	<i>25/6" ID</i>	
Site LTAR	<i>C. 375</i>	<i>C. 375</i>	

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTLY STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM	S-STICKY VS-VERY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY SC-SANDY CLAY			

- STRUCTURE**
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

- MINERALOGY**
 SLIGHTLY EXPANSIVE
 EXPANSIVE

MATTHEWS MILL POND

Show profile locations and other site features (dimensions, references or benchmark, and North)

