Harnett County Department of Public Health

Improvement Permit A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 80 Prince Place Dr. (Christian Lt. Rd. - SR ISSUED TO: Halcyon Homes, LLC SUBDIVISION Prince Place EXPANSION REPAIR Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 44.8x64.4(4bed/2.5) Proposed Wastewater System Type: 25% Reduction Sys. Projected Daily Flow: 480 Number of bedrooms: 4 Number of Occupants: 8 Basement Yes ☐ No Pump Required: Yes May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well NA X Five years Permit valid for: No expiration Permit conditions: SEE ATTACHED SITE SKETCH Authorized State Agent:: Date: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Halcyon Homes, LLC PROPERTY LOCATION: 80 Prince Place Dr. (Christian Lt. Rd. - S SUBDIVISION Prince Place Facility Type: 44.8x64.4(4bed/2.5) ➤ New Expansion Basement? Yes X No Basement Fixtures? Yes X No 25% reaction STOTEM Type of Wastewater System** (Initial) Wastewater Flow: 480 (See note below, if applicable) 25% renoction STSTIEM (Repair) Installation Requirements/Conditions Number of trenches Trench Spacing: 9 Septic Tank Size 1000 gallons Exact length of each trench Pump Tank Size _____gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 20 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: _____ ft. TDH vs. __ inches below pipe Aggregate Depth: inches above pipe GNAVITY TO D-DOX EGUAL DISTRIBUTION inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: Date: 12/06/2021

ANTONIO Construction Authorization Expiration Date: 12/06/2026

Harnett County Department of Public Health Site Sketch

Property Location: 80 Prince Place Dr. (Christian Lt. Rd. - SR 1412) Issued To: Halcyon Homes, LLC Subdivision Prince Place Lot # 67 Authorized State Agent: Date: 12/06/2021 S 8 * INSTALL AS LIGHT UPHILL AS CONTOOR ALLOWS prop scheen S M poperd house 2011-2020 (see motes) cov parch 1.62 proposed

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.