





Most Demanding Single Head Information		Most Demanding Two Head Information	
Information	Results	Information	Results
Flow Required at Head (GPM):	17	Flow Required at Head (GPM):	13
Source Pressure at Head (PSI):	12.03	Source Pressure at Head (PSI):	7.04
Maximum Spacing (length):	18	Maximum Spacing (length):	16
Maximum Spacing (Width):	18	Maximum Spacing (Width):	16
Domestic Flow Added (GPM):	0	Domestic Flow Added (GPM):	0
Sprinkler Model:	RFC49	Sprinkler Model:	RFC49
Elevation of Highest Head:	117	Elevation of Highest Head:	117
K-Factor	4.9	K-Factor	4.9
Temperature Rating:	155	Temperature Rating:	155
Flow Required at Source (GPM)	17	Flow Required at Source (GPM)	26.5706
Pressure Required at Source (psi)	40.49	Pressure Required at Source (psi)	55.02
Source Reference Point:	At Ref Pt STR	Source Reference Point:	At Ref Pt STR
C-Factor of Sprinkler Pipe	150	C-Factor of Sprinkler Pipe	150
C-Factor of Service Line	150	C-Factor of Service Line	150
Head Reference Point:	H.13	Head Reference Point:	H.11 & H.12

- 19  
**RFC49-16**  
 RELIABLE Model RFC49Concealed Pendent Spr FP  
 K=4.9, 155F°, 7/16" Orifice, Maximum Spacing 16'x16'  
 Sprinkler head demand: 13 gpm @ 7.04
- 1  
**RFC49-18**  
 RELIABLE Model RFC49Concealed Pendent Spr FP  
 K=4.9, 155F°, 7/16" Orifice, Maximum Spacing 18'x18'  
 Sprinkler head demand: 17 gpm @ 12.03
- 1  
**R49-16-175**  
 RELIABLE Model F1-R49-< Recess Pendent Spr 1-4 DN  
 K=4.9, 175F°, 7/16" Orifice, Maximum Spacing 16'x16'  
 Sprinkler head demand: 13 gpm @ 7.04

SPRINKLER DESCRIPTIONS



LEGEND	
	Manifold
	Inter Level Connection
	Hot Water Fixture
	Cold Water Fixture
	Type K Copper w/ ProPress Fittings
	Type L Copper w/ ProPress Fittings
	Type M Copper w/ ProPress Fittings
	ViegaPEX Ultra Black
	ViegaPEX Ultra Blue - Cold Plumbing
	ViegaPEX Ultra Red - Hot Plumbing



WATER SERVICE DETAIL

VEIEGA LLC'S DESIGN SERVICES DEPARTMENT HAS PREPARED THIS SERIES OF DRAWINGS AS THE FIRST DESIGN FOR PLUMBING, RADIANT, SNOW MELTING OR FIRE SUPPRESSION SYSTEMS FOR THE USE OF YOU, OUR CUSTOMER, IN PREPARING / OBTAINING SPECIFICATIONS, BIDS AND PROPOSALS IN RELATION TO THE SALE OF THESE SYSTEMS. THESE DRAWINGS ARE BASED UPON INFORMATION PROVIDED BY YOU AND HAVE BEEN PREPARED TO APPROPRIATE PROFESSIONAL STANDARDS OF DESIGN BASED UP THAT INFORMATION. THESE DRAWINGS ARE NOT TO BE CONSIDERED FINAL AND, PRIOR TO PERFORMING ANY WORK ASSOCIATED WITH THESE DESIGNS OR DRAWINGS, YOU MUST:

- 1) CHECK AND CONFIRM ALL PIPE SIZES, CALCULATIONS, MATERIALS, PLUMBING AND / OR FIRE CODES USED OR APPLICABLE; AND
- 2) PRESENT THE DRAWINGS TO YOUR PROFESSIONAL ENGINEER FOR REVIEW AND APPROVAL AND HAVE THE DRAWINGS MARKED "FINAL" BY YOUR PROFESSIONAL ENGINEER.

IF YOUR PROFESSIONAL ENGINEER REPORTS ANY ERRORS IN THE DRAWINGS OR MAKES ANY CHANGES IN THE DRAWINGS, THESE ERRORS OR CHANGES MUST BE COMMUNICATED TO VEIEGA LLC'S DESIGN SERVICES DEPARTMENT FOR A DETERMINATION IF A REVISION TO THE DESIGN IS NECESSARY.

VEIEGA LLC DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, ASSOCIATED WITH THE DESIGN OF THE SYSTEM OR ITS USE. ALL DESIGNS ARE PROVIDED "AS IS" AND IT IS YOUR SOLE RESPONSIBILITY TO CONFIRM AND ENSURE THAT THE SYSTEM TO BE INSTALLED WILL OPERATE AND FUNCTION IN COMPLIANCE WITH ALL APPLICABLE CODES AND IN ACCORDANCE WITH ALL APPLICABLE SPECIFICATIONS.

**Design Services Department**  
 1900 Southwood Drive - Nashua, NH 03063  
 Tel: 877-843-4262 x 351 Fax: 316-425-8466

Project:  
**OAKHAVEN LOT 12**  
**HOLLY SPRINGS, NC 27540**

Dwg no.:	FP 1
Title:	1ST FLOOR PLAN
Quotation no.:	FPNM2106-008 NC
Drawn by:	N.M.
Approved by:	
Date Submitted:	6/30/2021
Scale:	1/4" = 1'
Revision No.:	Revision Date:


VEIGA LLC'S DESIGN SERVICES DEPARTMENT HAS PREPARED THIS SERIES OF DRAWINGS AS THE FIRST DESIGN FOR PLUMBING, RADIANT, SNOW MELTING OR FIRE SUPPRESSION SYSTEMS FOR THE USE OF YOU, OUR CUSTOMER, IN PREPARING / OBTAINING SPECIFICATIONS, BIDS AND PROPOSALS IN RELATION TO THE SALE OF THESE SYSTEMS. THESE DRAWINGS ARE BASED UPON INFORMATION PROVIDED BY YOU AND HAVE BEEN PREPARED TO APPROPRIATE PROFESSIONAL STANDARDS OF DESIGN BASED UP THAT INFORMATION. THESE DRAWINGS ARE NOT TO BE CONSIDERED FINAL AND, PRIOR TO PERFORMING ANY WORK ASSOCIATED WITH THESE DESIGNS OR DRAWINGS, YOU MUST:

- 1) CHECK AND CONFIRM ALL PIPE SIZES, CALCULATIONS, MATERIALS, PLUMBING AND / OR FIRE CODES USED OR APPLICABLE; AND
- 2) PRESENT THE DRAWINGS TO YOUR PROFESSIONAL ENGINEER FOR REVIEW AND APPROVAL AND HAVE THE DRAWINGS MARKED "FINAL" BY YOUR PROFESSIONAL ENGINEER.

IF YOUR PROFESSIONAL ENGINEER REPORTS ANY ERRORS IN THE DRAWINGS OR MAKES ANY CHANGES IN THE DRAWINGS, THESE ERRORS OR CHANGES MUST BE COMMUNICATED TO VEIGA LLC'S DESIGN SERVICES DEPARTMENT FOR A DETERMINATION IF A REVISION TO THE DESIGN IS NECESSARY.

VEIGA LLC DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, ASSOCIATED WITH THE DESIGN OF THE SYSTEM OR ITS USE. ALL DESIGNS ARE PROVIDED "AS IS" AND IT IS YOUR SOLE RESPONSIBILITY TO CONFIRM AND ENSURE THAT THE SYSTEM TO BE INSTALLED WILL OPERATE AND FUNCTION IN COMPLIANCE WITH ALL APPLICABLE CODES AND IN ACCORDANCE WITH ALL APPLICABLE SPECIFICATIONS.

**Design Services Department**  
 1900 Southwood Drive - Nashua, NH 03063  
 Tel: 877-843-4262 x 351 Fax: 316-425-8466



2nd Floor 11 Sprinklers

Project:

OAKHAVEN LOT 12  
 HOLLY SPRINGS, NC 27540

Dwg no.:  
 FP 2

Title:  
 2ND FLOOR PLAN

Quotation no.: FPNM2106-008 NC

Drawn by: N.M.

Approved by:

Date Submitted: 6/30/2021

Scale: 1/4" = 1'

Revision No: Revision Date:

**FIRE PROTECTION INSTALLATION NOTES:**

1. INSTALLATION OF THE FIRE PROTECTION SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE 2016 EDITION OF NFPA 13D OR SECTION P2904 OF THE 2018 INTERNATIONAL RESIDENTIAL CODE (IRC). NFPA 13D IS THE STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS IN ONE- AND TWO-FAMILY DWELLINGS AND MANUFACTURED HOMES.
2. INSTALLATION OF THE FIRE PROTECTION SYSTEM SHALL COMPLY WITH ALL LOCAL RESIDENTIAL FIRE PROTECTION CODES AND ALL APPLICABLE STATE REGULATIONS.
3. SPRINKLER HEADS SHALL MEET ALL GENERAL CARE AND INSTALLATION REQUIREMENTS OF THE SPRINKLER MANUFACTURER. SUBSTITUTION OF SPRINKLER HEADS IS NOT PERMITTED.
4. AFTER INSTALLATION OF THE SPRINKLERS, THE ENTIRE SYSTEM SHALL BE PRESSURE TESTED IN ACCORDANCE WITH STATE AND LOCAL CODE REQUIREMENTS. SPRINKLERS SHALL BE LOCATED PER THE LAYOUT. DO NOT INSTALL SPRINKLERS IN AREAS EXPOSED TO TEMPERATURES THAT EXCEED THE MAXIMUM RECOMMENDED AMBIENT TEMPERATURE FOR THE TEMPERATURE RATING USED. MINIMUM DISTANCE OF SPRINKLER HEADS FROM HEAT SOURCES SHALL COMPLY WITH TABLE 7.5.6.3 IN THE 2016 EDITION OF NFPA 13D, INSTALLATION OF SPRINKLER SYSTEMS IN ONE - AND TWO - FAMILY DWELLINGS AND MANUFACTURED HOMES.
5. NO DEVIATIONS FROM THE PLAN SHALL BE ALLOWED WITHOUT APPROVAL FROM THE AUTHORITY HAVING JURISDICTION AND DESIGNER.
6. PIPING AND SPRINKLER FITTINGS SHALL BE SUPPORTED IN COMPLIANCE WITH LOCAL PLUMBING CODE AND THE 2016 EDITION OF NFPA 13D, INSTALLATION OF SPRINKLER SYSTEMS IN ONE - AND TWO - FAMILY DWELLINGS AND MANUFACTURED HOMES.
7. SMOKE DETECTORS SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 72, NATIONAL FIRE ALARM CODE. WHEN NOT EQUIPPED WITH SMOKE DETECTORS, LOCAL WATERFLOW ALARMS SHALL BE REQUIRED.
8. WATER SOFTENERS AND WATER FILTRATION DEVICES SHALL NOT BE INSTALLED IN THE SYSTEM WITHOUT A REVIEW OF THE HYDRAULIC CALCULATIONS OF THE SYSTEM.
9. A SIGN SHALL BE AFFIXED ADJACENT TO THE MAIN SHUTOFF VALVE THAT STATES IN MINIMUM 1/4" LETTERS, "WARNING: THE WATER SYSTEM FOR THIS HOME SUPPLIES FIRE SPRINKLERS THAT REQUIRE CERTAIN FLOWS AND PRESSURES TO FIGHT A FIRE. DEVICES THAT RESTRICT THE FLOW OR DECREASE THE PRESSURE OR AUTOMATICALLY SHUT OFF THE WATER TO THE FIRE SPRINKLER SYSTEM, SUCH AS WATER SOFTENERS, FILTRATION SYSTEMS, AND AUTOMATIC SHUT-OFF VALVES, SHALL NOT BE ADDED TO THIS SYSTEM WITHOUT A REVIEW OF THE FIRE SPRINKLER SYSTEM BY A FIRE PROTECTION SPECIALIST. DO NOT REMOVE THIS SIGN."
10. ALL PIPING AND FITTINGS SHALL BE PROPERLY INSULATED AND PROTECTED SO THAT THEY ARE NOT EXPOSED TO TEMPERATURES BELOW 40° F.
11. WHEN THE MAXIMUM STATIC PRESSURE EXCEEDS 80 PSI, A PRESSURE-REDUCING VALVE SHALL BE INSTALLED. NFPA 13D RESTRICTS THE OPERATING PRESSURE OF PEX SYSTEMS TO 80 PSI. PRESSURE DROP THROUGH THE PRESSURE-REDUCING DEVICE SHALL BE INCLUDED IN THE HYDRAULIC CALCULATIONS.
12. WHEN A FIRE DEPARTMENT CONNECTION IS REQUIRED, PEX TUBING SHALL NOT BE PERMITTED. CONSULT WITH THE AUTHORITY HAVING JURISDICTION (AHJ) ABOUT THIS REQUIREMENT PRIOR TO INSTALLATION.

**PLUMBING INSTALLATION NOTES:**

1. INSTALLATION OF HOT AND COLD WATER DISTRIBUTION SYSTEMS SHALL BE IN ACCORDANCE WITH THE LOCAL PLUMBING CODE.
2. WATER SOFTENERS AND WATER FILTRATION DEVICES SHALL NOT BE INSTALLED WITHOUT A REVIEW OF THE HYDRAULIC CALCULATIONS OF THE SYSTEM.
3. FINAL APPROVAL OF MULTIPURPOSE AND PASSIVE PURGE FIRE SPRINKLER INSTALLATIONS SHALL BE FROM THE AUTHORITY HAVING JURISDICTION.

**TESTING:**


1. EVERY VIEGA NFPA 13D FIRE PROTECTION INSTALLATION SHALL BE PRESSURE TESTED IN ACCORDANCE WITH NFPA 13D, WHICH STATES THAT SYSTEMS WITHOUT FIRE DEPARTMENT CONNECTIONS SHALL BE TESTED FOR LEAKAGE AT THE NORMAL SYSTEM OPERATING WATER PRESSURE.
2. THE AUTHORITY HAVING JURISDICTION (AHJ) MAY REQUIRE A FLOW VERIFICATION TEST OF THE MOST HYDRAULICALLY REMOTE SPRINKLER HEAD(S). THIS FLOW VERIFICATION TEST IS AVAILABLE TO ENSURE THE INSTALLED FIRE PROTECTION SYSTEM OPERATES AS DESIGNED. DOCUMENTATION ON HOW TO PERFORM A FLOW VERIFICATION TEST IS AVAILABLE THROUGH VIEGA TECHNICAL SERVICES.
3. THE FLOW VERIFICATION TEST SHALL BE PERFORMED AFTER ALL PIPING, FITTINGS, SPRINKLER HEADS AND PLUMBING CONNECTIONS HAVE BEEN INSTALLED AND PRESSURE TESTING OF THE SYSTEM HAS BEEN COMPLETED. THE FLOW TEST SHOULD OCCUR WHILE IN THE "ROUGH" STAGE OF CONSTRUCTION. FLOW TEST RESULTS SHOULD BE COMPARED TO THE SYSTEM DESIGN VALUES. RESIDUAL PRESSURE (PSI) AND FLOW (GPM) MUST BE EQUAL TO OR GREATER THEN THE DESIGN VALUES TO ENSURE A PROPERLY FUNCTIONING SYSTEM.

**DRAWING AND DESIGN NOTES:**


1. DESIGN SHALL ENSURE WATER SUPPLY TO THE MOST HYDRAULICALLY DEMANDING SINGLE AND DUAL SPRINKLER HEADS.
2. TUBING AND FITTINGS SHALL BE U.L. LISTED FOR RESIDENTIAL FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
3. VIEGAFEX ULTRA (BLACK IN COLOR) LISTED TO U.L. 1821 FOR RESIDENTIAL WET-PIPE FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
4. VIEGA PEX PRESS FITTINGS (POLYMER AND BRONZE) LISTED TO U.L. 1821 FOR RESIDENTIAL WET-PIPE FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
5. APPROVED SMOKE DETECTION SYSTEMS AND/OR WATER FLOW ALARMS SHALL BE INSTALLED WHERE REQUIRED BY THE AUTHORITY HAVING JURISDICTION (AHJ).

**MATERIALS LIST NOTES:**


1. SERVICE ENTRANCE MATERIALS FROM WATER MAIN CONNECTION TO DISTRIBUTION MANIFOLD ARE EXCLUDED.
2. SPRINKLERS AND ASSOCIATED ESCUTCHEONS OR COVER PLATES ARE NOT SUPPLIED BY VIEGA.
3. MATERIAL LIST IS SUGGESTED ONLY. CONTRACTOR SHALL CONFIRM REQUIRED MATERIALS PRIOR TO PLACEMENT OF ORDER.




**FIGURE A.9.1.1(a) Insulation Recommendations — Arrangement 1.**




**FIGURE A.9.1.1(b) Insulation Recommendations — Arrangement 2.**



**FIGURE A.9.1.1(c) Insulation Recommendations — Arrangement 3.**



**FIGURE A.9.1.1(d) Insulation Recommendations — Arrangement 4.**



**FIGURE A.9.1.1(e) Insulation Recommendations — Arrangement 5.**

**INSULATION DETAILS - ANNEX A.9.1.1 (NFPA 13D 2016)**





WATER METER PRESSURE LOSSES (PSI) - TABLE 10.4.4(A) NFPA 13D (2016)						
Meter Size (in.)	Flow (gpm)					
	18 or less	23	26	31	39	52
5/8"	9	14	18	26	38	*
3/4"	7	11	14	22	35	*
1"	2	3	3	4	6	10
1-1/2"	1	1	2	2	4	7
2"	1	1	1	1	2	3

**TABLE 10.4.4(a) (NFPA 13D 2016)**

DISTANCES FROM HEAT SOURCES - TABLE 7.5.6.3 NFPA 13D (2016)		
Heat Source	Ordinary Temp. 135°-170°	Intermediate Temp. 175°-220°
Side of Fireplace	36"	12"
Front of Fireplace	60"	36"
Coal or Wood Burning Stove	42"	12"
Kitchen Range	18"	9"
Wall Oven	18"	9"
Hot Air Flues	18"	9"
Uninsulated Heat Ducts	18"	9"
Uninsulated Hot Water Pipes	12"	6"
Side of Hot Air Diffusers	24"	12"
Front of Hot Air Diffusers	36"	18"
Hot Water Heater or Furnace	6"	3"
Light Fixture 0 W - 250 W	6"	3"
Light Fixture 250 W - 499 W	12"	6"

**TABLE 7.5.6.3 (NFPA 13D 2016)**

**INSTALLATION NOTES**



**INSTALLATION DETAIL - SPRINKLER BRACKETS**

Project:

**OAKHAVEN LOT 12  
HOLLY SPRINGS, NC 27540**

Dwg no.:

**FP 3**

Title:

**NOTES & DETAILS**

Quotation no.: FPNM2106-008 NC

Drawn by: N.M.

Approved by:

Date Submitted: 6/30/2021

Scale: N/A

Revision No: Revision Date:



# viega



Viega LLC  
Technical Services Department  
1900 Southwood Drive  
Nashua, NH 03063  
603-882-7171

Job Name : OAKHAVEN LOT 12 - One Head Calculation (H.13)  
Building : SINGLE FAMILY RESIDENCE  
Location : HOLLY SPRINGS NC 27540  
System : NFPA 13D  
Contract : FPNM2106-008 NC  
Data File : FPNM2106-008 NC ( Oakhaven Dr - Lot 12).wx1

HYDRAULIC DESIGN INFORMATION SHEET

Name - OAKHAVEN LOT 12 Date - 6/30/2021  
Location -  
Building - SINGLE FAMILY RESIDENCE System No. - NFPA 13D  
Contractor - x Contract No. - FPNM2106-008 NC  
Calculated By - VIEGA LLC Drawing No. - FPNM2106-008 NC  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height 9  
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ( )NFPA 13 Residential ( )NFPA 13R (X)NFPA 13D  
Y Number of Sprinklers Flowing: (X)1 ( )2 ( )4 ( )

S ( )Other

T ( )Specific Ruling Made by Date

E  
M Listed Flow at Start Point - 17 Gpm System Type  
Listed Pres. at Start Point - 12.03Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 18 x 18 ( ) Deluge ( ) PreAction  
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle  
S Additional Flow Added - Gpm Make RELIABLE Model RFC49  
I Elevation at Highest Outlet - 117 Feet Size 7/16 K-Factor 4.9  
G Note: Temperature Rating 155  
N

Calculation Gpm Required 17 Psi Required 40.49 At Ref Pt STR  
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - x Rated Cap. Cap.  
T Time of Test - x @ Psi Elev.  
E Static (Psi) - 60 Elev.  
R Residual (Psi) - 20 Other Well  
Flow (Gpm) - 168 Proof Flow Gpm  
S Elevation - 100

P Location: x  
P  
L Source of Information: x  
Y


# Water Supply Curve C

Viega LLC  
OAKHAVEN LOT 12 - One Head Calculation (H.13)

Page 2  
Date 6/30/2021

City Water Supply:  
C1 - Static Pressure : 60  
C2 - Residual Pressure: 20  
C2 - Residual Flow : 168

Demand:  
D1 - Elevation : 7.363  
D2 - System Flow : 16.995  
D2 - System Pressure : 40.490  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 16.995  
Safety Margin : 18.933



# Fittings Used Summary

Viega LLC  
OAKHAVEN LOT 12 - One Head Calculation (H.13)

Page 3  
Date 6/30/2021

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	1	1	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Vpel *	PEX Press 90 Elbow - Poly	12.6	18.9	17.7	18.6	29.4	36.4	0	0	0											
Vprt *	PEX Press Tee - Run-Poly	3.9	3.6	3.8	6.4	7.9	10.2	0	0	0											
Vptb *	PEX Press Tee - Branch-Poly	14	19.1	18.4	18.7	28.3	37.5	0	0	0											

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

# Flow Summary - NFPA 2007

Viega LLC  
 OAKHAVEN LOT 12 - One Head Calculation (H.13)

Page 4  
 Date 6/30/2021

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	60.0	20	168.0	59.423	17.0	40.49

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
H.13	117.0	4.9	12.03	17.0	
H.20	117.0		13.07		
H.17	117.0		13.91		
H.8	117.0		14.59		
T.26	117.0		15.0		
T.25	117.0		16.66		
T.29	108.0		21.05		
T.30	108.0		22.83		
T.33	108.0		22.98		
H.14	108.0		23.17		
H.18	108.0		23.51		
T.34	108.0		24.08		
H.16	108.0		24.43		
H.15	108.0		24.64		
T.31	108.0		25.36		
T.32	108.0		25.58		
S.1	104.0		28.56		
MTR	100.0		38.44		
STR	100.0		40.49		
H.11	117.0		12.81		
H.19	117.0		13.7		
H.12	117.0		14.61		
T.24	117.0		15.03		
T.23	117.0		16.76		
T.27	108.0		21.17		
T.28	108.0		23.04		
H.9	108.0		24.9		
H.5	117.0		15.0		
H.1	117.0		15.01		
T.22	117.0		15.02		
H.2	117.0		15.02		
H.3	117.0		15.03		
H.7	108.0		22.86		
H.4	108.0		22.94		
H.6	108.0		23.02		



# Final Calculations - Hazen-Williams

Viega LLC  
OAKHAVEN LOT 12 - One Head Calculation (H.13)

Page 5  
Date 6/30/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.13 to H.20	9.16	0.863 150.0	Vprt	3.8 0.0	16.000 3.800	12.030 0.0			K Factor = 4.90	
H.20 to H.17	9.16	0.0526 150.0		0.0	19.800	1.041			Vel = 5.02	
H.20 to H.17	0.0	0.863 150.0		0.0	16.000	13.071				
H.17 to H.8	9.16	0.0526 150.0		0.0	16.000	0.841			Vel = 5.02	
H.17 to H.8	0.0	0.863 150.0	Vprt	3.8 0.0	9.000 3.800	13.912 0.0				
H.8 to T.26	9.16	0.0527 150.0		0.0	12.800	0.674			Vel = 5.02	
H.8 to T.26	0.0	0.863 150.0	Vprt	3.8 0.0	4.000 3.800	14.586 0.0				
T.26 to T.25	9.16	0.0526 150.0		0.0	7.800	0.410			Vel = 5.02	
T.26 to T.25	-0.75	0.863 150.0	Vptb Vpel	18.4 17.7	1.000 36.100	14.996 0.0				
T.25 to T.29	8.41	0.0449 150.0		0.0	37.100	1.664			Vel = 4.61	
T.25 to T.29	0.0	0.863 150.0		0.0	11.000	16.660				
T.29 to T.30	8.41	0.0449 150.0		0.0	11.000	0.494			Vel = 4.61	
T.29 to T.30	0.0	0.863 150.0	Vptb Vpel	18.4 17.7	3.487 36.100	21.052 0.0				
T.30 to T.33	8.41	0.0449 150.0		0.0	39.587	1.776			Vel = 4.61	
T.30 to T.33	-2.04	0.863 150.0	Vprt	3.8 0.0	2.000 3.800	22.828 0.0				
T.33 to H.14	6.37	0.0269 150.0		0.0	5.800	0.156			Vel = 3.49	
T.33 to H.14	0.0	0.863 150.0	Vprt	3.8 0.0	3.000 3.800	22.984 0.0				
H.14 to H.18	6.37	0.0268 150.0		0.0	6.800	0.182			Vel = 3.49	
H.14 to H.18	0.0	0.863 150.0	Vprt	3.8 0.0	9.000 3.800	23.166 0.0				
H.18 to T.34	6.37	0.0268 150.0		0.0	12.800	0.343			Vel = 3.49	
H.18 to T.34	0.0	0.863 150.0	Vptb	18.4 0.0	3.000 18.400	23.509 0.0				
T.34 to H.16	6.37	0.0268 150.0		0.0	21.400	0.574			Vel = 3.49	
T.34 to H.16	0.0	0.863 150.0	Vprt	3.8 0.0	9.000 3.800	24.083 0.0				
H.16 to H.15	6.37	0.0269 150.0		0.0	12.800	0.344			Vel = 3.49	
H.16 to H.15	0.0	0.863 150.0	Vprt	3.8 0.0	4.000 3.800	24.427 0.0				
H.15 to T.31	6.37	0.0268 150.0		0.0	7.800	0.209			Vel = 3.49	
H.15 to T.31	0.0	0.863 150.0	Vptb Vprt	18.4 3.8	5.000 22.200	24.636 0.0				
T.31 to T.32	6.37	0.0268 150.0		0.0	27.200	0.729			Vel = 3.49	
T.31 to T.32	10.63	1.025 150.0		0.0	3.000	25.365				
T.32 to T.32	17.0	0.0713 150.0		0.0	3.000	0.214			Vel = 6.61	
T.32 to S.1	0.0	1.025 150.0	E T	2.7 6.75	8.000 9.450	25.579 1.732				
T.32 to S.1	17.0	0.0713 150.0		0.0	17.450	1.245			Vel = 6.61	

# Final Calculations - Hazen-Williams

Viega LLC  
OAKHAVEN LOT 12 - One Head Calculation (H.13)

Page 6  
Date 6/30/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S.1 to MTR	0.0 17.0	1.053 150.0 0.0626	2E	2.429 0.0	80.000 2.429 82.429	28.556 4.732 5.157			** Fixed Loss = 3 Vel = 6.26	
MTR to STR	0.0 17.0	1.049 150.0 0.0637	E T G	3.022 7.555 1.511	20.000 12.089 32.089	38.445 0.0 2.045			Vel = 6.31	
	0.0 17.00					40.490			K Factor = 2.67	
H.13 to H.11	7.83 7.83	0.863 150.0 0.0393	Vprt	3.8 0.0	16.000 3.800 19.800	12.030 0.0 0.778			Vel = 4.29	
H.11 to H.19	0.0 7.83	0.863 150.0 0.0393	Vprt	3.8 0.0	19.000 3.800 22.800	12.808 0.0 0.897			Vel = 4.29	
H.19 to H.12	0.0 7.83	0.863 150.0 0.0393		0.0 0.0	23.000 0.0 23.000	13.705 0.0 0.904			Vel = 4.29	
H.12 to T.24	0.0 7.83	0.863 150.0 0.0394	Vprt	3.8 0.0	7.000 3.800 10.800	14.609 0.0 0.425			Vel = 4.29	
T.24 to T.23	0.75 8.58	0.863 150.0 0.0466	Vptb Vpel	18.4 17.7	1.000 36.100 37.100	15.034 0.0 1.729			Vel = 4.71	
T.23 to T.27	0.0 8.58	0.863 150.0 0.0465		0.0 0.0	11.000 0.0 11.000	16.763 3.898 0.512			Vel = 4.71	
T.27 to T.28	0.0 8.58	0.863 150.0 0.0466	Vptb Vpel	18.4 17.7	4.000 36.100 40.100	21.173 0.0 1.869			Vel = 4.71	
T.28 to H.9	2.05 10.63	0.863 150.0 0.0691	Vprt	3.8 0.0	23.000 3.800 26.800	23.042 0.0 1.853			Vel = 5.83	
H.9 to T.31	0.0 10.63	0.863 150.0 0.0691	Vprt	3.8 0.0	3.000 3.800 6.800	24.895 0.0 0.470			Vel = 5.83	
	0.0 10.63					25.365			K Factor = 2.11	
T.26 to H.5	0.75 0.75	0.863 150.0 0.0005	Vprt	3.8 0.0	5.000 3.800 8.800	14.996 0.0 0.004			Vel = 0.41	
H.5 to H.1	0.0 0.75	0.863 150.0 0.0005	Vprt	3.8 0.0	21.000 3.800 24.800	15.000 0.0 0.013			Vel = 0.41	
H.1 to T.22	0.0 0.75	0.863 150.0 0.0005	Vprt	3.8 0.0	9.000 3.800 12.800	15.013 0.0 0.007			Vel = 0.41	
T.22 to H.2	0.0 0.75	0.863 150.0 0.0		0.0 0.0	1.000 0.0 1.000	15.020 0.0 0.0			Vel = 0.41	

# Final Calculations - Hazen-Williams

Viega LLC  
OAKHAVEN LOT 12 - One Head Calculation (H.13)

Page 7  
Date 6/30/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.2 to H.3	0.0 0.75	0.863 150.0 0.0005	Vprt 3.8 0.0 0.0	8.000 3.800 11.800	15.020 0.0 0.006		Vel = 0.41		
H.3 to T.24	0.0 0.75	0.863 150.0 0.0005	Vprt 3.8 0.0 0.0	11.000 3.800 14.800	15.026 0.0 0.008		Vel = 0.41		
	0.0 0.75				15.034		K Factor = 0.19		
T.30 to H.7	2.04 2.04	0.863 150.0 0.0033	Vprt 3.8 0.0 0.0	6.000 3.800 9.800	22.828 0.0 0.032		Vel = 1.12		
H.7 to H.4	0.0 2.04	0.863 150.0 0.0033	Vprt 3.8 0.0 0.0	20.000 3.800 23.800	22.860 0.0 0.078		Vel = 1.12		
H.4 to H.6	0.0 2.04	0.863 150.0 0.0033	Vprt 3.8 0.0 0.0	20.000 3.800 23.800	22.938 0.0 0.078		Vel = 1.12		
H.6 to T.28	0.0 2.04	0.863 150.0 0.0033	Vprt 3.8 0.0 0.0	4.000 3.800 7.800	23.016 0.0 0.026		Vel = 1.12		
	0.0 2.04				23.042		K Factor = 0.42		



# viega



Viega LLC  
Technical Services Department  
1900 Southwood Drive  
Nashua, NH 03063  
603-882-7171

Job Name : OAKHAVEN LOT 12 - Two Head Calculation (H.11 & H.12)  
Building : SINGLE FAMILY RESIDENCE  
Location : HOLLY SPRINGS NC 27540  
System : NFPA 13D  
Contract : FPNM2106-008 NC  
Data File : FPNM2106-008 NC ( Oakhaven Dr - Lot 12).wx2

HYDRAULIC DESIGN INFORMATION SHEET

Name - OAKAHAVEN LOT 12 Date - 6/30/2021  
Location -  
Building - SINGLE FAMILY RESIDENCE System No. - NFPA 13D  
Contractor - x Contract No. - FPNM2106-008 NC  
Calculated By - VIEGA LLC Drawing No. - FPNM2106-008 NC  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height 9  
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ( )NFPA 13 Residential ( )NFPA 13R (X)NFPA 13D  
Y Number of Sprinklers Flowing: ( )1 (X)2 ( )4 ( )

S ( )Other

T ( )Specific Ruling Made by Date

E  
M Listed Flow at Start Point - 13 Gpm System Type  
Listed Pres. at Start Point - 7.04 Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 16 x 16 ( ) Deluge ( ) PreAction  
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle  
S Additional Flow Added - Gpm Make RELIABLE Model RFC49  
I Elevation at Highest Outlet - 117 Feet Size 7/16 K-Factor 4.9  
G Note: Temperature Rating 155  
N

Calculation Gpm Required 26.5706 Psi Required 55.02 At Ref Pt STR  
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - x Rated Cap. Cap.  
T Time of Test - x @ Psi Elev.  
E Static (Psi) - 60 Elev.  
R Residual (Psi) - 20 Other Well  
Flow (Gpm) - 168 Proof Flow Gpm  
S Elevation - 100

P Location: x  
P  
L Source of Information: x  
Y

# Water Supply Curve C

Viega LLC  
OAKHAVEN LOT 12 - Two Head Calculation (H.11 & H.12)


Page 2  
Date 6/30/2021

### City Water Supply:

C1 - Static Pressure : 60  
C2 - Residual Pressure: 20  
C2 - Residual Flow : 168

### Demand:

D1 - Elevation : 7.363  
D2 - System Flow : 26.571  
D2 - System Pressure : 55.018  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 26.571  
Safety Margin : 3.663



# Fittings Used Summary

Viega LLC  
OAKHAVEN LOT 12 - Two Head Calculation (H.11 & H.12)

Page 3  
Date 6/30/2021

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	1	1	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Vpel *	PEX Press 90 Elbow - Poly	12.6	18.9	17.7	18.6	29.4	36.4	0	0	0											
Vprt *	PEX Press Tee - Run-Poly	3.9	3.6	3.8	6.4	7.9	10.2	0	0	0											
Vptb *	PEX Press Tee - Branch-Poly	14	19.1	18.4	18.7	28.3	37.5	0	0	0											

## Units Summary

Diameter Units           Inches  
Length Units               Feet  
Flow Units                 US Gallons per Minute  
Pressure Units             Pounds per Square Inch

# Flow Summary - NFPA 2007

Viega LLC  
 OAKHAVEN LOT 12 - Two Head Calculation (H.11 & H.12)

Page 4  
 Date 6/30/2021

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	60.0	20	168.0	58.681	26.57	55.018

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
H.11	117.0	4.9	7.04	13.0	
H.13	117.0		7.96		
H.20	117.0		8.88		
H.17	117.0		9.62		
H.8	117.0		10.22		
T.26	117.0		10.58		
T.25	117.0		14.19		
T.29	108.0		19.16		
T.30	108.0		23.01		
T.33	108.0		23.37		
H.14	108.0		23.78		
H.18	108.0		24.56		
T.34	108.0		25.86		
H.16	108.0		26.63		
H.15	108.0		27.11		
T.31	108.0		28.76		
T.32	108.0		29.25		
S.1	104.0		33.83		
MTR	100.0		50.34		
STR	100.0		55.02		
H.19	117.0		7.35		
H.12	117.0	4.9	7.67	13.57	
T.24	117.0		9.65		
T.23	117.0		13.8		
T.27	108.0		18.93		
T.28	108.0		23.42		
H.9	108.0		27.68		
H.3	117.0		9.84		
H.2	117.0		9.98		
T.22	117.0		10.0		
H.1	117.0		10.16		
H.5	117.0		10.47		
H.7	108.0		23.08		
H.4	108.0		23.22		
H.6	108.0		23.37		



# Final Calculations - Hazen-Williams

Viega LLC  
OAKHAVEN LOT 12 - Two Head Calculation (H.11 & H.12)

Page 5  
Date 6/30/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.11 to H.13	8.57	0.863 150.0	Vprt	3.8 0.0	16.000 3.800	7.040 0.0			K Factor = 4.90	
H.13 to H.20	8.57	0.0464 150.0		0.0	19.800	0.919			Vel = 4.70	
H.13 to H.20	0.0	0.863 150.0	Vprt	3.8 0.0	16.000 3.800	7.959 0.0				
H.20 to H.17	8.57	0.0464 150.0		0.0	19.800	0.919			Vel = 4.70	
H.20 to H.17	0.0	0.863 150.0		0.0	16.000 0.0	8.878 0.0				
H.17 to H.8	8.57	0.0464 150.0		0.0	16.000	0.743			Vel = 4.70	
H.17 to H.8	0.0	0.863 150.0	Vprt	3.8 0.0	9.000 3.800	9.621 0.0				
H.8 to T.26	8.57	0.0464 150.0		0.0	12.800	0.594			Vel = 4.70	
H.8 to T.26	0.0	0.863 150.0	Vprt	3.8 0.0	4.000 3.800	10.215 0.0				
T.26 to T.25	4.22	0.863 150.0	Vptb Vpel	18.4 17.7	1.000 36.100	10.577 0.0				
T.25 to T.29	12.79	0.0974 150.0		0.0	37.100	3.613			Vel = 7.02	
T.25 to T.29	0.0	0.863 150.0		0.0	11.000 0.0	14.190 3.898				
T.29 to T.30	12.79	0.0974 150.0		0.0	11.000	1.071			Vel = 7.02	
T.29 to T.30	0.0	0.863 150.0	Vptb Vpel	18.4 17.7	3.487 36.100	19.159 0.0				
T.30 to T.33	12.79	0.0974 150.0		0.0	39.587	3.855			Vel = 7.02	
T.30 to T.33	-2.88	0.863 150.0	Vprt	3.8 0.0	2.000 3.800	23.014 0.0				
T.33 to H.14	9.91	0.0607 150.0		0.0	5.800	0.352			Vel = 5.44	
T.33 to H.14	0.0	0.863 150.0	Vprt	3.8 0.0	3.000 3.800	23.366 0.0				
H.14 to H.18	9.91	0.0607 150.0		0.0	6.800	0.413			Vel = 5.44	
H.14 to H.18	0.0	0.863 150.0	Vprt	3.8 0.0	9.000 3.800	23.779 0.0				
H.18 to T.34	9.91	0.0608 150.0		0.0	12.800	0.778			Vel = 5.44	
H.18 to T.34	0.0	0.863 150.0	Vptb	18.4 0.0	3.000 18.400	24.557 0.0				
T.34 to H.16	9.91	0.0607 150.0		0.0	21.400	1.299			Vel = 5.44	
T.34 to H.16	0.0	0.863 150.0	Vprt	3.8 0.0	9.000 3.800	25.856 0.0				
H.16 to H.15	9.91	0.0608 150.0		0.0	12.800	0.778			Vel = 5.44	
H.16 to H.15	0.0	0.863 150.0	Vprt	3.8 0.0	4.000 3.800	26.634 0.0				
H.15 to T.31	9.91	0.0606 150.0		0.0	7.800	0.473			Vel = 5.44	
H.15 to T.31	0.0	0.863 150.0	Vptb Vprt	18.4 3.8	5.000 22.200	27.107 0.0				
T.31 to T.32	9.91	0.0607 150.0		0.0	27.200	1.652			Vel = 5.44	
T.31 to T.32	16.66	1.025 150.0		0.0	3.000 0.0	28.759 0.0				
T.32	26.57	0.1630		0.0	3.000	0.489			Vel = 10.33	

# Final Calculations - Hazen-Williams

Viega LLC  
OAKHAVEN LOT 12 - Two Head Calculation (H.11 & H.12)

Page 6  
Date 6/30/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
T.32 to S.1	0.0 26.57	1.025 150.0 0.1631	E T	2.7 6.75 0.0	8.000 9.450 17.450	29.248 1.732 2.846		Vel = 10.33		
S.1 to MTR	0.0 26.57	1.053 150.0 0.1430	2E	2.429 0.0 0.0	80.000 2.429 82.429	33.826 4.732 11.786		** Fixed Loss = 3 Vel = 9.79		
MTR to STR	0.0 26.57	1.049 150.0 0.1457	E T G	3.022 7.555 1.511	20.000 12.089 32.089	50.344 0.0 4.674		Vel = 9.86		
	0.0 26.57					55.018		K Factor = 3.58		
H.11 to H.19	4.43 4.43	0.863 150.0 0.0137	Vprt	3.8 0.0 0.0	19.000 3.800 22.800	7.040 0.0 0.313		Vel = 2.43		
H.19 to H.12	0.0 4.43	0.863 150.0 0.0137		0.0 0.0 0.0	23.000 0.0 23.000	7.353 0.0 0.316		Vel = 2.43		
H.12 to T.24	13.57 18.0	0.863 150.0 0.1834	Vprt	3.8 0.0 0.0	7.000 3.800 10.800	7.669 0.0 1.981		K Factor = 4.90 Vel = 9.87		
T.24 to T.23	-4.22 13.78	0.863 150.0 0.1119	Vptb Vpel	18.4 17.7 0.0	1.000 36.100 37.100	9.650 0.0 4.151		Vel = 7.56		
T.23 to T.27	0.0 13.78	0.863 150.0 0.1119		0.0 0.0 0.0	11.000 0.0 11.000	13.801 3.898 1.231		Vel = 7.56		
T.27 to T.28	0.0 13.78	0.863 150.0 0.1119	Vptb Vpel	18.4 17.7 0.0	4.000 36.100 40.100	18.930 0.0 4.487		Vel = 7.56		
T.28 to H.9	2.88 16.66	0.863 150.0 0.1590	Vprt	3.8 0.0 0.0	23.000 3.800 26.800	23.417 0.0 4.261		Vel = 9.14		
H.9 to T.31	0.0 16.66	0.863 150.0 0.1590	Vprt	3.8 0.0 0.0	3.000 3.800 6.800	27.678 0.0 1.081		Vel = 9.14		
	0.0 16.66					28.759		K Factor = 3.11		
T.24 to H.3	4.22 4.22	0.863 150.0 0.0125	Vprt	3.8 0.0 0.0	11.000 3.800 14.800	9.650 0.0 0.185		Vel = 2.31		
H.3 to H.2	0.0 4.22	0.863 150.0 0.0125	Vprt	3.8 0.0 0.0	8.000 3.800 11.800	9.835 0.0 0.148		Vel = 2.31		
H.2 to T.22	0.0 4.22	0.863 150.0 0.0130		0.0 0.0 0.0	1.000 0.0 1.000	9.983 0.0 0.013		Vel = 2.31		
T.22 to H.1	0.0 4.22	0.863 150.0 0.0125	Vprt	3.8 0.0 0.0	9.000 3.800 12.800	9.996 0.0 0.160		Vel = 2.31		

# Final Calculations - Hazen-Williams

Viega LLC  
OAKHAVEN LOT 12 - Two Head Calculation (H.11 & H.12)

Page 7  
Date 6/30/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.1 to H.5	0.0 4.22	0.863 150.0 0.0125	Vprt	3.8 0.0 0.0	21.000 3.800 24.800	10.156 0.0 0.311		Vel = 2.31	
H.5 to T.26	0.0 4.22	0.863 150.0 0.0125	Vprt	3.8 0.0 0.0	5.000 3.800 8.800	10.467 0.0 0.110		Vel = 2.31	
	0.0 4.22					10.577		K Factor = 1.30	
T.30 to H.7	2.88	0.863 150.0 0.0062	Vprt	3.8 0.0 0.0	6.000 3.800 9.800	23.014 0.0 0.061		Vel = 1.58	
H.7 to H.4	0.0 2.88	0.863 150.0 0.0062	Vprt	3.8 0.0 0.0	20.000 3.800 23.800	23.075 0.0 0.147		Vel = 1.58	
H.4 to H.6	0.0 2.88	0.863 150.0 0.0062	Vprt	3.8 0.0 0.0	20.000 3.800 23.800	23.222 0.0 0.147		Vel = 1.58	
H.6 to T.28	0.0 2.88	0.863 150.0 0.0062	Vprt	3.8 0.0 0.0	4.000 3.800 7.800	23.369 0.0 0.048		Vel = 1.58	
	0.0 2.88					23.417		K Factor = 0.60	