## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 128 Ramble Falls Ln. (Old Stage Rd. S. - S. ISSUED TO: Wellons Realty Inc SUBDIVISION WILDWOOD EXPANSION REPAIR Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 3-Bedroom 49'x49' SFD Proposed Wastewater System Type: 25% Reuction Sys. Projected Daily Flow: 360 GPD Number of Occupants: 6 Number of bedrooms: 3 Basement Yes Pump Required: Yes ⊠ No May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: X Five years ■ No expiration Permit conditions: 12/07/2021 Authorized State Agent:: \_-The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Wellons Realty Inc. PROPERTY LOCATION: 128 Ramble Falls Ln. (Old Stage Rd. S. SUBDIVISION WILDWOOD Facility Type: 3-Bedroom 49'x48' SFD Expansion Basement Fixtures? Yes Basement? Yes ☐ No 25% reaction STETEL Type of Wastewater System\*\* (Initial) Wastewater Flow: 360 GPD (See note below, if applicable ) 25% NEDUCTION SISTEM Installation Requirements/Conditions Number of trenches \_feet Trench Spacing: 7 Feet on Center Exact length of each trench 96 Septic Tank Size 1000 gallons Soil Cover: 12 Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_\_ft. TDH vs. \_\_\_ inches below pipe Aggregate Depth: ~A inches above pipe Conditions: GRANITY TO D-BOX EGUAL DISTRIBUTION IFOUNTED WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Cull Tate: 12/07/2021 ANSTENS COMON Construction Authorization Expiration Date: 12/67/2026

## Harnett County Department of Public Health Site Sketch

Property Location: 128 Ramble Falls Ln.	(Old Stage Rd. S SR 1769)	
Issued To: Wellons Realty Inc	Subdivision Wildwood	Lot # 17
		- 30 CHR2764 74 152 S. S.

Authorized State Agent: Date: 12/07/2021

