Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section Sheet: Property ID: Lot #:

File #: Code: 500 2111-0070

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

		WELDWOOD SID
Owner: - Applicant: WELLOWS REALTY TINE.		
Address: 117 namore Talls Date Evaluated: 12/07/2021		LOT 4
Proposed Facility: Design Flow (.1949):	Property Size:	
Location of Site: 360 ST Property Recorded: 360 GC		
Water Supply: Public Individual Well	☐ Spring	Other
Evaluation Method: Auger Boring Pit Cu	t	
Type of Wastewater: Sewage Industrial Process	☐ Mixed	
V		

P R O F I L E	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
2	L 3%	0-10	CAL LS	ML MSMP					es
		10.48	m su	VAL MSNP FN SP		40			0.35
						e p			
					6				
							11.		

Description	Initial	Repair System	Other Factors (.1946):	
	System		Site Classification (.1948):	PARVISION
Available Space (.1945)	V		Evaluated By:	
System Type(s)	25% 1257	2590 TED	Others Present:	ANME
Site LTAR	0.35	0.35		

E PROVISIONALLY SUITABLE
ANOREN WRUN, NEHS

COMMENTS: ____

LANDSCAPE POSITIONS	<u>GROUP</u>	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	П	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	Ш	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

ΙV SIC-SILTY CLAY 0.4 - 0.1 C-CLAY

SC-SANDY CLAY

STRUCTURE SG-SINGLE GRAIN M- MASSIVE CR-CRUMB **GR-GRANULAR** SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY PL-PLATY

MINERALOGY SLIGHTLY EXPANSIVE



