Harnett County Department of Public Health

Operation Permit PERMIT # 550 2111-0072 521765 Mew Installation Meric Septic Tank Meric Nitrification Line Repair Expansion PROPERTY LOCATION: 164 RAMPLE FALLS LN. (OLD STAGE RD S.) WILDWOOD SUBDIVISION LOT # 8 Name: (owner) WELLOWS REALTY INC. System Installer: CUNT MOANS Basement with plumbing: Garage Number of Bedrooms Type of Water Supply: ☐ Community 🛣 Public ☐ Well Distance from well Types V and VI Systems expire in 5 years. System Type: 25/0 NEOSCTIONS STSTEM Owner must contact Health Department 6 months prior to expiration for permit renewal. (In accordance with Table V a) This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization. * PUMP TO MEDIUM D-BOX EGUAL DISTRUSUTION * INSTALL: 07/19/2022 Pumpt Alarm checked on 9-28-22 By The * SUPPLY LINE 18IDH SELOW WATER LINE + CASED IN DOT PIPIE 25% 20. power DIN RANGET FALLS LN. PERMIT CONDITIONS: System shall perform in accordance with Rule /. 1961. Performance: As required by Rule .1961. II. Monitoring: III. Maintenance: As required by Rule .1961. Other: Subsurface system operator required? Yes 🗂 No 🖄 If yes, see attached sheet for additional operation conditions, maintenance and reporting. IV. Operation: ٧. Other: □ Alarm □ H20Line **PWR Line** D-Box □ Pump Following are the specifications for the sewage disposal system on the above captioned property. gallons Pump Tank: 1000 Septic Tank: 1000 Type of system:

Conventional Other EZ ELOW width of depth of exact length Subsurface No. of 70 feet inches ditches ditches ditches of each ditch Drainage Field French Drain Required: Linear feet Date Authorized State Agent