## ABBREVIATIONS

- C.O. CEILING JOIST COLUMN BRACED WALL LINE BRACED WALL PANEL CASED OPENING
- CLOS.
- CONCRETE
- CONC. COMPOSITION
- D.H. C.M.U. CONTINUOUS
  CARBON MONOXIDE ALARM
  CONCRETE MASONRY UNIT
  DOUBLE HUNG DIAMETER
- EX. DOWN **EXHAUST** DOUBLE JOIST
- EXT. EXTERIOR
- FTG. FOOTING FLOOR JOIST
- Ξ Н. В. G.F.I. HOSE BIB GROUND FAULT INTERRUPTER
- M.O. LAMINATED VENEER MASONRY OPENING
- MAX. MAS. MAXIMUM MASONRY
- MTL. M.C. METAL MEDICINE CABINET

ĭ Z

MINIMUM

- OSB 0.C. PERF. PERFORATED ORIENTED STRAND ON CENTER BOARD
- REINF REC. REINFORCED RECESSED
- SCR. S.D. SMOKE DETECTOR SCREENED
- S.Y.P. SEC. SHWR. SHOWER SECOND
- SPRUCE/PINE/FIR SOUTHERN YELLOW PINE
- SUSP. S.P.F. SUSPENDED
- U.O.N. ₹P. TYPICAL UNLESS OTHERWISE
- ¥. I WASH. WASHER WATER HEATER
- ¥.P. WEATHER PROOF
- WELDED WIRE MESH
- W.W.M. WDW. HT. WINDOW HEIGHT
- WOOD

#### SYMBOLS

- HOSE BIB
- 3-WAY SWITCH SWITCH
- $\diamondsuit$ EXHAUST FAN & LIGHT LIGHT FIXTURE
- SMOKE DETECTOR
- Δ SHOWER HEAD
- Φ CONVENIENCE OUTLET TELEPHONE JACK
- GROUND FAULT INTERRUPTER 220 VOLT OUTLET

CEILING FAN

CARBON MONOXIDE ALARM

Standard

7200

SUNSET

F K E

ROAD
SEE HOME DESIG

FUQUAY—VARINA, PREVIEWS ONLINE AT WWW.STA

27526

(919)552–

**-**5677

Homes

P

lan

**(** 

GENERAL

NOTE:

S

AND

SPECIFICATIONS

## COPYRIGHT

THIS PLAN IS PROTECTED UNDER THE FEDERAL COPYRIGHT ACT. REPRODUCTION IN WHOLE OR IN PART, INCLUDING DIRECT COPYING AND/OR PREPARATION OF DERIVATIVE WORKS, FOR ANY REASON WITHOUT THE PRIOR WRITTEN CONSENT FROM STANDARD HOMES PLAN SERVICE, INC. IS STRICTLY PROHIBITED.

#### ORIGINAL **PURCHASE AGREEMENT**

ATTACHED CONSTRUCTION LICENSE FOR INVOICE NUMBER 12509.

BUILDING

CODE

INFORMATION

THIS PLAN HAS BEEN DRAWN TO CONFORM TO THE NORTH CAROLINA RESIDENTIAL CODE, 2018 EDITION (2015 INTERNATIONAL RESIDENTIAL CODE FOR ONE— AND TWO—FAMILY DWELLINGS, CURRENT EDITION) WITH AMENDMENTS UNLESS OTHERWISE NOTED. (SEE ATTACHMENTS)

#### PRIOR **T**0 CONSTRUCTION

THE CONTRACTOR SHALL REVIEW THE PLAN(S) FOR THIS PARTICULAR BUILDING PROJECT TO ENSURE COMPLIANCE WITH ALL NATIONAL, STATE AND LOCAL CODES, CLIMATIC GEOGRAPHIC DESIGN CRITERIA, AND ANY OTHER PROVISIONS THAT MAY BE REQUIRED BY VA/FHA/RD.

THE CONTRACTOR SHALL VERIFY PLAN DIMENSIONS, STRUCTURAL COMPONENTS, AND GENERAL SPECIFICATIONS CONTAINED IN THIS SET OF PLANS AND REPORT ANY DISCREPANCIES TO STANDARD HOMES PLAN SERVICE, INC. FOR JUSTIFICATION OR CORRECTION BEFORE PROCEEDING WITH WORK ON HOUSE.

THE CONTRACTOR SHALL DETERMINE ROUGH OPENING SIZES FOR ALL BUILT—IN EQUIPMENT AND/OR FACILITIES AND ADJUST PLAN DIMENSIONS AS REQUIRED.

DO NOT SCALE FROM BLUEPRINTS. REFER TO THE LABELED DIMENSIONS FOR ACTUAL MEASUREMENTS.

IT SHALL BE THE RESPONSIBILITY OF THE OWNER/BUILDER TO PROVIDE FOR THE SERVICES OF A PROFESSIONAL ENGINEER IF REQUIRED BY THE BUILDING CODE OFFICIAL.

#### SHIPPING DATE

STAMP MUST APPEAR IN RED. PLANS FOR WHICH A BUILDING PERMIT HAS NOT BEEN OBTAINED ONE YEAR FROM THE ABOVE DATE IS SUBJECT TO REVIEW BY STANDARD HOMES PLAN SERVICE, INC. A FEE MAY BE CHARGED FOR THIS SERVICE.

#### **EXCAVATI** 2

EXCAVATE TO UNDIS EXTEND BELOW LOO OF 12" BELOW ADJ BEARING CAPACITY). ISTURBED SOIL. BOTTOM OF FOOTING SHALL CAL FROST LINE AND TO A MINIMUM DEPTH CACENT GRADE. (PRESUMED 2000 PSF SOIL)

EXPANSIVE, COMPRESSIVE OR SHIFTING SOILS SHALL BE REMOVED TO A DEPTH AND WIDTH SUFFICIENT TO ASSUME A STABLE MOISTURE CONTENT IN EACH ACTIVE ZONE.

### **FOUNDATION**

PROVIDE 1/2" DIA. STEEL ANCHOR BOLTS 6'-0" O.C., 1'-0" MAX. FROM CORNERS AND 1'-0" MAX. FROM ENDS OF EACH PLATE SECTION, WITH 7" MIN. EMBEDMENT.

SLOPE GRADE AWAY FROM FOUNDATION WALLS 6" MINIMUM WITHIN THE FIRST 10 FEET. PROVIDE FOUNDATION WATERPROOFING AND DRAIN WITH POSITIVE SLOPE TO OUTLET AS REQUIRED BY SITE CONDITIONS.

PROVIDE APPROVED AND BONDED CHEMICAL SOIL TREATMENT AGAINST FUNGUS, TERMITES AND OTHER HARMFUL INSECTS. PROVIDE PRESSURE TREATED LUMBER FOR SILLS, PLATES, BANDS AND ANY LUMBER IN CONTACT WITH MASONRY.

#### CRAWL SPAC

ALL GIRDER JOINTS AND ENDS OF GIRDERS SHALL REST ON SOLID BEARINGS. FILL CORES OF HOLLOW MASONRY TO FOOTING WITH CONCRETE. FILL TOP COURSE CORES OF EXTERIOR FOUNDATION WALL WITH CONCRETE.

FOOTINGS SHALL GIRDER PIERS. EXTEND 6" AND SHALL BE 12" THICK UNDER

CHIMNEY FOOTING AND SHALL BE AT SHALL EXTEND 12" MINIMUM BEYOND EACH SIDE LEAST 12" THICK.

#### BASEMENT

ALL GIRDER JOINTS SHALL BREAK ON COLUMN CENTER LINES (STAGGERED) AND ENDS OF GIRDERS SHALL REST ON SOLID MASONRY. DOUBLE SILL AND USE LEDGER OVER ALL BASEMENT OPENINGS.

ALL BASE. SASH SHALL BE 18/20 2-LT. 3'-3 7/8" X 1'-11 15/16" 3420 HB.

#### **FRAMING**

ALL FLOOR JOISTS, CEILING JOISTS, RAFTERS, GIRDERS, HEADERS, SILLS AND BEAMS SHALL BE NO. 2 SPRUCE/PINE/FIR (S.P.F.) UNLESS OTHERWISE INDICATED.

ALL LOAD BEARING WALLS SHALL BE STUD GRADE SPRUCE/PINE/FIR (S.P.F.) UNLESS OTHERWISE INDICATED.

DESIGN SPECIFICATIONS FOR LAMINATED VENEER LUMBER (LVL)
BEAMS AND HEADERS: GRADE : 2950Fh-2 0F

GRADE: 2950Fb-2.0E BENDING Fb: 2950 MOE: 2.0 X 10<sup>6</sup> SHEAR Fv: 290

SUPPORT FOR HEADERS:
HEADERS SHALL BE SUPPORTED ON EACH END WITH ONE OR MORE
JACK STUDS OR WITH APPROVED FRAMING ANCHORS IN ACCORDANCE
WITH BUILDING CODE (SEE PLAN). THE FULL—HEIGHT STUD ADJACENT
TO EACH END OF THE HEADER SHALL BE END NAILED TO EACH END
OF THE HEADER WITH FOUR—16D NAILS. SEE TABLE BELOW.

MINIMUM NUMBER ې ک FULL HEIGHT STUDS AT EACH END OF HEADERS

| 16 FT. | 12 FT. | 8 FT. | 4 FT. | 3 FEET OR LESS | (FEEI) | HEADER SPAN                  |
|--------|--------|-------|-------|----------------|--------|------------------------------|
| 6      | 5      | 3     | 2     | 1              | 16     | MAXIMUM STUD S               |
| 4      | 3      | 2     | 1     | 1              | 24     | MAXIMUM STUD SPACING (INCHES |

# CLIMATIC AND GEOGRAPHICAL DESIGN CRITERIA

ROOF LIVE LOAD (POUNDS PER SQUARE FOOT) : 20 PSF 120 MPH

ULTIMATE DESIGN WIND SPEED (MILES PER HOUR): 120 NOMINAL DESIGN WIND SPEED: 93 MPH
EXPOSURE CATEGORY "B" UNLESS OTHERWISE NOTED WINDOW DESIGN PRESSURE RATING: DP 25
COMPONENT AND CLADDING LOADS FOR A BUILDING WITH A MEAN ROOF HEIGHT OF 30 FEET OR LESS:

| DDESCHOE ZONE |             | טרוואיליר טרטופוע א | OFTIMALE DESIGN WIND SEED (MELL) |             |
|---------------|-------------|---------------------|----------------------------------|-------------|
| TRESSOIL ZONE | 115         | 120                 | 130                              | 140         |
| ZONE 1        | 13.1, -14.0 | 14.2, -15.0         | 16.7, -18.0                      | 19.4, -21.0 |
| ZONE 2        | 13.1, -16.0 | 14.2, -18.0         | 16.7, -21.0                      | 19.4, -24.0 |
| ZONE 3        | 13.1, -16.0 | 14.2, -18.0         | 16.7, -21.0                      | 19.4, -24.0 |
| ZONE 4        | 14.3, -15.0 | 15.5, -16.0         | 18.2, -19.0                      | 21.2, -22.0 |
| ZONE 5        | 14.3, -19.0 | 15.5, -20.0         | 18.2, -24.0                      | 21.2, -28.0 |

ASSUMED MEAN ROOF HEIGHT: 17'-7"

SUBJECT TO DAMAGE FROM WEATHERING: MODERATE CLIMATE ZONES (UNLESS OTHERWISE NOTED): ZONES 3 AND 4 MINIMUM VALUES FOR ENERGY COMPLIANCE:
CEILING R-38; EXTERIOR WALLS R-15; FLOORS R-19
WINDOW U-FACTOR ≤ 0.35; RECOMMENDED SHGC ≤ 0.30 SEISMIC CONDITION BY ZONE : ZONES A AND B

## MISCELLANEOUS

LOCATE ALL CONVENIENCE OUTLETS ABOVE KITCHEN BASE CABINETS 42" ABOVE FINISHED FLOOR.

## EMERGENCY EGRESS REQUIREMENTS

IT SHALL BE THE RESPONSIBILITY OF THE OWNER/BUILDER TO VERIFY CONFORMITY WITH EGRESS REQUIREMENTS BASED ON SPECIFICATIONS PROVIDED BY WINDOW MANUFACTURER.

2018 NORTH CAROLINA RESIDENTIAL CODE
THE REQUIRED EGRESS WINDOW FROM EVERY SLEEPING ROOM SHALL HAVE A SILL HEIGHT OF NOT MORE THAN 44 INCHES ABOVE FINISHED FLOOR. THE NET CLEAR OPENING SHALL NOT BE LESS THAN 4.0 SQUARE FEET WHERE THE NET CLEAR OPENING HEIGHT SHALL BE AT LEAST 22 INCHES AND THE NET CLEAR OPENING WIDTH SHALL BE AT LEAST 20 INCHES. IN ADDITION THE MINIMUM TOTAL GLASS AREA SHALL NOT BE LESS THAN 5.0 SQUARE FEET IN THE CASE OF A GROUND STORY WINDOW AND NOT LESS THAN 5.7 SQUARE FEET IN THE CASE OF A SECOND STORY WINDOW.

2015 INTERNATIONAL RESIDENTIAL CODE

THE REQUIRED EGRESS WINDOW FROM EVERY SLEEPING ROOM SHALL HAVE A SILL HEIGHT OF NOT MORE THAN 44 INCHES ABOVE FINISHED FLOOR. ALL EMERGENCY ESCAPE AND RESCUE OPENINGS SHALL HAVE A MINIMUM NET CLEAR OPENING OF 5.7 SQUARE FEET EXCEPT GRADE FLOOR OPENINGS SHALL HAVE A MINIMUM NET OPENING OF 5 SQUARE FEET. THE MINIMUM NET CLEAR OPENING HEIGHT SHALL BE 24 INCHES. THE MINIMUM NET CLEAR OPENING WIDTH SHALL BE 20 INCHES

rvice



0

JOSHUA MASON DESIGNED FOR

SHPS PLAN NAME

KARA

MARIE

PLA

Ş Ş

MATL

09-28-20 SHEET

N

SID.

9











