



ATTIC VENTILATION CALCULATIONS



ATTIC AREA	2999 SQ.FT.	(AREA VENTILATION REQUIRED 20.9 SQ.FT.)
EACH FT. BASE GABLE LOUVER @		SQ.FT. NET FREE AREA
EACH FT. BASE GABLE LOUVER @		SQ.FT. NET FREE AREA
EACH FT. LOUVER @		SQ.FT. NET FREE AREA
38 LIN.FT. EAVE VENT @ 11 SQ.IN./FT. =	7.5	SQ.FT. NET FREE AREA
110 LIN.FT. RIDGE VENT @ 18 SQ.IN./FT. =	13.7	SQ.FT. NET FREE AREA



FRONT ELEVATION
SCALE: 1/4" = 1'-0"



RAKE DETAIL FOR GABLE ENDS



RIGHT ELEVATION
SCALE: 1/4" = 1'-0"

EXCLUSIVE RESIDENCE DESIGN FOR:
WATERMARK HOMES

T M DESIGNS
RESIDENTIAL PLANS BY TINA MCFADDEN
(910) 354-4736 TMDESIGNS2016@GMAIL.COM

LOT: 25 OAK HAVEN

NAME: JASMINE

© 2019. COPYRIGHT ALL RIGHTS RESERVED

T M DESIGNS WILL NOT BE LIABLE FOR ANY ERRORS NOT BROUGHT TO THEIR ATTENTION PRIOR TO THE START OF CONSTRUCTION. WHILE EVERY EFFORT WAS MADE IN THE PREPARATION OF THESE DRAWINGS AND DIMENSIONS TO AVOID ERRORS THE OWNER AND / OR BUILDER SHALL VERIFY ALL DIMENSIONS, DETAILS, LOCAL AND STATE CODES.

I HEREBY CERTIFY THAT THIS DRAWING MEETS LOCAL CODES, 2018 INTERNATIONAL BUILDING CODES


THIS IS FOR THE CONSTRUCTION OF ONE HOUSE ON A SINGLE LOT, NOT TO BE REUSED

PLAN NUMBER
RG22-A05F

1 A	GARAGE	F	R
	DATE:	11/6/21	



REAR ELEVATION
SCALE: 1/4"=1'-0"



LEFT ELEVATION
SCALE: 1/4"=1'-0"

T M DESIGNS

RESIDENTIAL PLANS BY TINA MCFADDEN
(910) 354-4736 TMDDESIGNS2016@GMAIL.COM

EXCLUSIVE RESIDENCE DESIGN FOR:
WATERMARK HOMES

LOT: 25 OAK HAVEN

NAME: JASMINE

© 2019. COPYRIGHT ALL RIGHTS RESERVED


T M DESIGNS WILL NOT BE LIABLE FOR ANY ERRORS NOT BROUGHT TO THEIR ATTENTION PRIOR TO THE START OF CONSTRUCTION. WHILE EVERY EFFORT WAS MADE IN THE PREPARATION OF THESE DRAWINGS AND DIMENSIONS TO AVOID ERRORS THE OWNER AND / OR BUILDER SHALL VERIFY ALL DIMENSIONS, DETAILS, LOCAL AND STATE CODES.

I HEREBY CERTIFY THAT THIS DRAWING MEETS LOCAL CODES, 2018 INTERNATIONAL BUILDING CODES


THIS IS FOR THE CONSTRUCTION OF ONE HOUSE ON A SINGLE LOT. NOT TO BE REUSED

PLAN NUMBER
BG22-A05F

1	GARAGE	F	R
	DATE:	11/6/21	




BRACING METHOD



EXTERIOR WALL TO BE FULLY SHEATHED WITH 7/16" OSB. NAILING PATTERN TO BE 8" ON ALL EDGES AND 12" IN FIELD, WITH 8d NAILS.

ENERGY TABLE
 UFACTOR OF WINDOWS .30
 CLIMATE ZONE 3
 INSULATION: WALLS 15
 CEILING 38
 FLOORS 19



FOUNDATION CRIPPLE WALLS SHALL BE FRAMED OF STUDS NOT SMALLER THAN THE STUDGING ABOVE. WHEN EXCEEDING 4 FT. IN HEIGHT, SUCH WALLS SHALL BE FRAMED OF STUDS HAVING THE SIZE REQUIRED FOR AN ADDITIONAL STORY. CRIPPLE WALLS WITH A STUD HEIGHT LESS THAN 14 INCHES SHALL BE CONTINUOUSLY SHEATHED ON ONE SIDE WITH WOOD STRUCTURAL PANELS FASTENED TO BOTH THE TOP AND BOTTOM PLATES IN ACCORDANCE WITH TABLE R602.5(1), OR CRIPPLE WALLS SHALL BE CONSTRUCTED OF SOLID BLOCKING.

NOTE:
 CEILINGS ARE 9'-0"
 UNLESS NOTED.

FIRST FLOOR PLAN

SCALE: 1/4" = 1'-0"

HEATED AREA

1ST FL	1906	SQ FT
2ND FL	369	SQ FT
TOTAL	2275	SQ FT

OTHER AREAS

GARAGE	707	SQ FT
F.PORCH	130	SQ FT
R.PORCH	256	SQ FT
STORAGE	340	SQ FT


EXTERIOR WALLS
 (2) 2X10 HEADERS

CLEAR SPAN FOR HEADER	NUMBER OF STUDS	
	JACKS	KINGS
ALL DOOR & C.O. BELOW 4'	1	1
ALL DOOR & C.O. 4' TO 7'-11"	2	2
ALL DOOR & C.O. 8' AND ABOVE	SIZED BY ENGINEER	

UNLESS NOTED OTHER WISE

GARAGE PANEL WALL

GARAGE PANEL WALLS UNDER 24" WIDE SHOULD BE EITHER PORTAL FRAMED OR 7/16" OSB ON BOTH SIDES WITH A NAILING PATTERN OF 3" ON ALL PANEL EDGES AND 6" IN THE FIELD.





2830 MULL WINDOW IN DORMER, CENTERED ABOVE PORCH WINDOW

T M DESIGNS
 RESIDENTIAL PLANS BY TINA MCFADDEN
 (910) 354-4736 TMDDESIGNS2016@GMAIL.COM

WATERMARK HOMES
 EXCLUSIVE RESIDENCE DESIGN FOR:
 LOT: 25 OAK HAVEN
 NAME: JASMINE

© 2012. COPYRIGHT ALL RIGHTS RESERVED
 T M DESIGNS WILL NOT BE LIABLE FOR ANY ERRORS NOT BROUGHT TO THEIR ATTENTION PRIOR TO THE START OF CONSTRUCTION. WHILE EVERY EFFORT WAS MADE IN THE PREPARATION OF THESE DRAWINGS AND DIMENSIONS TO AVOID ERRORS THE OWNER AND/OR BUILDER SHALL VERIFY ALL DIMENSIONS, DETAILS, LOCAL AND STATE CODES.
 I HEREBY CERTIFY THAT THIS DRAWING MEETS LOCAL CODES, 2018 INTERNATIONAL BUILDING CODES
 THIS IS FOR THE CONSTRUCTION OF ONE HOUSE ON A SINGLE LOT, NOT TO BE REUSED

PLAN NUMBER
RG22-A05
 2 A GARAGE DATE: 11/6/21



EXTERIOR WALLS (2) 2X10 HEADERS		
CLEAR SPAN FOR HEADER	NUMBER OF STUDS	
	JACKS	KINGS
ALL DOOR & C.O. BELOW 4'	1	1
ALL DOOR & C.O. 4' TO 7'-11"	2	2
ALL DOOR & C.O. 8' AND ABOVE	SIZED BY ENGINEER	

UNLESS NOTED OTHER WISE

SECOND FLOOR PLAN
SCALE: 1/4" = 1'-0"

TM DESIGNS

RESIDENTIAL PLANS BY TINA MCFADDEN
(910) 354-4736 TMDESIGNS2016@GMAIL.COM

WATERMARK HOMES

EXCLUSIVE RESIDENCE DESIGN FOR:

NAME: JASMINE LOT: 25 OAK HAVEN

© 2019. COPYRIGHT ALL RIGHTS RESERVED

TM DESIGNS WILL NOT BE LIABLE FOR ANY ERRORS NOT BROUGHT TO THEIR ATTENTION PRIOR TO THE START OF CONSTRUCTION, WHILE EVERY EFFORT WAS MADE IN THE PREPARATION OF THESE DRAWINGS AND DIMENSIONS TO AVOID ERRORS THE OWNER AND/OR BUILDER SHALL VERIFY ALL DIMENSIONS, DETAILS, LOCAL AND STATE CODES.

I HEREBY CERTIFY THAT THIS DRAWING MEETS LOCAL CODES, 2018 INTERNATIONAL BUILDING CODES.



THIS IS FOR THE CONSTRUCTION OF ONE HOUSE ON A SINGLE LOT, NOT TO BE REUSED.

PLAN NUMBER
RG22-A05


2	GARAGE	? ?
	DATE:	11/6/21

WALL ANCHOR OPTIONS
 USE ANCHOR BOLTS
 ANCHOR BOLTS: 1/2" DIA. BOLTS AT 6'-0" O.C.
 AND NOT MORE THAN 12" FROM CORNERS, EMBEDDED
 MIN. 7" INTO FOUNDATION. USE A MIN. OF 2 BOLTS
 PER EACH STUD WALL


ALL FOUNDATION WALLS HAVE
 A 16" X 8" FOOTING UNLESS
 NOTED OTHERWISE.



CONCRETE SLAB FLOOR — (A)



GARAGE WALL — (B)



LOAD BEARING WALL THICKENED SLAB — (C)

FOUNDATION PLAN
 SCALE: 1/4"=1'-0"

EXCLUSIVE RESIDENCE DESIGN FOR:

WATERMARK HOMES

RESIDENTIAL PLANS BY TINA MCFADDEN
 (910) 354-4736 TMDDESIGNS2016@GMAIL.COM

NAME: JASMINE
 LOT: 25 OAK HAVEN

© 2019. COPYRIGHT ALL RIGHTS RESERVED

T.M. DESIGNS WILL NOT BE LIABLE FOR ANY ERRORS NOT BROUGHT TO THEIR ATTENTION PRIOR TO THE START OF CONSTRUCTION. WHILE EVERY EFFORT WAS MADE IN THE PREPARATION OF THESE DRAWINGS AND DIMENSIONS TO AVOID ERRORS THE OWNER AND/OR BUILDER SHALL VERIFY ALL DIMENSIONS, DETAILS, LOCAL AND STATE CODES.

I HEREBY CERTIFY THAT THIS DRAWING MEETS LOCAL CODES, 2018 INTERNATIONAL BUILDING CODES

THIS IS FOR THE CONSTRUCTION OF ONE HOUSE ON A SINGLE LOT, NOT TO BE REUSED

PLAN NUMBER
 RG22-A05

3	GARAGE	? ?
	DATE:	11/6/21



ROOF & FLOOR TRUSSES & BEAMS

Reilly Road Industrial Park
 Fayetteville, N.C. 28309
 Phone: (910) 864-8787
 Fax: (910) 864-4444

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature
Anthony Williams

LOAD CHART FOR JACK STUDS

(BASED ON TABLES R502.5(1) & (b))
 NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADER/GIRDER

END REACTION (UP TO)	REQ'D STUDS FOR (1)PLY HEADER	END REACTION (UP TO)	REQ'D STUDS FOR (1)PLY HEADER	END REACTION (UP TO)	REQ'D STUDS FOR (1)PLY HEADER
1700	1	2550	1	3400	1
3400	2	5100	2	6800	2
5100	3	7650	3	10200	3
6800	4	10200	4	13600	4
8500	5	12750	5	17000	5
10200	6	15300	6		
11900	7				
13600	8				
15300	9				

- Plumbing Drop Notes**
1. Plumbing drop locations shown are NOT exact.
 2. Contractor to verify ALL plumbing drop locations prior to setting Floor Trusses.
 3. Adjust spacing as needed not to exceed 24"oc.

- Dimension Notes**
1. All exterior wall to wall dimensions are to face of sheathing unless noted otherwise.
 2. All interior wall dimensions are to face of frame wall unless noted otherwise.
 3. All exterior wall to truss dimensions are to face of frame wall unless noted otherwise.

Roof Area = 4253.6 sq.ft.
 Ridge Line = 132.6 ft.
 Hip Line = 0 ft.
 Horiz. OH = 135.33 ft.
 Raked OH = 270.31 ft.
 Decking = 146 sheets

All Walls Shown Are Considered Load Bearing

▲ = Indicates Left End of Truss (Reference Engineered Truss Drawing)
 Do Not Erect Trusses Backwards


WALL SCHEDULE

	1st Floor Brg. Wall
	2nd Floor Brg. Wall
	Gar. Walls Dropped
	Non-Bearing Walls

Products

PlotID	Length	Product	Piles	Net Qty
GDH-2	13' 0"	1-3/4"x 11-7/8" LVL Kerto-S	2	2
GDH	12' 0"	1-3/4"x 11-7/8" LVL Kerto-S	2	2

Connector Information				Nail Information	
Sym	Product	Manuf	Qty	Supported Member	Header
	HUS26	USP	5	Varies	16d/3-1/2"



Truss Placement Plan
 SCALE: 3/16" = 1' 0"

BUILDER	Watermark Homes	COUNTY	Johnston
JOB NAME	Lot 25 Oak Haven	ADDRESS	Lot 25 Oak Haven
PLAN	R622-A05F	MODEL	Roof
SEAL DATE	11/6/21	DATE REV.	01/13/22
QUOTE #	Quote #	DRAWN BY	Johnnie Baggett
JOB #	J1121-6508	SALESMAN	Anthony Williams

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.
 These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbciindustry.com

Reaction Summary of Order



REQ. QUOTE DATE	/ /	ORDER #	J1121-6508
ORDER DATE	11/11/21	QUOTE #	
DELIVERY DATE	/ /	CUSTOMER ACCT #	000030
DATE OF INVOICE	/ /	CUSTOMER PO #	
ORDERED BY	Brady Rufenacht	INVOICE #	
COUNTY	Johnston	TERMS	Net 10 Days
SUPERINTENDANT	Brady Rufenacht	SALES REP	Anthony Williams
JOBSITE PHONE #	(910) 483-2229	SALES AREA	Anthony Williams

SOLD TO	Watermark Homes, Inc. 196 Annette Drive Benson, NC 27504 (919) 938-8194	JOB NAME: Lot 25 Oak Haven MODEL: Roof TAG: RG22-A05F DELIVERY INSTRUCTIONS:	LOT # 25 SUBDIV: Oak Haven JOB CATEGORY:
	Watermark Homes Lot 25 Oak Haven Benson, NC	SPECIAL INSTRUCTIONS:	PLAN SEAL DATE:

BUILDING DEPARTMENT Roof Order	OVERHANG INFO	HEEL HEIGHT	00-06-08	REQ. LAYOUTS	REQ. ENGINEERING	QUOTE	JRB	01/13/22
	END CUT	RETURN				LAYOUT	JRB	01/13/22
	PLUMB	NO	GABLE STUDS	24 IN. OC	JOBSITE	1	CUTTING	JRB

ROOF TRUSSES	LOADING INFORMATION	TCLL-TCDL-BCLL-BCDL	STRESS INCR.	ROOF TRUSS SPACING: 24.0 IN. O.C. (TYP.)
		20.0,10.0,0.0,10.0	1.15	

PROFILE	QTY	PITCH		TYPE ID	BASE O/A	LUMBER		OVERHANG		REACTIONS
		TOP	BOT			TOP	BOT	LEFT	RIGHT	
	1	6.75	0.00	GABLE A1GE	45-11-00 45-11-00	2 X 6	2 X 6	01-02-08		Joint 10 Joint 11 Joint 12 Joint 18 1128.0 lbs. 37.6 lbs. 425.1 lbs. 2328.0 lbs. -257.0 lbs. -99.4 lbs. -45.7 lbs. -436.4 lbs.
	4	6.75	0.00	PIGGYBACK A2	45-11-00 45-11-00	2 X 6	2 X 6	01-02-08		Joint 11 Joint 16 1604.4 lbs. 2161.1 lbs. -94.5 lbs. -120.5 lbs.
	6	6.75	0.00	PIGGYBACK A3	45-11-00 45-11-00	2 X 6	2 X 6	01-02-08	01-02-08	Joint 12 Joint 17 1679.4 lbs. 2150.4 lbs. -111.9 lbs. -120.1 lbs.
	1	6.75	0.00	GABLE B1GE	40-11-00 40-11-00	2 X 6	2 X 6	01-02-08	01-02-08	Joint 2 Joint 26 Joint 28 Joint 29 Joint 37 127.3 lbs. 268.8 lbs. 107.0 lbs. 948.6 lbs. 282.5 lbs. -71.0 lbs. -16.2 lbs. -233.3 lbs. -430.2 lbs. -53.0 lbs.
	4	6.75	0.00	PIGGYBACK B2	40-11-00 40-11-00	2 X 6	2 X 6	01-02-08	01-02-08	Joint 9 Joint 16 1267.2 lbs. 2184.5 lbs. -97.4 lbs. -119.3 lbs.
	1	12.00	0.00	GABLE C1GE	24-11-00 24-11-00	2 X 6	2 X 10	01-02-08	01-02-08	Joint 2 Joint 11 Joint 13 Joint 14 Joint 15 1077.0 lbs. 832.4 lbs. 244.2 lbs. 151.4 lbs. 508.4 lbs. -11.5 lbs. -92.6 lbs. -199.6 lbs. -61.7 lbs. -341.7 lbs.
	5	12.00	0.00	ATTIC C2	24-11-00 24-11-00	2 X 6	2 X 10	01-02-08	01-02-08	Joint 2 Joint 12 1729.7 lbs. 1729.7 lbs. 172.2 lbs. 172.2 lbs.
	14	12.00	0.00	ATTIC C3	24-11-00 24-11-00	2 X 6	2 X 10		01-02-08	Joint 1 Joint 10 1660.1 lbs. 1730.8 lbs. 190.0 lbs. 172.0 lbs.
	1 2 Ply	12.00	0.00	ATTIC C4	24-11-00 24-11-00	2 X 8	2 X 10		01-02-08	Joint 1 Joint 10 2887.6 lbs. 3002.2 lbs. 329.6 lbs. 300.8 lbs.
	1 2 Ply	12.00	0.00	ATTIC C5	24-11-00 24-11-00	2 X 8	2 X 10		01-02-08	Joint 1 Joint 10 2887.6 lbs. 3002.2 lbs. 329.6 lbs. 300.8 lbs.
	5	12.00	0.00	ATTIC C6	24-11-00 24-11-00	2 X 6	2 X 10			Joint 1 Joint 9 1667.3 lbs. 1661.9 lbs. 190.5 lbs. 188.4 lbs.

Reaction Summary of Order



REQ. QUOTE DATE	/ /	ORDER #	J1121-6508
ORDER DATE	11/11/21	QUOTE #	
DELIVERY DATE	/ /	CUSTOMER ACCT #	000030
DATE OF INVOICE	/ /	CUSTOMER PO #	
ORDERED BY	Brady Rufenacht	INVOICE #	
COUNTY	Johnston	TERMS	Net 10 Days
SUPERINTENDANT	Brady Rufenacht	SALES REP	Anthony Williams
JOBSITE PHONE #	(910) 483-2229	SALES AREA	Anthony Williams

SOLD TO	Watermark Homes, Inc. 196 Annette Drive Benson, NC 27504 (919) 938-8194	JOB NAME: Lot 25 Oak Haven MODEL: Roof TAG: RG22-A05F DELIVERY INSTRUCTIONS:	LOT # 25 SUBDIV: Oak Haven JOB CATEGORY:
	Watermark Homes Lot 25 Oak Haven Benson, NC	SPECIAL INSTRUCTIONS:	PLAN SEAL DATE:

BUILDING DEPARTMENT	OVERHANG INFO	HEEL HEIGHT	00-06-08	REQ. LAYOUTS	REQ. ENGINEERING	QUOTE	JRB	01/13/22
	END CUT	RETURN				LAYOUT	JRB	01/13/22
	PLUMB	NO	GABLE STUDS	24 IN. OC	JOBSITE	1	CUTTING	JRB

ROOF TRUSSES	LOADING INFORMATION	TCLL-TCDL-BCLL-BCDL	STRESS INCR.	ROOF TRUSS SPACING: 24.0 IN. O.C. (TYP.)
		20.0,10.0,0.0,10.0	1.15	

PROFILE	QTY	PITCH		TYPE ID	BASE O/A	LUMBER		OVERHANG		REACTIONS				
		TOP	BOT			TOP	BOT	LEFT	RIGHT					
	1	12.00	0.00	GABLE C7GE	24-11-00 24-11-00	2 X 6	2 X 10	01-02-08	01-02-08	Joint 2 1723.6 lbs. 33.6 lbs.	Joint 11 1723.6 lbs. 33.6 lbs.			
	1	12.00	0.00	GABLE D1GE	12-05-00 12-05-00	2 X 6	2 X 6	01-02-08	01-02-08	Joint 1 146.4 lbs. -18.7 lbs.	Joint 5 126.9 lbs. 7.2 lbs.	Joint 6 372.6 lbs. -137.0 lbs.	Joint 7 229.2 lbs. 55.8 lbs.	Joint 8 372.9 lbs. -137.1 lbs.
	1	6.75	0.00	GABLE E1GE	11-11-00 11-11-00	2 X 6	2 X 6	01-02-08	01-02-08	Joint 2 159.2 lbs. -28.2 lbs.	Joint 8 159.2 lbs. -39.0 lbs.	Joint 10 161.2 lbs. -71.7 lbs.	Joint 11 173.6 lbs. -74.9 lbs.	Joint 12 127.7 lbs. 30.1 lbs.
	1	6.75	0.00	COMMON E2	11-11-00 11-11-00	2 X 6	2 X 6	01-02-08	01-02-08	Joint 2 537.6 lbs. -44.2 lbs.	Joint 4 537.6 lbs. -44.2 lbs.			
	1	6.75	0.00	GABLE G1GE	09-06-00 09-06-00	2 X 6	2 X 6	01-02-08	01-02-08	Joint 2 179.4 lbs. -45.5 lbs.	Joint 6 179.4 lbs. -58.1 lbs.	Joint 8 224.0 lbs. -95.0 lbs.	Joint 9 105.4 lbs. 21.2 lbs.	Joint 10 225.6 lbs. -96.6 lbs.
	1	6.75	0.00	COMMON G2	09-06-00 09-06-00	2 X 6	2 X 6			Joint 1 368.3 lbs. -20.9 lbs.	Joint 3 368.3 lbs. -20.9 lbs.			
	1 2 Ply	6.75	0.00	COMMON G3-GR	09-06-00 09-06-00	2 X 6	2 X 6			Joint 1 4371.5 lbs. 1221.8 lbs.	Joint 3 4408.7 lbs. 1233.3 lbs.			
	1	12.00	0.00	GABLE H1GE	09-11-00 09-11-00	2 X 6	2 X 6	01-02-08	01-02-08	Joint 10 186.6 lbs. -102.9 lbs.	Joint 11 161.5 lbs. -186.5 lbs.	Joint 12 201.4 lbs. -122.2 lbs.	Joint 13 186.6 lbs. 57.8 lbs.	Joint 14 202.8 lbs. -123.5 lbs.
	1	12.00	0.00	COMMON H2	09-11-00 09-11-00	2 X 6	2 X 6			Joint 1 396.7 lbs. -52.8 lbs.	Joint 5 396.7 lbs. -52.8 lbs.			
	1	6.75	0.00	GABLE PB1	10-07-03 10-07-03	2 X 4	2 X 4			Joint 1 48.9 lbs. -38.4 lbs.	Joint 2 88.9 lbs. -17.8 lbs.	Joint 8 81.1 lbs. 0.5 lbs.	Joint 9 14.4 lbs. -3.2 lbs.	Joint 10 144.9 lbs. -66.1 lbs.
	10	6.75	0.00	PIGGYBACK PB2	10-07-03 10-07-03	2 X 4	2 X 4			Joint 2 236.1 lbs. -34.6 lbs.	Joint 4 236.1 lbs. -42.3 lbs.	Joint 6 445.2 lbs. 3.9 lbs.		

Reaction Summary of Order



ROOF & FLOOR TRUSSES & BEAMS
 Reilly Road Industrial Park P.O. Box 40408
 Fayetteville, N.C. 28309 (910) 864-TRUS

REQ. QUOTE DATE	/ /	ORDER #	J1121-6508
ORDER DATE	11/11/21	QUOTE #	
DELIVERY DATE	/ /	CUSTOMER ACCT #	000030
DATE OF INVOICE	/ /	CUSTOMER PO #	
ORDERED BY	Brady Rufenacht	INVOICE #	
COUNTY	Johnston	TERMS	Net 10 Days
SUPERINTENDANT	Brady Rufenacht	SALES REP	Anthony Williams
JOBSITE PHONE #	(910) 483-2229	SALES AREA	Anthony Williams

SOLD TO	Watermark Homes, Inc. 196 Annette Drive Benson, NC 27504 (919) 938-8194	JOB NAME: Lot 25 Oak Haven MODEL: Roof TAG: RG22-A05F DELIVERY INSTRUCTIONS:	LOT # 25 SUBDIV: Oak Haven JOB CATEGORY:
	Watermark Homes Lot 25 Oak Haven Benson, NC	SPECIAL INSTRUCTIONS:	PLAN SEAL DATE:

BUILDING DEPARTMENT	OVERHANG INFO	HEEL HEIGHT	00-06-08	REQ. LAYOUTS	REQ. ENGINEERING	QUOTE	JRB	01/13/22
	END CUT	RETURN				LAYOUT	JRB	01/13/22
	PLUMB	NO	GABLE STUDS	24 IN. OC	JOBSITE	1	CUTTING	JRB

ROOF TRUSSES	LOADING INFORMATION	TCLL-TCDL-BCLL-BCDL	STRESS INCR.	ROOF TRUSS SPACING: 24.0 IN. O.C. (TYP.)
		20.0,10.0,0.0,10.0	1.15	

PROFILE	QTY	PITCH		TYPE ID	BASE O/A	LUMBER		OVERHANG		REACTIONS				
		TOP	BOT			TOP	BOT	LEFT	RIGHT	Joint 1	Joint 2	Joint 4	Joint 5	Joint 6
	1	6.75	0.00	GABLE PB3	05-07-03 05-07-03	2 X 4	2 X 4			Joint 1	Joint 2	Joint 4	Joint 5	Joint 6
										81.3 lbs.	255.2 lbs.	243.9 lbs.	62.5 lbs.	187.3 lbs.
										-86.0 lbs.	-145.9 lbs.	-134.6 lbs.	-67.2 lbs.	6.8 lbs.
	4	6.75	0.00	PIGGYBACK PB4	05-07-03 05-07-03	2 X 4	2 X 4			Joint 2	Joint 4	Joint 6		
										154.4 lbs.	154.4 lbs.	207.9 lbs.		
										-28.4 lbs.	-32.8 lbs.	14.3 lbs.		
	2	12.00	0.00	GABLE PB5	03-10-06 03-10-06	2 X 4	2 X 4			Joint 1	Joint 2	Joint 4	Joint 5	Joint 6
										120.9 lbs.	226.8 lbs.	195.3 lbs.	85.2 lbs.	116.9 lbs.
										-107.2 lbs.	-164.7 lbs.	-136.4 lbs.	-67.5 lbs.	17.4 lbs.
	24	12.00	0.00	PIGGYBACK PB6	03-10-06 03-10-06	2 X 4	2 X 4			Joint 2	Joint 4	Joint 6		
										117.6 lbs.	117.6 lbs.	119.5 lbs.		
										-19.3 lbs.	-23.3 lbs.	18.2 lbs.		
	2	12.00	0.00	PIGGYBACK PB7	02-11-12 02-11-12	2 X 8	2 X 4			Joint 1	Joint 2	Joint 4	Joint 5	Joint 6
										39.5 lbs.	146.4 lbs.	134.6 lbs.	18.8 lbs.	85.1 lbs.
										-29.8 lbs.	-51.9 lbs.	-43.3 lbs.	-6.2 lbs.	19.8 lbs.
	1	6.75	0.00	VALLEY V1	43-06-10 43-06-10	2 X 4	2 X 4			Joint 1	Joint 13	Joint 14	Joint 15	Joint 16
										211.7 lbs.	185.8 lbs.	479.0 lbs.	468.2 lbs.	515.6 lbs.
										-20.0 lbs.	30.8 lbs.	-104.7 lbs.	-66.4 lbs.	-76.9 lbs.
	1	6.75	0.00	VALLEY V2	36-10-09 36-10-09	2 X 4	2 X 4			Joint 1	Joint 13	Joint 14	Joint 15	Joint 16
										108.2 lbs.	75.0 lbs.	271.0 lbs.	394.4 lbs.	510.1 lbs.
										-58.2 lbs.	-15.0 lbs.	-65.0 lbs.	-78.3 lbs.	-73.4 lbs.
	1	6.75	0.00	VALLEY V3	29-09-04 29-09-04	2 X 4	2 X 4			Joint 1	Joint 11	Joint 12	Joint 13	Joint 14
										109.7 lbs.	83.8 lbs.	285.8 lbs.	405.7 lbs.	536.6 lbs.
										-30.5 lbs.	4.1 lbs.	-68.4 lbs.	-75.6 lbs.	-83.7 lbs.
	1	6.75	0.00	VALLEY V4	22-07-15 22-07-15	2 X 4	2 X 4			Joint 1	Joint 7	Joint 8	Joint 10	Joint 11
										112.9 lbs.	95.1 lbs.	297.5 lbs.	439.6 lbs.	455.8 lbs.
										-12.6 lbs.	13.3 lbs.	-69.4 lbs.	-85.8 lbs.	59.5 lbs.
	1	6.75	0.00	VALLEY V5	15-06-09 15-06-09	2 X 4	2 X 4			Joint 1	Joint 5	Joint 6	Joint 7	Joint 8
										110.5 lbs.	110.1 lbs.	350.1 lbs.	264.6 lbs.	350.3 lbs.
										-3.9 lbs.	5.6 lbs.	-86.2 lbs.	41.3 lbs.	-86.3 lbs.
	1	6.75	0.00	VALLEY V6	08-05-04 08-05-04	2 X 4	2 X 4			Joint 1	Joint 3	Joint 4		
										154.1 lbs.	154.1 lbs.	282.4 lbs.		
										-24.6 lbs.	-29.5 lbs.	15.0 lbs.		

Reaction Summary of Order






ROOF & FLOOR TRUSSES & BEAMS
 Reilly Road Industrial Park P.O. Box 40408
 Fayetteville, N.C. 28309 (910) 864-TRUS

REQ. QUOTE DATE	/ /	ORDER #	J1121-6508
ORDER DATE	11/11/21	QUOTE #	
DELIVERY DATE	/ /	CUSTOMER ACCT #	000030
DATE OF INVOICE	/ /	CUSTOMER PO #	
ORDERED BY	Brady Rufenacht	INVOICE #	
COUNTY	Johnston	TERMS	Net 10 Days
SUPERINTENDANT	Brady Rufenacht	SALES REP	Anthony Williams
JOBSITE PHONE #	(910) 483-2229	SALES AREA	Anthony Williams

SHEET	Watermark Homes, Inc. 196 Annette Drive Benson, NC 27504 (919) 938-8194	JOB NAME: Lot 25 Oak Haven MODEL: Roof TAG: RG22-A05F DELIVERY INSTRUCTIONS:	LOT # 25 SUBDIV: Oak Haven JOB CATEGORY:
	Watermark Homes Lot 25 Oak Haven Benson, NC	SPECIAL INSTRUCTIONS:	PLAN SEAL DATE:


BUILDING DEPARTMENT	OVERHANG INFO	HEEL HEIGHT	00-06-08	REQ. LAYOUTS	REQ. ENGINEERING	QUOTE	JRB	01/13/22								
Roof Order	<table border="1"> <tr> <td>END CUT</td> <td>RETURN</td> </tr> <tr> <td>PLUMB</td> <td>NO</td> </tr> </table>	END CUT	RETURN	PLUMB	NO	GABLE STUDS	24 IN. OC	<table border="1"> <tr> <td>JOBSITE</td> <td>1</td> </tr> </table>	JOBSITE	1	<table border="1"> <tr> <td>JOBSITE</td> <td>1</td> </tr> </table>	JOBSITE	1	LAYOUT	JRB	01/13/22
END CUT	RETURN															
PLUMB	NO															
JOBSITE	1															
JOBSITE	1															
						CUTTING	JRB	11/16/21								

ROOF TRUSSES		LOADING INFORMATION		TCLL-TCDL-BCLL-BCDL	STRESS INCR.	ROOF TRUSS SPACING: 24.0 IN. O.C. (TYP.)				
				20.0,10.0,0.0,10.0	1.15					
PROFILE	QTY	PITCH		TYPE ID	BASE O/A	LUMBER		OVERHANG		REACTIONS
	PLY	TOP	BOT			TOP	BOT	LEFT	RIGHT	
	1	12.00	0.00	VALLEY VB1	08-08-04 08-08-04	2 X 4	2 X 4			Joint 1 Joint 3 Joint 4 196.0 lbs. 196.0 lbs. 251.7 lbs. -34.9 lbs. -34.9 lbs. 33.2 lbs.
	1	12.00	0.00	VALLEY VB2	06-05-04 06-05-04	2 X 4	2 X 4			Joint 1 Joint 3 Joint 4 141.2 lbs. 141.2 lbs. 181.3 lbs. -25.2 lbs. -25.2 lbs. 23.9 lbs.
	1	12.00	0.00	VALLEY VB3	04-02-04 04-02-04	2 X 4	2 X 4			Joint 1 Joint 3 Joint 4 86.4 lbs. 86.4 lbs. 110.9 lbs. -15.4 lbs. -15.4 lbs. 14.6 lbs.

ITEMS						
QTY	ITEM TYPE	SIZE	LENGTH FT-IN-16	PART NUMBER	NOTES	
5	Hangers, USP	HUS 26			SIMPSON (HUS26)	
2	LVL Beams (Sized)	LVL, 1-3/4" x 11-7/8" (S)	12-00-00		GDH	
2	LVL Beams (Sized)	LVL, 1-3/4" x 11-7/8" (S)	13-00-00		GDH-2	

GDH Kerto-S LVL 1.750" X 11.875" 2-Ply - PASSED

Level: Level



Member Information

Type:	Girder	Application:	Floor
Plies:	2	Design Method:	ASD
Moisture Condition:	Dry	Building Code:	IBC/IRC 2015
Deflection LL:	480	Load Sharing:	No
Deflection TL:	240	Deck:	Not Checked
Importance:	Normal - II		
Temperature:	Temp <= 100°F		

Reactions UNPATTERNED lb (Uplift)

Brg	Direction	Live	Dead	Snow	Wind	Const
1	Vertical	0	825	0	0	0
2	Vertical	0	825	0	0	0

Bearings

Bearing	Length	Dir.	Cap.	React D/L lb	Total	Ld. Case	Ld. Comb.
1 - SPF End Grain	3.000"	Vert	9%	825 / 0	825	Uniform	D
2 - SPF End Grain	3.000"	Vert	9%	825 / 0	825	Uniform	D

Analysis Results

Analysis	Actual	Location	Allowed	Capacity	Comb.	Case
Moment	1859 ft-lb	4'10 1/2"	17919 ft-lb	0.104 (10%)	D	Uniform
Unbraced	1859 ft-lb	4'10 1/2"	9664 ft-lb	0.192 (19%)	D	Uniform
Shear	624 lb	1'2 7/8"	7980 lb	0.078 (8%)	D	Uniform
LL Defl inch	0.000 (L/999)	0	999.000 (L/0)	0.000 (0%)		
TL Defl inch	0.035 (L/3190)	4'10 1/2"	0.469 (L/240)	0.075 (8%)	D	Uniform

Design Notes

- 1 Provide support to prevent lateral movement and rotation at the end bearings. Lateral support may also be required at the interior bearings by the building code.
- 2 Girders are designed to be supported on the bottom edge only.
- 3 Multiple plies must be fastened together as per manufacturer's details.
- 4 Top loads must be supported equally by all plies.
- 5 Top must be laterally braced at end bearings.
- 6 Bottom must be laterally braced at end bearings.
- 7 Lateral slenderness ratio based on single ply width.

ID	Load Type	Location	Trib Width	Side	Dead 0.9	Live 1	Snow 1.15	Wind 1.6	Const. 1.25	Comments
1	Uniform			Top	120 PLF	0 PLF	0 PLF	0 PLF	0 PLF	WALL
2	Uniform			Top	40 PLF	0 PLF	0 PLF	0 PLF	0 PLF	D1GE
	Self Weight				9 PLF					

Notes

Calculated Structured Designs is responsible only of the structural adequacy of this component based on the design criteria and loadings shown. It is the responsibility of the customer and/or the contractor to ensure the component suitability of the intended application, and to verify the dimensions and loads.

Lumber

1. Dry service conditions, unless noted otherwise
2. LVL not to be treated with fire retardant or corrosive chemicals

Handling & Installation

1. LVL beams must not be cut or drilled
2. Refer to manufacturer's product information regarding installation requirements, multi-ply fastening details, beam strength values, and code approvals
3. Damaged Beams must not be used
4. Design assumes top edge is laterally restrained
5. Provide lateral support at bearing points to avoid lateral displacement and rotation

6. For flat roofs provide proper drainage to prevent ponding

This design is valid until 3/30/2024

Manufacturer Info


Metsä Wood
 301 Merritt 7 Building, 2nd Floor
 Norwalk, CT 06851
 (800) 622-5850
www.metsawood.com/us
 ICC-ES: ESR-3633

Comtech, Inc.
 1001 S. Reilly Road, Suite #639
 Fayetteville, NC
 USA
 28314
 910-864-TRUS



GDH-2 Kerto-S LVL 1.750" X 11.875" 2-Ply - PASSED

Level: Level



Member Information

Type:	Girder	Application:	Floor
Plies:	2	Design Method:	ASD
Moisture Condition:	Dry	Building Code:	IBC/IRC 2015
Deflection LL:	480	Load Sharing:	No
Deflection TL:	240	Deck:	Not Checked
Importance:	Normal - II		
Temperature:	Temp <= 100°F		

Reactions UNPATTERNED lb (Uplift)

Brg	Direction	Live	Dead	Snow	Wind	Const
1	Vertical	0	1264	0	0	0
2	Vertical	0	1264	0	0	0

Bearings

Bearing	Length	Dir.	Cap.	React D/L lb	Total	Ld. Case	Ld. Comb.
1 - SPF End Grain	3.000"	Vert	14%	1264 / 0	1264	Uniform	D
2 - SPF End Grain	3.000"	Vert	14%	1264 / 0	1264	Uniform	D

Analysis Results

Analysis	Actual	Location	Allowed	Capacity	Comb.	Case
Moment	2848 ft-lb	4'10 1/2"	17919 ft-lb	0.159 (16%)	D	Uniform
Unbraced	2848 ft-lb	4'10 1/2"	9664 ft-lb	0.295 (29%)	D	Uniform
Shear	952 lb	1'2 7/8"	7980 lb	0.119 (12%)	D	Uniform
LL Defl inch	0.000 (L/999)	0	999.000 (L/0)	0.000 (0%)		
TL Defl inch	0.054 (L/2083)	4'10 1/2"	0.469 (L/240)	0.115 (12%)	D	Uniform

Design Notes

- 1 Provide support to prevent lateral movement and rotation at the end bearings. Lateral support may also be required at the interior bearings by the building code.
- 2 Girders are designed to be supported on the bottom edge only.
- 3 Multiple plies must be fastened together as per manufacturer's details.
- 4 Top loads must be supported equally by all plies.
- 5 Top must be laterally braced at end bearings.
- 6 Bottom must be laterally braced at end bearings.
- 7 Lateral slenderness ratio based on single ply width.

ID	Load Type	Location	Trib Width	Side	Dead 0.9	Live 1	Snow 1.15	Wind 1.6	Const. 1.25	Comments
1	Uniform			Top	210 PLF	0 PLF	0 PLF	0 PLF	0 PLF	WALL
2	Uniform			Top	40 PLF	0 PLF	0 PLF	0 PLF	0 PLF	C1GE
	Self Weight				9 PLF					

Notes

Calculated Structured Designs is responsible only of the structural adequacy of this component based on the design criteria and loadings shown. It is the responsibility of the customer and/or the contractor to ensure the component suitability of the intended application, and to verify the dimensions and loads.

Lumber

1. Dry service conditions, unless noted otherwise
2. LVL not to be treated with fire retardant or corrosive chemicals

Handling & Installation

1. LVL beams must not be cut or drilled
2. Refer to manufacturer's product information regarding installation requirements, multi-ply fastening details, beam strength values, and code approvals
3. Damaged Beams must not be used
4. Design assumes top edge is laterally restrained
5. Provide lateral support at bearing points to avoid lateral displacement and rotation

6. For flat roofs provide proper drainage to prevent ponding

This design is valid until 3/30/2024

Manufacturer Info

Metsä Wood
 301 Merritt 7 Building, 2nd Floor
 Norwalk, CT 06851
 (800) 622-5850
www.metsawood.com/us
 ICC-ES: ESR-3633

Comtech, Inc.
 1001 S. Reilly Road, Suite #639
 Fayetteville, NC
 USA
 28314
 910-864-TRUS





1731 Round Rock Drive, Raleigh, NC 27615 • (919) 872-3250 • fax (919) 877-5775 • www.flssamerica.com

Oak Haven Lot 25

FIRE SPRINKLER PRODUCT DATA

12/20/2021

Steel Pipe Submittal Data for Fire Sprinkler System

See Chart For Inside Diameters and Wall Thickness

All piping to be one or more of the following: (Refer to checked for submittal items).

- Schedule 40 Steel pipe conforming to ASTM A-135 or A-795 using Cast Iron, Malleable Iron or Ductile Iron screw fittings in accordance with standard ANSI B16.3 or ANSI B16.4. Pipe may also be joined by grooved fittings approved for fire protection use.
- Schedule 7 or 10 Steel Pipe conforming to ASTM A-135 or A-795 using grooved fittings listed for fire protection use.
- All welding will comply with the applicable requirements of AWS B2.1, Specification for Welding Procedure and Performance Qualification. This will be limited to pipe outlets and flanged end treatments.

All materials to be used in the installation of sprinkler system are to conform to NFPA 13, Local Authorities Having Jurisdiction and any applicable referenced codes and standards.

Steel Pipe Dimensions per NFPA 13:

Pipe		Sch 40		Sch 10		Sch 07	
Nom. Dia.	O.D (in)	I.D. (in)	Wall (in)	I.D. (in)	Wall (in)	I.D. (in)	Wall (in)
1"	1.315	1.049	0.133	1.097	0.109	n/a	n/a
1¼"	1.660	1.380	0.140	1.442	0.109	1.536	0.062
1½"	1.900	1.610	0.145	1.682	0.109	1.728	0.086
2"	2.375	2.067	0.154	2.157	0.109	2.203	0.086
2½"	2.875	2.469	0.203	2.635	0.120	2.703	0.086
3"	3.500	3.068	0.216	3.260	0.120	3.314	0.093
4"	4.500	4.026	0.237	4.260	0.120	4.310	0.095
6"	6.625	6.065	0.280	6.357	0.134	n/a	n/a
8"	8.625	7.981	0.322	8.249	0.188	n/a	n/a
10"	10.750	10.020	0.365	n/a	n/a	n/a	n/a
12"	12.750	11.938	0.406	n/a	n/a	n/a	n/a

This submittal shall include the following checked items.

	<i>Domestic</i>	<i>Foreign</i>
Origin of Manufacture	<input checked="" type="checkbox"/>	<input type="checkbox"/>

	<i>Black</i>	<i>Galvanized</i>
Exterior Finish	<input checked="" type="checkbox"/>	<input type="checkbox"/>

	<i>Sch. 40</i>	<i>Sch. 10</i>	<i>Sch. 7</i>
Schedule	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

	<i>A-135</i>	<i>A-795</i>	<i>A-53</i>
ASTM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



Submittal Data CPVC Pipe and Fittings

Listings:

- Light hazard occupancies as defined in the standard for “Installation of Sprinkler Systems”, NFPA 13.
- Residential occupancies as defined in the standard for “Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height”, NFPA 13R.
- Residential occupancies as defined in the standard for “Installation of Sprinkler Systems in One and Two Family Dwellings and Manufactured Homes”, NFPA 13D. - Underground fire service systems as described in the “Installation of Sprinkler
- Systems”, NFPA 13 2007 Edition, and where appropriate the “Standard for Installation of Private Service Mains & Their Appurtenances”, NFPA 24
- Local Authorities having jurisdiction and any applicable referenced
- codes and standards.

Approvals:

UL, FM, CUL, NSF, Dade County, LPCB, MEA, and the City of Los Angeles.

Material Specifications:

Pipe: ASTM F442, SDR 13.5

Fittings: ASTM F438, (Sch. 40) and ASTM F439 (Sch. 80)

Maximum Working Pressure of 175 PSI



Straight Elbow



Reducing Elbow



Straight Tee



Reducing Tee



Cross



Reducing Cross



45 Elbow



Coupling



Sprinkler Adapter
w/ Brass Insert



Slip-Thread Adapter



Sprinkler Head Adapter 90° Ell



Sprinkler Head Adapter Tee



Back-to-Back Tee



Grooved Coupling Adapter



Reducer Bushing



Cap

CPVC Pipe Submittal Data for Fire Sprinkler Systems

All material used in the installation of the sprinkler system conforms to:

NFPA 13

NFPA 13R

NFPA 13D



- All CPVC piping should be pressure tested at 200 PSI for 2 hours.
- Chemical compatibility should be checked per manufacturer.
- Glycerin antifreeze solutions are acceptable and installation of antifreeze systems should comply with NFPA Section 7.6.2 of NFPA 13 (2007 Edition).

BlazeMaster® Pipe Dimensions and Weights SDR 13.5 (ASTM F 442)									
Nominal Size		Average OD		Average ID		Pounds Per Foot	Kilograms Per Meter	Pounds Per Foot	Kilograms Per Meter
Inches	mm	Inches	mm	Inches	mm	Empty	Empty	H ₂ O Filled	H ₂ O Filled
3/4	20.0	1.050	26.7	.874	22.2	0.168	0.250	0.428	0.637
1	25.0	1.315	33.4	1.101	28.0	0.262	0.390	0.675	1.005
1 1/4	32.0	1.660	42.2	1.394	35.4	0.418	0.622	1.079	1.606
1 1/2	40.0	1.900	48.3	1.598	40.6	0.548	0.816	1.417	2.109
2	50.0	2.375	60.3	2.003	50.9	0.859	1.278	2.224	3.310
2 1/2	65.0	2.875	73.0	2.423	61.5	1.257	1.871	3.255	4.844
3	80.0	3.500	88.9	2.950	75.0	1.867	2.778	4.829	7.186

Note: The above average OD and average ID information is per ASTM F442. Check with individual manufacturers for actual OD and ID information.

Allowance for Friction Loss in Fittings (Equivalent Feet of Pipe)								
Fitting Size (In.)	3/4"	1"	1 1/4"	1 1/2"	2"	2 1/2"	3"	
Tee Branch	3	5	6	8	10	12	15	
Elbow 90° *	4	5	6	7	9	12	13	
Elbow 45°	1	1	2	2	2	3	4	
Coupling	1	1	1	1	1	2	2	
Tee Run	1	1	1	1	1	2	2	



Submittal Data for CPVC Strap Hangers

All materials to be used in the installation of sprinkler system are to conform to NFPA 13, 13R and 13D, Local Authorities having Jurisdiction and any applicable referenced codes and standards.

UL Listed in the USA and Canada to support fire sprinkler piping.


- A “one-hole strap” can function as a hanger and restraining device. It supports CPVC pipe horizontally from top or side of beam. As a restraining device, the hanger will be inverted so the fastener is downward. This installation will prevent upward movement of the sprinkler during activation.
- A “two-hole strap” can function as a hanger and restraining device. It supports CPVC pipe horizontally from top, bottom, or side of beam. A hex-head self-threading screw (furnished with most CPVC hangers) is easily installed using an electric drill. No pre-drilling pilot hole is required.
- A “side-mount strap” supports the CPVC pipe horizontally from top or bottom of beam
- A “stand-off 2-hole strap” supports the CPVC pipe off of the vertical face of the structural or composite wood joists.

Hangers must be clean, free of burrs, and all surface oils. Any contaminants must be removed from the hanger.

The pipe size of the hanger shall be the same size as the supported pipe.

Pipe hangers must have a load bearing surface at least ½” inch wide.

Examples of CPVC Hangers



This submittal shall include the following checked items:

Product	
<input type="checkbox"/>	¾” Hangers
<input checked="" type="checkbox"/>	1” Hangers
<input type="checkbox"/>	1-1/4” Hangers
<input type="checkbox"/>	1-1/2” Hangers
<input type="checkbox"/>	2” Hangers

Origin of Manufacture	
Domestic	Foreign
<input checked="" type="checkbox"/>	<input type="checkbox"/>



TECHNICAL DATA

FREEDOM® RESIDENTIAL CONCEALED PENDENT SPRINKLER VK494 (K4.9)

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058


Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com

Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

1. DESCRIPTION

Viking Freedom® Residential Concealed Pendent Sprinkler VK494 is a small thermosensitive, glass-bulb residential sprinkler designed for installation on concealed pipe systems where the appearance of a smooth ceiling is desired. The orifice design, with a K-factor of 4.9 (70.6 metric*), allows the sprinkler's efficient use of available water supplies for the hydraulically designed fire-protection system. The fast response glass bulb operating element and special deflector characteristics meet the challenges of residential sprinkler standards.

The sprinkler is pre-assembled with a threaded adapter for installation with a low-profile small-diameter cover assembly installed flush to the ceiling. The two-piece design allows installation and testing of the sprinkler prior to installation of the cover plate. The "push-on" and "thread-on" designs of the concealed cover plate assemblies allow easy installation of the cover plate after the system has been tested and the ceiling finish has been applied, while also providing up to 1/2" (13 mm) of vertical adjustment. The cover assembly can be removed and reinstalled, allowing temporary removal of ceiling panels without taking the sprinkler system out of service or removing the sprinkler. The Electroless Nickel PTFE (ENT) coating has been investigated for installation in corrosive atmospheres and is C-UL-US-EU Listed as indicated in the Approval Charts. The ENT finish is only available for the sprinkler assembly, the cover plate is not plated.



2. LISTINGS AND APPROVALS



cULusEU Listed: Category VKKW

Refer to the Approval Charts and Design Criteria for C-UL-US-EU Listing requirements that must be followed.



WARNING: Cancer and Reproductive Harm-
www.P65Warnings.ca.gov

3. TECHNICAL DATA

Specifications:

Minimum Operating Pressure: Refer to the Approval Chart.

Maximum Working Pressure: 175 psi (12 bar). Factory tested hydrostatically to 500 psi (34.5 bar).

Thread size: 1/2" (15 mm) NPT

Nominal K-factor: 4.9 U.S. (70.6 metric*)

Glass-bulb fluid temperature rating: to -65 °F (-55 °C)

* Metric K-factor measurement shown is in Bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.

Material Standards:

Sprinkler Body: Brass UNS-C84400 or QM Brass

Deflector: Phosphor Bronze UNS-C51000

Deflector Pins: Stainless Steel UNS-S30200

Button: Brass UNS-C36000

Pip Cap and Insert Assembly: Copper UNS-C11000 and Stainless Steel UNS-S30400

Compression Screw: 18-8 Stainless Steel

Yoke: Phosphor Bronze UNS-C51000

Belleville Spring Sealing Assembly: Beryllium Nickel Alloy, coated on both sides with PTFE Tape

Cover Adapter: Cold Rolled Steel UNS-G10080, Finish: Clear Chromate over Zinc Plating

Shipping Cap: High Density Polyethylene

Cover Plate Materials:

Cover Plate Assembly: Copper UNS-C11000 and Brass UNS-C26800 or Stainless Steel UNS-S30400

Spring: Beryllium Nickel

Solder: Eutectic

Ordering Information: The sprinkler and cover plate must be ordered separately. Refer to Tables 1 and 2.

4. INSTALLATION

Refer to appropriate NFPA Installation Standards.

5. OPERATION

During fire conditions, when the temperature around the sprinkler approaches the cover plate's nominal temperature rating, the cover plate detaches and releases the deflector. Continued heating of the exposed sprinkler causes the heat-sensitive liquid in the glass bulb to expand. When the temperature reaches the sprinkler's nominal temperature rating, the glass bulb shatters releasing the yoke, pip cap assembly and sealing spring. Water begins flowing through the sprinkler orifice and strikes the deflector forming a uniform spray pattern over a specific area of coverage, which is determined by the water supply pressure at the sprinkler, in order to extinguish or control the fire.



TECHNICAL DATA

FREEDOM® RESIDENTIAL CONCEALED PENDENT SPRINKLER VK494 (K4.9)

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

6. INSPECTIONS, TESTS AND MAINTENANCE

Refer to NFPA 25 for Inspection, Testing and Maintenance requirements.

7. AVAILABILITY

Viking Sprinkler Model VK494 is available through a network of domestic and international distributors. See The Viking Corporation web site for the closest distributor or contact The Viking Corporation.

8. GUARANTEE

For details of warranty, refer to Viking's current list price schedule or contact Viking directly.

TABLE 1: SPRINKLER ORDERING INFORMATION

Instructions:

- (1) Select a Sprinkler Base Part Number
- (2) Add the suffix for the desired Finish
- (3) Add the suffix for the desired Sprinkler Temperature Rating
- (4) Order a cover plate (refer to Table 2)

Example:

20759AE = 200 °F (93 °C) Temperature Rated Sprinkler with a standard Brass finish.

Sprinkler Base Part Number ¹	Size	1: Finishes		2: Temperature Ratings ⁷			
	NPT Inch	Description	Suffix	Nominal Rating	Bulb Color	Max. Ambient Ceiling Temperature ²	Suffix
20759	1/2	Brass	A	155 °F (68 °C)	Red	100 °F (38 °C)	B
		ENT ^{5,6}	JN	200 °F (93 °C)	Green	150 °F (65 °C)	E
		Corrosion Resistant Sprinkler Finish: ENT					

Accessories

Sprinkler Wrenches and tools:

- A. Heavy Duty Part Number: 14047W/B³ (available since 2006)
- B. Head Cabinet Wrench Part Number: 14031^{3,4} (available since 2006)
- C. Optional Concealed Cover Plate Installer Tool Part Number: 14412⁸ (available since 2007)
- D. Optional Large Concealed Cover Plate Installer Tool Part No. 14867⁸ (available since 2007)

Sprinkler Cabinet:

Holds up to 6 sprinklers: Part number 01731A (available since 1971).

Footnotes

1. Part number shown is the base part number. For complete part number, refer to the current Viking price list schedule.
2. Based on NFPA 13, NFPA 13R, and NFPA 13D. Other limits may apply, depending on fire loading, sprinkler location, and other requirements of the Authority Having Jurisdiction. Refer to specific installation standards.
3. Requires a 1/2" ratchet (not available from Viking).
4. Also optional for removal of the protective cap. Ideal for sprinkler cabinets.
5. cULus Listed as corrosion resistant.
6. The corrosion resistant coatings have passed the standard corrosion test required by the approving agencies indicated in the Approval Charts. These tests cannot and do not represent all possible corrosive environments. Prior to installation, verify through the end-user that the coatings are compatible with or suitable for the proposed environment. For automatic sprinklers, the ENT coating is applied to all exposed exterior surfaces, including the waterway. For ENT coated sprinklers, the Belleville spring is exposed.
7. The sprinkler temperature rating is stamped on the deflector.
8. The installer tool is for push-on style cover plates only.



TECHNICAL DATA

FREEDOM® RESIDENTIAL CONCEALED PENDENT SPRINKLER VK494 (K4.9)

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

TABLE 2: COVER PLATE ORDERING INFORMATION

Instructions:

- (1) Select a Cover Plate Base Part Number
- (2) Add the suffix for the desired Finish
- (3) Add the suffix for the required Cover Plate Nominal Rating.

Example:

23190MC/W = 165 °F (74 °C) Temperature Rated, 2-3/4" (70 mm) diameter, Thread-On style, Round Cover Plate with a Painted White finish.

1: Select a Cover Plate Base Part Number ³						2: Select a Finish	
Thread-On Style			Push-On Style			Description	Suffix ⁵
Base Part Number ¹	Size Inch (mm)	Type	Base Part Number	Size Inch (mm)	Type		
23190	2-3/4 (70)	Round	23447	2-3/4 (70)	Round	Polished Chrome	F
23174	3-5/16 (84)	Round	23463	3-5/16 (84)	Round	Brushed Chrome	F-/B
23179	3-5/16 (84)	Square	23482	3-5/16 (84)	Square	Bright Brass	B
23193 ⁵	2-3/4 (70)	Stainless Steel Round	23455 ⁵	2-3/4 (70)	Stainless Steel Round	Antique Brass	B-/A
						Brushed Brass	B-/B
23183 ⁵	3-5/16 (84)	Stainless Steel Round	23473 ⁵	3-5/16 (84)	Stainless Steel Round	Brushed Copper	E-/B
						Painted White	M-/W
						Painted Ivory	M-/I
						Painted Black	M-/B

3: Temperature Rating Matrix ^{1,2}				
Cover Plate Nominal Rating (Required)	Temperature Classification	Sprinkler Nominal Rating	Sprinkler Maximum Ambient Ceiling Temperature ²	Suffix
135 °F (57 °C)	Ordinary	155 °F (68 °C)	100 °F (38 °C)	A
165 °F (74 °C)	Intermediate	200 °F (93 °C)	150 °F (65 °C)	C

Footnotes

1. Part number shown is the base part number. For complete part number, refer to the current Viking price list schedule.
2. The sprinkler temperature rating is stamped on the deflector.
3. Based on NFPA-13, NFPA 13R, and NFPA 13D. Other limits may apply, depending on fire loading, sprinkler location, and other requirements of the Authority Having Jurisdiction. Refer to specific installation standards.
4. Where a dash (-) is shown in the Finish suffix designation, insert the desired Temperature Rating suffix. See example above.
5. Stainless Steel versions are not available with any finishes or paint.




TECHNICAL DATA

FREEDOM® RESIDENTIAL CONCEALED PENDENT SPRINKLER VK494 (K4.9)

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

Approval Chart Viking VK494, 4.9 K-factor Residential Concealed Pendent Sprinkler

For systems designed to NFPA 13D or NFPA 13R. For systems designed to NFPA 13, refer to the Design Criteria. For Ceiling types refer to current editions of NFPA 13, 13R or 13D

Sprinkler Base Part Number ¹	SIN	NPT Thread Size		Nominal K-factor		Maximum Water Working Pressure
		Inches	mm	U.S.	metric ²	
20759	VK494	1/2	15	4.9	70.6	175 psi (12 bar)
Max. Coverage Area ⁶ W X L Ft. X Ft. (m X m)	Flow GPM (LPM)	Pressure PSI (bar)	Deflector to Ceiling	Installation Type	Listings and Approvals ^{3,5} 	Minimum Spacing Ft. (m)
12 X 12 (3.7 X 3.7)	13 (49.2)	7.0 (0.48)	Refer to Figure 2	Concealed with Cover Plate Assembly. See Footnote 7.	See Footnotes 8, & 9	8 (2.4)
14 X 14 (4.3 X 4.3)	13 (49.2)	7.0 (0.48)				
16 X 16 (4.9 X 4.9)	13 (49.2)	7.0 (0.48)				
18 X 18 (5.5 X 5.5)	17 (64.4)	12.0 (0.83)				
20 X 20 (6.1 X 6.1)	20 (75.7)	16.7 (1.15)				

Footnotes

- Part number shown is the base part number. For complete part number, refer to the current Viking price schedule.
- Metric K-factor measurement shown is when pressure is measured in Bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.
- This chart shows the listings and approvals available at the time of printing. Other approvals may be in process. Check with the manufacturer for any additional approvals. Refer also to Design Criteria.
- Listed by Underwriter's Laboratories, Inc. for use in the U.S., Canada, and European Union.
- Meets New York City requirements, effective July 1, 2008.
- For areas of coverage smaller than shown, use the "Flow" and "Pressure" for the next larger area listed. Flows and pressures listed are per sprinkler. The distance from sprinklers to walls shall not exceed one-half the sprinkler spacing indicated for the minimum "Flow" and "Pressure" used.
- Other paint colors are available on request with the same listings as the standard finish colors. Stainless Steel cover plates are not available with any finishes or paint. Listings and approvals apply for any paint manufacturer. Contact Viking for additional information. Custom colors are indicated on a label inside the cover assembly. Refer to Figure 3.
- Accepted Cover Plate Finishes are: Polished Chrome, Brushed Chrome, Bright Brass, Antique Brass, Brushed Brass, Brushed Copper, Painted White, Painted Ivory, or Painted Black.
- C-UL-US-EU Listed as corrosion resistant - Electroless Nickel PTFE (ENT)



TECHNICAL DATA

FREEDOM® RESIDENTIAL CONCEALED PENDENT SPRINKLER VK494 (K4.9)

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

DESIGN CRITERIA

(Also refer to the Approval Chart.)

UL Listing Requirements (C-UL-US-EU):

When using Viking Residential Concealed Pendent Sprinkler VK494 for systems designed to NFPA 13D or NFPA 13R, apply the listed areas of coverage and minimum water supply requirements shown in the Approval Chart.

For systems designed to NFPA 13: The number of design sprinklers is to be the four contiguous most hydraulically demanding sprinklers. The minimum required discharge from each of the four sprinklers is to be the greater of the following:


- The flow rates given in the Approval Chart for NFPA 13D and NFPA 13R applications for each listed area of coverage, or
- Calculated based on a minimum discharge of 0.1 gpm/sq. ft. over the “design area” in accordance with sections 9.5.2.1 or 10.2.4.1.2 of the current edition of NFPA 13.
- Minimum distance between residential sprinklers: 8 ft. (2.4 m).

NOTE: Concealed sprinklers must be installed in neutral or negative pressure plenums only.


IMPORTANT: Always refer to Bulletin Form No. F_080415 - Best Practices for Residential Sprinkler Handling and Installation. Also refer to Form No. F_080614 for general care, installation, and maintenance information. Viking sprinklers are to be installed in accordance with the latest edition of Viking technical data, the appropriate standards of NFPA and any other similar Authorities Having Jurisdiction, and also with the provisions of governmental codes, ordinances, and standards, whenever applicable. Final approval and acceptance of all residential sprinkler installations must be obtained from the Authorities Having Jurisdiction.

Sprinkler and Adapter Assembly

- Protective cap removed
- Use wrench 14047W/B**



Step 1:
Carefully slide the wrench sideways around the deflector and pins



Step 2:
Carefully press the wrench upward and turn slightly to ensure engagement with the sprinkler wrench flats.

NEVER install the sprinkler by applying the installation wrench across the frame arms. **DO NOT** overtighten. Use only the designated sprinkler wrenches, Viking Part Numbers 14047W/B** or 14031**. A leak tight seal should be achieved by turning the sprinkler clockwise 1 to 1-1/2 turns beyond finger tight.







Figure 1: Sprinkler Installation and Proper Wrench Usage
 ** A 1/2" ratchet is required (Not available from Viking)



TECHNICAL DATA

FREEDOM® RESIDENTIAL
CONCEALED PENDENT
SPRINKLER VK494 (K4.9)





The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com



GENERAL NOTES

- THIS WET PIPE FIRE SPRINKLER SYSTEM IS DESIGNED AS LIGHT HAZARD/RESIDENTIAL OCCUPANCY WITH A DESIGN DENSITY OF .05 GPM/2 SPRINKLERS MAX IN ACCORDANCE WITH 13D (2013 EDITION) AND NFPA 13-11.3.1.1.
- HYDRAULIC CALCULATIONS ARE BASED UPON FLOW DATA PERFORMED BY FLSA ON 04/21/2021 AT 4:00PM. HYDRAULIC CALCULATIONS TO BE BASED ON NFPA 13D (2013 EDITION).
- FIRE SPRINKLER OVERHEAD PIPE AND FITTINGS ARE TO BE CPVC PIPE LISTED FOR FIRE PROTECTION USED UNLESS NOTED OTHERWISE.
- ALL HANGERS TO BE U.L. LISTED FOR FIRE PROTECTION SERVICES. HANGERS SHALL BE INSTALLED IN ACCORDANCE WITH THEIR LISTING. SPACING AND LOCATION TO COMPLY WITH NFPA 13.
- ALL EQUIPMENT TO BE U.L. LISTED FOR FIRE PROTECTION SERVICES AND LISTED IN ACCORDANCE WITH ITS LISTING.
- IN AREAS WHERE WET-TYPE SPRINKLER SYSTEM PIPING HAS BEEN INSTALLED, IT IS THE OWNERS' RESPONSIBILITY TO PROVIDE ADEQUATE HEAT. (AMBIENT TEMPERATURE OF A MINIMUM 40°F)
- ALL DRAINAGE TO COMPLY WITH NFPA 13D AND CONTRACT DOCUMENTS.
- [X'-X'] DENOTES CENTERLINE OF PIPE AFF.
- ALL SPRINKLER HEADS SHALL BE LISTED RESIDENTIAL SPRINKLER HEADS IN ACCORDANCE WITH 7.5.1 OF NFPA 13D.
- FLSA POINT OF CONNECTION IS AT 1'-0" AFF.
- UNDERGROUND PIPING TO BE FLUSHED PRIOR TO SPRINKLER PIPE CONNECTION. FLUSHING IS TO BE COMPLETED BY OTHERS.
- PIPING TO SPRINKLER HEADS 1" CPVC UNLESS OTHERWISE NOTED.

NOTE:
SITE HYDRAULIC REFERENCE PLAN HAS BEEN SHOWN FOR REFERENCE ONLY. ALL UNDERGROUND WORK SHALL BE INSTALLED BY UTILITY CONTRACTOR AND INSTALLED IN ACCORDANCE WITH THE CIVIL SITE UTILITY PLAN. FLSA SHALL BEGIN WORK AT 1'-0" ABOVE FINISHED FLOOR.



Sprinkler Design Data

Project Name:	OAKHAVEN LOT 25	System:	WET
Project Street Address:	124 BUCKHAVEN DR.	Sys. Sq. Ft.:	VARIES
Suite:	-	Floor#:	2
Designed By:	HAILEY WEYANT	Phone:	(919) 872-3250
Occupancy:	RESIDENTIAL	Hazard:	LIGHT/RESIDENTIAL

Design Summary

Design Method	RA # 1	RA # 2	RA #	RA #	RA #
Design Area #	1	2	-	-	-
Location	REMO. AREA #1	REMO. AREA #2	-	-	-
Type of System	WET	WET	-	-	-
Hazard Class	RESIDENTIAL	RESIDENTIAL	-	-	-
Criteria Form	NFPA 13D (2013)	NFPA 13D (2013)	-	-	-
Design Area	1 HEAD	2 HEADS	-	-	-
Sprinkler Spacing	20X20 (400 SF)	16X16 (256 SF)	-	-	-
Density	.05	.05	-	-	-
K-factor	4.9	4.9	-	-	-
Domestic Flow	3 GPM	2 GPM	-	-	-
# Design Sprinklers	1	2	-	-	-
Special Application Spk.	-	-	-	-	-
Requirement @ TEST	23.03 gpm	29.40	-	-	-
G.P.M. Req'd	29.34 psi	29.08	-	-	-
P.S.I. Req'd	24.97	25.12	-	-	-
Safety Factor @ TEST	-	-	-	-	-
Volume of Dry System	-	-	-	-	-

Water Supply Information

Tested by:	-	Date/Time	4/21/2021	4:00 pm	Pressure Hydrant	4918037
Hydrant Elevation	-	Flow Hydrant	-	-	Static	-
Static (PSI)	54.5	Residual (PSI)	13.5	Flow (GPM)	417	-

Copy of Water Test Data Included with Calculation is required




TABLE A - CPVC STANDARD SUPPORT SPACING


NOMINAL SIZE, INCHES	MAX SUPPORT SPACING, FEET
3/4"	5'-0"
1"	6'-0"
1 1/2"	7'-0"
2"	8'-0"
2 1/2"	9'-0"
3"	10'-0"

TABLE B - MAX SUPPORT SPACING DISTANCE IN LINE SPRINKLER HEAD DROP TEE

NOMINAL PIPE SIZE	LESS THAN 100 PSI	MORE THAN 100 PSI
3/4"	4'-0"	3'-0"
1"	5'-0"	4'-0"
1 1/2"	6'-0"	5'-0"
1 1/2" - 3"	7'-0"	7'-0"

TABLE C - MAX SUPPORT SPACING DISTANCE END SPRINKLER HEAD DROP ELBOW

NOMINAL PIPE SIZE	LESS THAN 100 PSI	MORE THAN 100 PSI
3/4"	4'-0"	3'-0"
1"	5'-0"	4'-0"
1 1/2"	6'-0"	5'-0"
1 1/2" - 3"	7'-0"	7'-0"



SITE PLAN - FOR HYDRAULIC REFERENCE ONLY

FLOW TEST:
DATE - 4/21/2021
STATIC - 54.5 psi
RESIDUAL - 13.5 psi
FLOW - 417 gpm

NODE LEGEND:
UG1 - UG2 = 1-1/4" PVC 55'-0"+/-
UG2 - UG3 = 6" PVC 1856'-3"+/-
UG3 - TEST = 6" PVC 1000'-0"+/-

SCOPE OF WORK

- FLSA TO BEGIN WORK AT 1'-0" AFF
 - FLSA TO INSTALL AUTOMATIC SPRINKLER SYSTEM UNDER NFPA 13D (2013) TO PROTECT NEW RESIDENTIAL HOME
 - FLSA TO TIE THE NEW SPRINKLER SYSTEM INTO PLUMBING FOR A PASSIVE PURGE SYSTEM.
 - ALL PIPING TO BE CPVC.
 - ALL UNDERGROUND AND RUN-IN BY OTHERS
- THIS FIRE SPRINKLER PLANNING AND DESIGN DRAWING HAS BEEN PREPARED BY FIRE & LIFE SAFETY AMERICA, INC. AS A LICENSED FIRE SPRINKLER CONTRACTOR UNDER ARTICLE 2 OF CHAPTER 87 OR THE GENERAL STATUTES FOR THE STATE OF NORTH CAROLINA.
- EXCLUSIVE USE PURSUANT TO G.S. 89C-25(8) IS FOR FIRE & LIFE SAFETY AMERICA, INC. AND FIRE & LIFE SAFETY AMERICA, INC. SHALL PERFORM ANY AND ALL INSTALLATION WORK AND OTHER WORK PERFORMED IN RELIANCE ON THE DRAWING PURSUANT TO G.S. 85B-15(A)(2).
- INSTALLATION WORK OR ANY OTHER WORK PERFORMED BY ANOTHER PERSON OR ENTITY IN RELIANCE UPON THIS DRAWING OR ANY COPY THEREOF IS STRICTLY PROHIBITED.
- COPYRIGHT FIRE & LIFE SAFETY AMERICA, INC., ALL RIGHTS RESERVED.

<p>SYSTEM DESIGN CRITERIA</p> <p>TYPE SYSTEM: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> DELUGE <input type="checkbox"/> NFPA STANDARD: <input type="checkbox"/> #13 <input type="checkbox"/> #13D <input type="checkbox"/> #13R <input type="checkbox"/> #14 <input type="checkbox"/> #20 <input type="checkbox"/> #22 <input type="checkbox"/> PREACTION <input type="checkbox"/> ANTI-FREEZE</p> <p>OCCUPANCY: <input checked="" type="checkbox"/> RESIDENTIAL <input type="checkbox"/> HAZARD: <input checked="" type="checkbox"/> LIGHT <input type="checkbox"/> PIPE ID REQUIRED: <input type="checkbox"/> NO <input type="checkbox"/> YES <input type="checkbox"/> SLEEVES REQUIRED: <input type="checkbox"/> NO <input type="checkbox"/> YES <input type="checkbox"/></p> <p>MAXIMUM SPACING: <input checked="" type="checkbox"/> VARIES <input type="checkbox"/> LOCAL HOSE THREADS: <input checked="" type="checkbox"/> N.S.T. <input type="checkbox"/> SLEEVES REQUIRED: <input type="checkbox"/> NO <input type="checkbox"/> YES <input type="checkbox"/></p> <p>SPRINKLERS ARE REQUIRED TO BE LOCATED IN THE CENTER OF THE CEILING TILES.</p>		<p>APPROVING AGENCIES</p> <p>APPROVING AUTHORITY: HARNETT COUNTY</p> <p>UNDERWRITER: N/A</p>		<p>GENERAL NOTES</p> <p>1. Freeze Protection: The owner is responsible for maintaining a min. of 40°F temperature for all wet systems and portions of other systems containing water.</p> <p>2. M.I.C. Protection: The owner is responsible for all detection testing/prevention.</p> <p>3. Design is subject to minor deviations arising from field conditions and/or trade coordination. Such deviations shall not affect code compliance or scope of work and shall not require resubmittal except in "as-built" if required by contract documents.</p> <p>4. Underground piping to ensure lead-in is plumbed, 2-holed, rodded, flushed, thrust blocked and a fully executed underground test certificate required per NFPA to be provided to FLSA prior to connection. FLSA is not responsible for damage to its system or components due to debris entering the system from underground water lines provided by others.</p> <p>5. This drawing is property of Fire and Life Safety America and is not to be duplicated and/or distributed without written authorization from FLSA.</p> <p>6. Hydrostatic testing will only be performed with water or air depending on adequate temperature. Any other form of testing is excluded.</p>		<p>LEGEND</p> <table border="1"> <tr> <th>Symbol</th> <th>Description</th> </tr> <tr> <td>○</td> <td>Hydraulic Reference Point</td> </tr> <tr> <td>○</td> <td>Elev. Below Top of Steel</td> </tr> <tr> <td>○</td> <td>Elev. Above Finished Floor</td> </tr> <tr> <td>+</td> <td>Top of Top of Steel</td> </tr> <tr> <td>○</td> <td>Ceiling Height</td> </tr> <tr> <td>○</td> <td>Denotes Hanger Location</td> </tr> <tr> <td>○</td> <td>Denotes Seismic Support</td> </tr> <tr> <td>○</td> <td>Room name or use</td> </tr> <tr> <td>○</td> <td>Sleeve Location</td> </tr> <tr> <td>○</td> <td>FLSA Start Point</td> </tr> </table>		Symbol	Description	○	Hydraulic Reference Point	○	Elev. Below Top of Steel	○	Elev. Above Finished Floor	+	Top of Top of Steel	○	Ceiling Height	○	Denotes Hanger Location	○	Denotes Seismic Support	○	Room name or use	○	Sleeve Location	○	FLSA Start Point	<p>SPRINKLER SUMMARY</p> <table border="1"> <thead> <tr> <th>SYM</th> <th>TYPE</th> <th>FINISH</th> <th>TEMP</th> <th>ORIE.</th> <th>K*</th> <th>NPT</th> <th>MANUF.</th> <th>SIN#</th> <th>ESCUTCHEON</th> <th>QTY</th> </tr> </thead> <tbody> <tr> <td>○</td> <td>RES. PENDENT</td> <td>WHITE</td> <td>200°</td> <td>1/2"</td> <td>4.9</td> <td>1/2"</td> <td>VIKING</td> <td>VK494</td> <td>CONCEALED</td> <td>0</td> </tr> </tbody> </table> <p>TOTAL SPRINKLERS THIS PROJECT: 21</p> <p>TOTAL SPRINKLERS THIS DRAWING: 0</p>		SYM	TYPE	FINISH	TEMP	ORIE.	K*	NPT	MANUF.	SIN#	ESCUTCHEON	QTY	○	RES. PENDENT	WHITE	200°	1/2"	4.9	1/2"	VIKING	VK494	CONCEALED	0	<p>REVISIONS</p> <table border="1"> <thead> <tr> <th>#</th> <th>DATE</th> <th>DESCRIPTION</th> <th>BY</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>12/20/2021</td> <td>SUBMITTAL TO AHJ</td> <td>HCW</td> </tr> </tbody> </table>		#	DATE	DESCRIPTION	BY	1	12/20/2021	SUBMITTAL TO AHJ	HCW	<p>GRAPHIC SCALE: 1/8" = 1'-0"</p> <p>1721 Round Rock Drive Raleigh, NC 27715 PHONE (919) 872-3250 FAX (919) 877-8776</p> <p>FLSA PROTECTING AMERICA</p>		<p>RICHMOND, VA CHESAPEAKE, VA ROANOKE, VA SPRINGFIELD, VA ORLANDO, FL HOUSTON, TX SAN ANTONIO, TX DALLAS, TX AUSTIN, FL CHARLOTTE, NC RALEIGH, NC BALTIMORE, MD ATLANTA, GA</p> <p>JONATHAN STELLA LEVEL III AUTOMATIC SPRINKLER SYSTEMS #11897</p> <p>NORTH CAROLINA STATE LICENSE #29733</p>	
Symbol	Description																																																																		
○	Hydraulic Reference Point																																																																		
○	Elev. Below Top of Steel																																																																		
○	Elev. Above Finished Floor																																																																		
+	Top of Top of Steel																																																																		
○	Ceiling Height																																																																		
○	Denotes Hanger Location																																																																		
○	Denotes Seismic Support																																																																		
○	Room name or use																																																																		
○	Sleeve Location																																																																		
○	FLSA Start Point																																																																		
SYM	TYPE	FINISH	TEMP	ORIE.	K*	NPT	MANUF.	SIN#	ESCUTCHEON	QTY																																																									
○	RES. PENDENT	WHITE	200°	1/2"	4.9	1/2"	VIKING	VK494	CONCEALED	0																																																									
#	DATE	DESCRIPTION	BY																																																																
1	12/20/2021	SUBMITTAL TO AHJ	HCW																																																																
<p>PIPE TYPES AND FITTING TYPES</p> <p>LINE PIPING: CPVC</p> <p>LINE FITTINGS: CPVC</p>		<p>GENERAL CONTRACTOR: WATERMARK HOMES</p> <p>ADDRESS: 1303 FT BRAGG ROAD SUITE 201</p> <p>CITY & STATE: FAYETTEVILLE, NC 28305</p> <p>PHONE NO.: (910) 483-2229</p> <p>FAX NO.:</p>		<p>JOB #: 22NC1459</p> <p>DATE: 12/14/2021</p> <p>DRAWN BY: H. WEYANT</p> <p>SCALE: AS NOTED</p>		<p>HYD. SITE PLAN, GENERAL NOTES & DETAILS</p> <p>OAKHAVEN LOT 25</p> <p>124 BUCKHAVEN DR.</p> <p>HOLLY SPRINGS, NC 27540</p>		<p>DRAWING #: FP 1</p> <p>OF 2</p>																																																											




1731 Round Rock Drive, Raleigh, NC 27615 • (919) 872-3250 • fax (919) 877-5775 • www.flsamerica.com

OAKHAVEN LOT 25

HYDRAULIC CALCULATIONS

12/20/2021



Hydraulic calculations using HydraCALC

Fire & Life Safety America
1731 Roundrock Drive
Raleigh, NC 27615
P: (919) 872-3250
F: (919) 877-5775

Job Name : Oakhaven Lot 25- Bedroom #2
Drawing : FP1
Location : 124 Buckhaven Dr
Remote Area : RA1
Contract : 22NC1459
Data File : RA1-Bedroom #2.WXF

HYDRAULIC CALCULATIONS
for

Project name: Oakhaven Lot 25
Location: 124 Buckhaven Dr
Drawing no: FP1
Date: 12/14/2021

Design

Remote area number: RA1
Remote area location: Bedroom #2
Occupancy classification: Residential
Density: .05 - Gpm/SqFt
Area of application: 1 Head - SqFt
Coverage per sprinkler: 400 - SqFt
Type of sprinklers calculated: VK494
No. of sprinklers calculated: 1
In-rack demand: N/A - GPM
Hose streams: 3 - GPM
Total water required (including hose streams): 23.03 - GPM @ 29.34 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 4/21/2021
Location: NC 42, NC 27540
Source: Fire & Life Safety America

Name of contractor: Fire & Life Safety America
Address: 1731 Roundrock Drive / Raleigh, NC 27615 / P: (919) 872-3250
Phone number: F: (919) 877-57
Name of designer: H. WEYANT
Authority having jurisdiction: Harnett County
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve C

Fire & Life Safety America
Oakhaven Lot 25- Bedroom #2

Page 2
Date 12/14/2021

City Water Supply:
C1 - Static Pressure : 54.5
C2 - Residual Pressure: 13.5
C2 - Residual Flow : 417

Demand:
D1 - Elevation : 2.599
D2 - System Flow : 20.024
D2 - System Pressure : 29.341
Hose (Demand) : 3
D3 - System Demand : 23.024
Safety Margin : 24.966



Fittings Used Summary

Fire & Life Safety America
Oakhaven Lot 25- Bedroom #2

Page 3
Date 12/14/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10														
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
N *	CPVC 90'EII Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0	
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0	
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Fire & Life Safety America
Oakhaven Lot 25- Bedroom #2

Page 4
Date 12/14/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	54.5	13.5	417.0	54.307	23.02	29.341

NODE ANALYSIS


<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S101	9.0	4.9	16.7	20.02	
101	10.0		16.81		
M101	10.0		18.24		
M102	10.0		21.31		
TOR	8.0		22.93		
BOR	3.0		26.41		
UG1	3.0		27.21	3.0	
UG2	-3.0		31.88		
UG3	-3.0		31.92		
TEST	3.0		29.34		

Final Calculations : Hazen-Williams

Fire & Life Safety America
Oakhaven Lot 25- Bedroom #2

Page 5
Date 12/14/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S101 to 101	9 10	4.90	20.02	1	N	7.0	1.000	150	16.700			
						0.0	7.000		-0.433			
			20.02	1.101		0.0	8.000	0.0681	0.545		Vel = 6.75	
			0.0									
101			20.02						16.812		K Factor = 4.88	
101 to M101	10 10		20.02	1	N O	7.0	9.000	150	16.812			
						5.0	12.000		0.0			
			20.02	1.101		0.0	21.000	0.0682	1.432		Vel = 6.75	
M101 to M102	10 10		0.0	1	O	5.0	40.000	150	18.244			
						0.0	5.000		0.0			
			20.02	1.101		0.0	45.000	0.0682	3.069		Vel = 6.75	
M102 to TOR	10 8		0.0	1	N	7.0	4.000	150	21.313			
						0.0	7.000		0.866			
			20.02	1.101		0.0	11.000	0.0683	0.751		Vel = 6.75	
			0.0									
TOR			20.02						22.930		K Factor = 4.18	
TOR to BOR	8 3		20.02	1	N Ball	7.0	8.000	150	22.930			
						4.303	11.303		2.166			
			20.02	1.101		0.0	19.303	0.0681	1.315		Vel = 6.75	
BOR to UG1	3 3		0.0	1	2E	7.65	4.000	150	26.411			
						0.0	7.650		0.0			
			20.02	1.101		0.0	11.650	0.0682	0.795		Vel = 6.75	
UG1 to UG2	3 -3	H3	3.00	1.25	T 2E	9.523	55.000	150	27.206			
						9.523	19.046		2.599			
			23.02	1.394		0.0	74.046	0.0280	2.071		Vel = 4.84	
UG2 to UG3	-3 -3		0.0	6	2G 3E	9.25	1856.250	150	31.876			
						64.749	95.581		0.0			
			23.02	6.09	2F	21.583	1951.831	0	0.042		Vel = 0.25	
UG3 to TEST	-3 3		0.0	6	T 2E	48.896	1000.000	150	31.918			
						45.637	99.422		-2.599			
			23.02	6.16	G	4.89	1099.422	0	0.022		Vel = 0.25	
			0.0									
TEST			23.02						29.341		K Factor = 4.25	



Hydraulic calculations using HydraCALC

Fire & Life Safety America
1731 Roundrock Drive
Raleigh, NC 27615
P: (919) 872-3250
F: (919) 877-5775

Job Name : Oakhaven Lot 17 - Bonus Room
Drawing : FP1
Location : 124 Buckhaven Dr.
Remote Area : RA2
Contract : 22NC1459
Data File : RA2- Recreation Room.WXF

HYDRAULIC CALCULATIONS
for

Project name: Oakhaven Lot 25
Location: 124 Buckhaven Dr.
Drawing no: FP1
Date: 12/14/2021

Design

Remote area number: RA2
Remote area location: Recreation Room
Occupancy classification: Residential
Density: .05 - Gpm/SqFt
Area of application: 298 - SqFt
Coverage per sprinkler: 256 - SqFt
Type of sprinklers calculated: VK494
No. of sprinklers calculated: 2
In-rack demand: N/A - GPM
Hose streams: 3 - GPM
Total water required (including hose streams): 29.40 - GPM @ 29.08 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 4/21/2021
Location: NC 42, NC 27540
Source: Fire & Life Safety America

Name of contractor: Fire & Life Safety America
Address: 1731 Roundrock Drive / Raleigh, NC 27615 / P: (919) 872-3250
Phone number: F: (919) 877-57
Name of designer: H. WEYANT
Authority having jurisdiction: Harnett County
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C

Fire & Life Safety America
Oakhaven Lot 17 - Bonus Room


Page 2
Date 9/7/2021

City Water Supply:

C1 - Static Pressure : 54.5
C2 - Residual Pressure: 13.5
C2 - Residual Flow : 417

Demand:

D1 - Elevation : 6.496
D2 - System Flow : 26.402
D2 - System Pressure : 29.081
Hose (Demand) : 3
D3 - System Demand : 29.402
Safety Margin : 25.115



Fittings Used Summary

Fire & Life Safety America
Oakhaven Lot 17 - Bonus Room

Page 3
Date 9/7/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'EII Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Fire & Life Safety America
Oakhaven Lot 17 - Bonus Room

Page 4
Date 9/7/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	54.5	13.5	417.0	54.197	29.4	29.081

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S201	18.0	4.9	7.0	12.96	
S202	18.0	4.9	7.52	13.44	
201	19.0		6.81		
202	19.0		7.28		
M201	10.0		14.22		
M202	10.0		16.04		
TOR	8.0		20.04		
BOR	3.0		24.4		
UG1	3.0		25.72	3.0	
UG2	-3.0		31.58		
UG3	-3.0		31.65		
TEST	3.0		29.08		

Final Calculations : Hazen-Williams

Fire & Life Safety America
Oakhaven Lot 17 - Bonus Room

Page 5
Date 9/7/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S201 to 201	18 19	4.90	12.96 12.96	1 1.101	N	7.0 0.0	1.000 7.000 8.000	150	7.000 -0.433			
			0.0						0.244	Vel =	4.37	
201			12.96						6.811	K Factor =	4.97	
S202 to 202	18 19	4.90	13.44 13.44	1 1.101	O	5.0 0.0	1.000 5.000 6.000	150	7.521 -0.433			
			0.0						0.196	Vel =	4.53	
202			13.44						7.284	K Factor =	4.98	
201 to 202	19 19		12.96 12.96	1 1.101		0.0 0.0	15.500 0.0 15.500	150	6.811 0.0			
									0.473	Vel =	4.37	
202 to M201	19 10		13.44 26.4	1 1.101	2N	14.0 0.0	12.750 14.000 26.750	150	7.284 3.898			
			0.0						3.042	Vel =	8.90	
M201 to M202	10 10		0.0 26.4	1 1.101	N	7.0 0.0	9.000 7.000 16.000	150	14.224 0.0			
									1.820	Vel =	8.90	
M202 to TOR	10 8		0.0 26.4	1 1.101	3O	15.0 0.0	12.500 15.000 27.500	150	16.044 0.866			
			0.0						3.128	Vel =	8.90	
TOR			26.40						20.038	K Factor =	5.90	
TOR to BOR	8 3		26.40 26.4	1 1.101	N Ball	7.0 4.303	8.000 11.303 19.303	150	20.038 2.166			
									2.195	Vel =	8.90	
BOR to UG1	3 3		0.0 26.4	1 1.101	2E	7.65 0.0	4.000 7.650 11.650	150	24.399 0.0			
									1.325	Vel =	8.90	
UG1 to UG2	3 -3	H3	3.00 29.4	1.25 1.394	T 2E	9.523 9.523	55.000 19.046 74.046	150	25.724 2.599			
									3.257	Vel =	6.18	
UG2 to UG3	-3 -3		0.0 29.4	6 6.09	2G 3E 2F	9.25 64.749 21.583	1856.250 95.581 1951.831	150	31.580 0.0			
									0.065	Vel =	0.32	
UG3 to TEST	-3 3		0.0 29.4	6 6.16	T 2E G	48.896 45.637 4.89	1000.000 99.422 1099.422	150	31.645 -2.599			
			0.0						0.035	Vel =	0.32	
TEST			29.40						29.081	K Factor =	5.45	