




1731 Round Rock Drive, Raleigh, NC 27615 • (919) 872-3250 • fax (919) 877-5775 • www.flsamerica.com

OAKHAVEN LOT 33

HYDRAULIC CALCULATIONS

12/20/2021



Hydraulic calculations using HydraCALC

FIRE & LIFE SAFETY AMERICA
1731 ROUND ROCK DRIVE
RALEIGH, NC 27615
919-872-3250

Job Name : Oakhaven Lot 33
Drawing : FP1
Location : 79 BUCKHAVEN DRIVE
Remote Area : RA1
Contract : 22NC1555
Data File : RA1- 2nd Floor Bedroom #2.WXF

HYDRAULIC CALCULATIONS
for

Project name: Oakhaven Lot 33
Location: 79 BUCKHAVEN DRIVE
Drawing no: FP1
Date: 12/20/2021

Design

Remote area number: RA1
Remote area location: 2ND FLOOR - BEDROOM #2
Occupancy classification: RESIDENTIAL
Density: .05 - Gpm/SqFt
Area of application: 166 - SqFt
Coverage per sprinkler: 400 - SqFt
Type of sprinklers calculated: VK494
No. of sprinklers calculated: 1
In-rack demand: N/A - GPM
Hose streams: 3 - GPM
Total water required (including hose streams): 23.03 - GPM @ 34.18 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 4/21/2021
Location: NC 42, NC 27540
Source: Fire & Life Safety America

Name of contractor: Fire & Life Safety America
Address: 1731 Roundrock Drive / Raleigh, NC 27615 / P: (919) 872-3250
Phone number: F: (919) 877-57
Name of designer: H. WEYANT
Authority having jurisdiction: HARNETT COUNTY
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve C

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 33

Page 2
Date 12/20/2021

City Water Supply:
C1 - Static Pressure : 54.5
C2 - Residual Pressure: 13.5
C2 - Residual Flow : 417

Demand:
D1 - Elevation : 6.496
D2 - System Flow : 20.024
D2 - System Pressure : 34.186
Hose (Demand) : 3
D3 - System Demand : 23.024
Safety Margin : 20.121



Fittings Used Summary

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 33

Page 3
Date 12/20/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 33

Page 4
Date 12/20/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	54.5	13.5	417.0	54.307	23.02	34.186

NODE ANALYSIS


<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S101	18.0	4.9	16.7	20.02	
101	19.0		16.81		
M101	19.0		18.18		
M102	10.0		23.06		
M103	10.0		24.17		
TOR	8.0		28.07		
BOR	3.0		31.26		
UG1	3.0		32.05	3.0	
UG2	-3.0		36.73		
UG3	-3.0		36.74		
UG4	-3.0		36.76		
TEST	3.0		34.19		

Final Calculations : Hazen-Williams

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 33

Page 5
Date 12/20/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S101 to 101	18 19	4.90	20.02 20.02	1 1.101	N	7.0 0.0 0.0	1.000 7.000 8.000	150 0.0681	16.700 -0.433 0.545			Vel = 6.75
101			0.0 20.02						16.812			K Factor = 4.88
101 to M101	19 19		20.02 20.02	1 1.101	N O	7.0 5.0 0.0	8.000 12.000 20.000	150 0.0682	16.812 0.0 1.364			Vel = 6.75
M101 to M102	19 10		0.0 20.02	1 1.101	O	5.0 0.0 0.0	9.500 5.000 14.500	150 0.0682	18.176 3.898 0.989			Vel = 6.75
M102 to M103	10 10		0.0 20.02	1 1.101	O	5.0 0.0 0.0	11.167 5.000 16.167	150 0.0682	23.063 0.0 1.103			Vel = 6.75
M103 to TOR	10 8		0.0 20.02	1 1.101	2N	14.0 0.0 0.0	30.583 14.000 44.583	150 0.0682	24.166 0.866 3.040			Vel = 6.75
TOR			0.0 20.02						28.072			K Factor = 3.78
TOR to BOR	8 3		20.02 20.02	1 1.101	N	7.0 0.0 0.0	8.000 7.000 15.000	150 0.0681	28.072 2.166 1.022			Vel = 6.75
BOR to UG1	3 3		0.0 20.02	1 1.101	2E	7.65 0.0 0.0	4.000 7.650 11.650	150 0.0682	31.260 0.0 0.795			Vel = 6.75
UG1 to UG2	3 -3	H3	3.00 23.02	1.25 1.394	T 2E	9.523 9.523 0.0	55.000 19.046 74.046	150 0.0280	32.055 2.599 2.071			Vel = 4.84
UG2 to UG3	-3 -3		0.0 23.02	6 6.09	3E 2F	64.749 21.583 0.0	482.000 86.332 568.332	150 0	36.725 0.0 0.012			Vel = 0.25
UG3 to UG4	-3 -3		0.0 23.02	6 6.09	2G 3F	9.25 32.374 0.0	1149.000 41.623 1190.623	150 0	36.737 0.0 0.026			Vel = 0.25
UG4 to TEST	-3 3		0.0 23.02	6 6.16	T 2E G	48.896 45.637 4.89	1000.000 99.422 1099.422	150 0	36.763 -2.599 0.022			Vel = 0.25
TEST			0.0 23.02						34.186			K Factor = 3.94



Hydraulic calculations using HydraCALC

FIRE & LIFE SAFETY AMERICA
1731 ROUND ROCK DRIVE
RALEIGH, NC 27615
919-872-3250

Job Name : Oakhaven Lot 33
Drawing : FP1
Location : 79 BUCKHAVEN DRIVE
Remote Area : RA2
Contract : 22NC1555
Data File : RA2- 2nd Floor Bonus Room.WXF

HYDRAULIC CALCULATIONS
for

Project name: Oakhaven Lot 33
Location: 79 BUCKHAVEN DRIVE
Drawing no: FP1
Date: 12/20/2021

Design

Remote area number: RA2
Remote area location: 2ND FLOOR- BONUS ROOM
Occupancy classification: RESIDENTIAL
Density: .05 - Gpm/SqFt
Area of application: 276 - SqFt
Coverage per sprinkler: 196 - SqFt
Type of sprinklers calculated: VK494
No. of sprinklers calculated: 2
In-rack demand: N/A - GPM
Hose streams: 3 - GPM
Total water required (including hose streams): 29.27 - GPM @ 28.87 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 4/21/2021
Location: NC 42, NC 27540
Source: Fire & Life Safety America

Name of contractor: Fire & Life Safety America
Address: 1731 Roundrock Drive / Raleigh, NC 27615 / P: (919) 872-3250
Phone number: F: (919) 877-57
Name of designer: H. WEYANT
Authority having jurisdiction: HARNETT COUNTY
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve C

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 33

Page 2
Date 12/20/2021

City Water Supply:
C1 - Static Pressure : 54.5
C2 - Residual Pressure: 13.5
C2 - Residual Flow : 417

Demand:
D1 - Elevation : 6.496
D2 - System Flow : 26.268
D2 - System Pressure : 28.873
Hose (Demand) : 3
D3 - System Demand : 29.268
Safety Margin : 25.327



Fittings Used Summary

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 33

Page 3
Date 12/20/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

FIRE & LIFE SAFETY AMERICA
 Oakhaven Lot 33

Page 4
 Date 12/20/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	54.5	13.5	417.0	54.199	29.27	28.873

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S201	18.0	4.9	7.0	12.96	
S202	18.0	4.9	7.37	13.3	
201	19.0		7.02		
202	19.0		7.36		
M201	19.0		9.86		
M202	10.0		15.62		
TOR	8.0		20.38		
BOR	3.0		24.24		
UG1	3.0		25.55	3.0	
UG2	-3.0		31.38		
UG3	-3.0		31.4		
UG4	-3.0		31.44		
TEST	3.0		28.87		

Final Calculations : Hazen-Williams

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 33

Page 5
Date 12/20/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S201 to 201	18 19	4.90	12.96 12.96	1 1.101	2N	14.0 0.0 0.0	1.000 14.000 15.000	150 0.0305	7.000 -0.433 0.458		Vel = 4.37	
201			0.0 12.96						7.025		K Factor = 4.89	
S202 to 202	18 19	4.90	13.30 13.3	1 1.101	N O	7.0 5.0 0.0	1.000 12.000 13.000	150 0.0320	7.372 -0.433 0.416		Vel = 4.48	
202			0.0 13.30						7.355		K Factor = 4.90	
201 to 202	19 19		12.96 12.96	1 1.101		0.0 0.0 0.0	10.833 0.0 10.833	150 0.0305	7.025 0.0 0.330		Vel = 4.37	
202			0.0 12.96						7.355		K Factor = 4.78	
202 to M201	19 19		26.27 26.27	1 1.101	O N	5.0 7.0 0.0	10.250 12.000 22.250	150 0.1127	7.355 0.0 2.507		Vel = 8.85	
M201 to M202	19 10		0.0 26.27	1 1.101	N	7.0 0.0 0.0	9.500 7.000 16.500	150 0.1127	9.862 3.898 1.859		Vel = 8.85	
M202 to TOR	10 8		0.0 26.27	1 1.101	2N O	14.0 5.0 0.0	15.583 19.000 34.583	150 0.1127	15.619 0.866 3.897		Vel = 8.85	
TOR			0.0 26.27						20.382		K Factor = 5.82	
TOR to BOR	8 3		26.27 26.27	1 1.101	N	7.0 0.0 0.0	8.000 7.000 15.000	150 0.1126	20.382 2.166 1.689		Vel = 8.85	
BOR to UG1	3 3		0.0 26.27	1 1.101	2E	7.65 0.0 0.0	4.000 7.650 11.650	150 0.1127	24.237 0.0 1.313		Vel = 8.85	
UG1 to UG2	3 -3	H3	3.00 29.27	1.25 1.394	T 2E	9.523 9.523 0.0	55.000 19.046 74.046	150 0.0436	25.550 2.599 3.229		Vel = 6.15	
UG2 to UG3	-3 -3		0.0 29.27	6 6.09	3E 2F	64.749 21.583 0.0	482.000 86.332 568.332	150 0	31.378 0.0 0.019		Vel = 0.32	
UG3 to UG4	-3 -3		0.0 29.27	6 6.09	2G 3F	9.25 32.374 0.0	1149.000 41.623 1190.623	150 0	31.397 0.0 0.040		Vel = 0.32	
UG4 to TEST	-3 3		0.0 29.27	6 6.16	T 2E G	48.896 45.637 4.89	1000.000 99.422 1099.422	150 0	31.437 -2.599 0.035		Vel = 0.32	
TEST			0.0 29.27						28.873		K Factor = 5.45	