




1731 Round Rock Drive, Raleigh, NC 27615 • (919) 872-3250 • fax (919) 877-5775 • www.flssamerica.com

OAKHAVEN LOT 22

HYDRAULIC CALCULATIONS

12/20/2021



Hydraulic calculations using HydraCALC

FIRE & LIFE SAFETY AMERICA
1731 ROUND ROCK DRIVE
RALEIGH, NC 27615
919-872-3250

Job Name : Oakhaven Lot 22
Drawing : FP2
Location : 70 Oakhaven Dr.
Remote Area : RA1
Contract : 22NC1553
Data File : RA1- Master Bedroom.WXF

HYDRAULIC CALCULATIONS
for

Project name: Oakhaven Lot 22
Location: 70 Oakhaven Dr.
Drawing no: FP2
Date: 12/20/2021

Design

Remote area number: RA1
Remote area location: Master Bedroom
Occupancy classification: Residential
Density: .05 - Gpm/SqFt
Area of application: 221 - SqFt
Coverage per sprinkler: 400 - SqFt
Type of sprinklers calculated: VK494
No. of sprinklers calculated: 1
In-rack demand: N/A` - GPM
Hose streams: 3 - GPM
Total water required (including hose streams): 23.024 - GPM @ 29.276 - Psi
Type of system: WET, CPVC 13D
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 4/21/2021
Location: NC 42, NC 27540
Source: Fire & Life Safety America

Name of contractor: Fire & Life Safety America
Address: 1731 Roundrock Drive / Raleigh, NC 27615 / P: (919) 872-3250
Phone number: F: (919) 877-57
Name of designer: R. COLLINS
Authority having jurisdiction: Harnett County
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve C

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 22

Page 2
Date 12/20/2021

City Water Supply:
C1 - Static Pressure : 54.5
C2 - Residual Pressure: 13.5
C2 - Residual Flow : 417

Demand:
D1 - Elevation : 2.599
D2 - System Flow : 20.024
D2 - System Pressure : 29.276
Hose (Demand) : 3
D3 - System Demand : 23.024
Safety Margin : 25.031



Fittings Used Summary

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 22

Page 3
Date 12/20/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

FIRE & LIFE SAFETY AMERICA
 Oakhaven Lot 22

Page 4
 Date 12/20/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	54.5	13.5	417.0	54.307	23.02	29.276

NODE ANALYSIS


<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S101	9.0	4.9	16.7	20.02	
101	10.0		16.81		
M101	10.0		18.93		
M102	10.0		20.11		
TOR	8.0		23.17		
BOR	3.0		26.35		
UG1	3.0		27.15	3.0	
UG2	-3.0		31.82		
UG3	0.0		30.53		
UG4	-3.0		31.85		
TEST	3.0		29.28		

Final Calculations : Hazen-Williams

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 22

Page 5
Date 12/20/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S101 to 101	9 10	4.90	20.02	1	N	7.0 0.0	1.000 7.000	150	16.700 -0.433			
			20.02	1.101		0.0	8.000	0.0681	0.545	Vel =	6.75	
101			0.0 20.02						16.812	K Factor =	4.88	
101 to M101	10 10		20.02	1	N O	7.0 5.0	19.125 12.000	150	16.812 0.0			
			20.02	1.101		0.0	31.125	0.0682	2.123	Vel =	6.75	
M101 to M102	10 10		0.0	1	O	5.0 0.0	12.292 5.000	150	18.935 0.0			
			20.02	1.101		0.0	17.292	0.0682	1.179	Vel =	6.75	
M102 to TOR	10 8		0.0	1	O 2N	5.0 14.0	13.042 19.000	150	20.114 0.866			
			20.02	1.101		0.0	32.042	0.0682	2.185	Vel =	6.75	
TOR			0.0 20.02						23.165	K Factor =	4.16	
TOR to BOR	8 3		20.02	1	N	7.0 0.0	8.000 7.000	150	23.165 2.166			
			20.02	1.101		0.0	15.000	0.0682	1.023	Vel =	6.75	
BOR to UG1	3 3		0.0	1	2E	7.65 0.0	4.000 7.650	150	26.354 0.0			
			20.02	1.101		0.0	11.650	0.0682	0.794	Vel =	6.75	
UG1 to UG2	3 -3	H3	3.00	1.25	T 2E	9.523 9.523	55.000 19.046	150	27.148 2.599			
			23.02	1.394		0.0	74.046	0.0280	2.072	Vel =	4.84	
UG2 to UG3	-3 0		0.0	6	3E 2F	64.749 21.583	326.000 86.332	150	31.819 -1.299			
			23.02	6.09		0.0	412.332	0	0.008	Vel =	0.25	
UG3 to UG4	0 -3		0.0	6	2G 3F	9.25 32.374	1149.000 41.623	150	30.528 1.299			
			23.02	6.09		0.0	1190.623	0	0.026	Vel =	0.25	
UG4 to TEST	-3 3		0.0	6	T 2E	48.896 45.637	1000.000 99.422	150	31.853 -2.599			
			23.02	6.16	G	4.89	1099.422	0	0.022	Vel =	0.25	
TEST			0.0 23.02						29.276	K Factor =	4.25	



Hydraulic calculations using HydraCALC

FIRE & LIFE SAFETY AMERICA
1731 ROUND ROCK DRIVE
RALEIGH, NC 27615
919-872-3250

Job Name : Oakhaven Lot 22
Drawing : FP2
Location : 70 BUCKHAVEN DR.
Remote Area : RA2
Contract : 22NC1553
Data File : RA2- Kitchen.WXF

HYDRAULIC CALCULATIONS
for

Project name: Oakhaven Lot 22
Location: 70 BUCKHAVEN DR.
Drawing no: FP2
Date: 12/20/2021

Design

Remote area number: RA2
Remote area location: Kitchen
Occupancy classification: Residential
Density: .05 - Gpm/SqFt
Area of application: 314 - SqFt
Coverage per sprinkler: 256 - SqFt
Type of sprinklers calculated: VK494
No. of sprinklers calculated: 1
In-rack demand: N/A` - GPM
Hose streams: 3 - GPM
Total water required (including hose streams): 29.050 - GPM @ 25.882 - Psi
Type of system: WET CPVC 13D
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 4/21/2021
Location: NC 42, NC 27540
Source: Fire & Life Safety America

Name of contractor: Fire & Life Safety America
Address: 1731 Roundrock Drive / Raleigh, NC 27615 / P: (919) 872-3250
Phone number: F: (919) 877-57
Name of designer: R. COLLINS
Authority having jurisdiction: Harnett County
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve C

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 22

Page 2
Date 12/20/2021

City Water Supply:
C1 - Static Pressure : 54.5
C2 - Residual Pressure: 13.5
C2 - Residual Flow : 417

Demand:
D1 - Elevation : 2.599
D2 - System Flow : 26.05
D2 - System Pressure : 25.882
Hose (Demand) : 3
D3 - System Demand : 29.05
Safety Margin : 28.321



Fittings Used Summary

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 22

Page 3
Date 12/20/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 22

Page 4
Date 12/20/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	54.5	13.5	417.0	54.203	29.05	25.882

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S201	9.0	4.9	7.0	12.96	
S202	9.0	4.9	7.13	13.09	
201	10.0		6.81		
202	10.0		6.95		
M201	10.0		7.31		
M202	10.0		8.83		
M101	10.0		11.15		
M102	10.0		13.07		
TOR	8.0		17.49		
BOR	3.0		21.32		
UG1	3.0		22.61	3.0	
UG2	-3.0		28.39		
UG3	0.0		27.11		
UG4	-3.0		28.45		
TEST	3.0		25.88		

Final Calculations : Hazen-Williams

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 22

Page 5
Date 12/20/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S201 to 201	9 10	4.90	12.96 12.96	1 1.101	N	7.0 0.0 0.0	1.000 7.000 8.000	150	7.000 -0.433 0.244			Vel = 4.37
201			0.0 12.96						6.811		K Factor = 4.97	
S202 to 202	9 10	4.90	13.09 13.09	1 1.101	N	7.0 0.0 0.0	1.000 7.000 8.000	150	7.132 -0.433 0.248			Vel = 4.41
202			0.0 13.09						6.947		K Factor = 4.97	
201 to M201	10 10		12.96 12.96	1 1.101	N	7.0 0.0 0.0	9.417 7.000 16.417	150	6.811 0.0 0.501			Vel = 4.37
M201			0.0 12.96						7.312		K Factor = 4.79	
202 to M201	10 10		13.09 13.09	1 1.101	O	5.0 0.0 0.0	6.750 5.000 11.750	150	6.947 0.0 0.365			Vel = 4.41
M201			0.0 13.09						7.312		K Factor = 4.84	
M201 to M202	10 10		26.05 26.05	1 1.101	O	5.0 0.0 0.0	8.667 5.000 13.667	150	7.312 0.0 1.516			Vel = 8.78
M202 to M101	10 10		0.0 26.05	1 1.101	O	5.0 0.0 0.0	15.917 5.000 20.917	150	8.828 0.0 2.321			Vel = 8.78
M101 to M102	10 10		0.0 26.05	1 1.101	O	5.0 0.0 0.0	12.292 5.000 17.292	150	11.149 0.0 1.918			Vel = 8.78
M102 to TOR	10 8		0.0 26.05	1 1.101	O 2N	5.0 14.0 0.0	13.042 19.000 32.042	150	13.067 0.866 3.555			Vel = 8.78
TOR			0.0 26.05						17.488		K Factor = 6.23	
TOR to BOR	8 3		26.05 26.05	1 1.101	N	7.0 0.0 0.0	8.000 7.000 15.000	150	17.488 2.166 1.664			Vel = 8.78
BOR to UG1	3 3		0.0 26.05	1 1.101	2E	7.65 0.0 0.0	4.000 7.650 11.650	150	21.318 0.0 1.292			Vel = 8.78
UG1 to UG2	3 -3	H3	3.00 29.05	1.25 1.394	T 2E	9.523 9.523 0.0	55.000 19.046 74.046	150	22.610 2.599 3.185			Vel = 6.11
UG2 to UG3	-3 0		0.0 29.05	6 6.09	3E 2F	64.749 21.583 0.0	326.000 86.332 412.332	150	28.394 -1.299 0.013			Vel = 0.32
UG3 to UG4	0 -3		0.0 29.05	6 6.09	2G 3F	9.25 32.374 0.0	1149.000 41.623 1190.623	150	27.108 1.299 0.040			Vel = 0.32

Final Calculations : Hazen-Williams

FIRE & LIFE SAFETY AMERICA
Oakhaven Lot 22

Page 6
Date 12/20/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG4 to TEST	-3 3		0.0 29.05	6 6.16	T 2E G	48.896 45.637 4.89	1000.000 99.422 1099.422	150 0	28.447 -2.599 0.034		Vel = 0.31	
TEST			0.0 29.05						25.882		K Factor = 5.71	