

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: *Regency Homes* Applicant: *Josy Williams*  
 Address: *412 Josy Williams* Date Evaluated: *5-18-22*  
 Proposed Facility: *SFD* Design Flow (.1949): *360 GPD* Property Size:  
 Location of Site: Property Recorded:  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
<i>1, 2, 3</i>	<i>L</i>	<i>0-18</i>	<i>LS</i>	<i>Gr Fr/s/s/p/sxp</i>	<i>10YR 6/2</i>	<i>&gt; 48"</i>	<i>-</i>	<i>-</i>	<i>PS-4</i>
	<i>2-5 1/2</i>	<i>18-48</i>	<i>SCI</i>	<i>SBk Fi/s/s/sp/sxp</i>	<i>≥ 30"</i>				<i>Group III</i>
<i>4</i>	<i>L</i>	<i>0-10</i>	<i>LS</i>	<i>Gr Fr/s/s/p/sxp</i>	<i>10YR 6/1</i>	<i>&gt; 48"</i>	<i>-</i>	<i>-</i>	<i>4</i>
	<i>2-5 1/2</i>	<i>10-48</i>	<i>SCI</i>	<i>SBk Fi/s/s/sp/sxp</i>	<i>&lt; 12"</i>				

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <i>Mh REHS</i> Others Present:
Available Space (.1945)	<i>✓</i>	<i>✓</i>	
System Type(s) <i>Pump</i>	<i>25% and</i>	<i>25% and</i>	
Site LTAR	<i>.4</i>	<i>.4</i>	

COMMENTS: \_\_\_\_\_

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND		FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
FS-FOOT SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM			SP-SLIGHTLY STICKY
CC-CONCLAVE SLOPE		CL-CLAY LOAM			P-PLASTIC
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			VP-VERY PLASTIC
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE

- SG-SINGLE GRAIN
- M- MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

