Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section Sheet: Property ID: Lot #: File #:

Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Regency Apr Address: 350 Josy	plicant: Dat	e Evaluated: 3-25-22		
Proposed Facility: 5 F	Des Des	sign Flow (.1949): 360 GPD	Property Size:	
Location of Site:	Pro	perty Recorded:		
Water Supply:	✓ Public	Individual Well	☐ Spring	Other
Evaluation Method:	Auger Boring	☐ Pit ☐ Cu	ıt	
Type of Wastewater:	Sewage	☐ Industrial Process	☐ Mixed	

P R O F I .1940 L Landscape E Position/ # Slope %	.1940		SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
	Horizon Depth (In.)	.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR	
132	L	0-26	W G-	Frhisprepase	>48"	248"	_	_	S.6 Group
	2-5%	26-48	SL G-	Frhispopusa Frhispopusa					Group
10									
							2		
							- 4		

Description	Initial	Repair System	Other Factors (.1946):	1
	System		Site Classification (.1948):) 11
Available Space (.1945)			Evaluated By:	Ma DEHE
System Type(s)	25%	25%	Others Present:	1. (1)
Site LTAR	. 6	- 6	100 minutes (100 m	

COMMENTS: ____

LANDSCAPE POSITIONS	<u>GROUP</u>	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	П	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

IV SIC-SILTY CLAY 0.4 - 0.1 C-CLAY

SC-SANDY CLAY

STRUCTURE SG-SINGLE GRAIN M- MASSIVE CR-CRUMB GR-GRANULAR SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY

MINERALOGY SLIGHTLY EXPANSIVE

EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North) PL-PLATY PR-PRISMATIC 0 Wood