Harnett County Department of Public Health


Improvement Permit

A	PROPERTY LOCATION: 193 Walker Grove Ln Matthews Rd. (SR		
ISSUED TO: True Homes LLC	SUBDIVISION Walker Grove LOT # 7		
NEW REPAIR EXPANSIO			
Type of Structure: 47x50 sfd, 4 beds 3 b			
Proposed Wastewater System Type: 25% Reduct	ion Sys.		
Projected Daily Flow: 480 GPD			
Number of bedrooms: 4 Number of Occup	ants: 8max		
Basement Yes 🔀 No			
	red based on final location and elevations of facilities		
Type of Water Supply: Community Public			
Permit conditions:	No expiration		
Authorized State Agent::	NEST Date: 01/18/2022 SEE ATTACHED SITE SKETCH		
The issuance of this permit by the Health Department in no way guarar	tees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This		
site is subject to revocation if the site plan, plat, or the intended use of	hanges. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of		
the Laws and Rules for Sewage Treatment and Disposal and to condition	s of this permit.		

	Construction Authorization		
	(Required for Building Permit)		
	954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance		
with the attached system layout.			
ISSUED TO: True Homes LLC	PROPERTY LOCATION: 193 Walker Grove Ln Matthews Rd. (5		
133020 10	SUBDIVISION Walker Grove LOT # 7		
Facility Type: 47x50 sfd, 4 beds 3 bat			
	tures? Yes No		
	MEDICATION STERM (Initial) Wastewater Flow: 480 GPD		
(See note below, if applicable 🔲)			
	GETTON STATE (Repair)		
Installation Requirements/Conditions	Number of trenches		
Septic Tank Size 1000 gallons	Exact length of each trench 90 feet Trench Spacing: 9 Feet on Center		
Pump Tank Sizegallons	Trenches shall be installed on contour at a Soil Cover:inches		
	Maximum Trench Depth of:inches (Maximum soil cover shall not exceed		
	(Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)		
	in all directions)		
Pump Requirements:ft. TDH vs	GPM NA inches below pipe		
	Aggregate Depth: inches above pipe		
Conditions: GAADITY TO D-BOX	EGUAL SISTIBUTION RECUIRED NA inches total		
WATER LINES (INCLUDING IRRIGATION) MUST I	BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.		
NO UTILITIES ALLOWED IN INITIAL OR REPAIR D			
**If applicable: [understand the system type specified	is different from the type specified on the application. I accept the specifications of this permit.		
Oursell and Barrantaine Grantum	Date:		
Owner/Legal Representative Signature:			
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH			
construction authorization is subject to compliance with the provisions of	title Laws allu notes for sewage freatment and pisposal and to the conditions of this permit.		
	When allest		
Authorized State Agent:	Construction Authorization Expiration Date: 01/18/2027		
ANDREW CONTIN	Construction Authorization Expiration Date: 01/18/2027		


Harnett County Department of Public Health Site Sketch

Property Location: 193 Walker Grove Ln	Matthews Rd. (SR 1436)		
Issued To: True Homes LLC	Subdivision Walker Grove		Lot # 7
Authorized State Agent:	HORES CURTA	Date: _	01)18/2022




This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.

Walker Grove 4-Bedroom Septic Proposal True Homes - Lot #7



WALKER GROVE LANE - 50' R/W

- * This drawing represents a preliminary septic design.
- **Not a Permit
- *** A more detailed septic design should be completed prior to any lot grading.



Adams Soil Consulting 919-414-6761 Job #860