Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 16 Timber Rail Ln. (NC 42) ISSUED TO: Triangle Home Pros SUBDIVISION Triangle Home Pros LLC / T W Truelov LOT # 1 REPAIR 🗌 EXPANSION | NEW X Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 46x42 sfd, 4 beds 4 baths Proposed Wastewater System Type: 25% Reduction Sys. Projected Daily Flow: 480 GPD Number of bedrooms: 4 Number of Occupants: 8 Basement Yes X No May be required based on final location and elevations of facilities Pump Required: Yes __ No Type of Water Supply: Community Public Well Distance from well NA feet X Five years Permit valid for: No expiration Authorized State Agent .: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Triangle Home Pros PROPERTY LOCATION: 16 Timber Rail Ln. (NC 42) SUBDIVISION Triangle Home Pros LLC / T W Tr LOT # 1 Facility Type: 46x42 sfd, 4 beds 4 baths New Expansion Repair Basement Fixtures? Yes Basement? Yes X No ☐ No Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GPD (See note below, if applicable) 25% EDUCTION STATIEM Installation Requirements/Conditions Number of trenches Trench Spacing: Feet on Center Septic Tank Size 1256 Exact length of each trench Soil Cover: 12 Pump Tank Size 1250 gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 24 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. inches below pipe Aggregate Depth: inches above pipe Conditions: PUAR TO D-BOX EQUAL DISTRIBUTION FWITED MA inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: in 124 Date: 02/07/2022 Construction Authorization Expiration Date: 02/07/2027 ANDREW CORRED

Harnett County Department of Public Health Site Sketch

