

**DESIGN PROFESSIONAL INSPECTION FORM**RECORD OF THE INSPECTION OF A **COMPONENT OR ELEMENT** BY A NC LICENSED ARCHITECT OR ENGINEER**Project Information:**

Residential Single-Family Project: <input checked="" type="radio"/> Y <input type="radio"/> N	Commercial Project: Y <input checked="" type="radio"/> N <input type="radio"/>
Code Enforcement Project No:	Permit No: SFD2201-0019
Project Name: KEITH HILLS SID	Owner: HUGH SURLES BUILDERS
Project Address: 1120 KEITH HILLS RD, LIVINGTON	Suite No:
Date Inspected: 1.27.22	Contractor Name: CORY GILBERT
Component Inspected: FOOTING	

**Responsible Licensed NC Architect or NC Engineer**

Name:	JOE E GODWIN JR.
Firm Name:	ENOCH ENGINEERS P.A.
Phone Numbers:	Office: 919.894.7705 Mobile:
Email Address:	GENERAL@ENOCHENGINEERS.COM
Mailing Address:	1403 HWY 50 S., BENSON NC 27504

**APPLICABLE CODE:** 2018 NCRC, SECTION R403  
 2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code


Describe Element/Component/Type of Inspection: \*

FOOTING SIZE/DEPTH W/ SOIL BEARING CAPACITY OF 2000 PSF.SOIL BEARING FIELD REPORT PROVIDED BY REQUEST.

\*(subgrade form/letter may also be required)


**Attestation/Signature:**

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.

**DocuSigned by:**


339EA4405059480... 2/15/2022

Licensed Architect or Engineer

**Inspection Department disclaimer:**

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.