

March 16, 2022

Robert Wiggins  
5601 Dutchman Dr  
Raleigh, NC 27606

ph: 910-893-7547

fax: 910-893-9371

**RE: Existing Tank Application #SFD2201-0039**

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

**1. Uncover outlet lid on septic tank and break seal on lid. (\$25.00 fee incurred)**

2. Have system pumped out

3. Replace Sanitary Tee with Filter

4. Other – *Get Septic Contractor to open + inspect septic lines +  
Fix Sanitary T if needed*

Your application will be put on hold until the selected items above have been addressed.

When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS  
Environmental Health Program Specialist  
Harnett County Department of Public Health

MO/KH  
Copy - Central Permitting