

March 4, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Ben Stout Real Estate
PO Box 53798
Fayetteville, NC 28305

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application #SFD2202-0002

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to accurately mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs brush, trees and vegetation removed from house and septic area
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other- We were not able to find enough suitable soil on the lot for a septic system and repair. You will need to get a soil scientist to design the septic system, or they may move the house all the way back, change the driveway location, and pump to the septic system of a house with fewer bedrooms**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Specialist
Harnett County Department of Public Health

MO/KH

Copy: Central Permitting