



Permit Inspections

Harnett County

Permit Number: **SFD2202-0026**

Description: **76x87**

Applied: **2/7/2022**

Approved: **5/12/2022**

Site Address: **142 FRED BURNS RD**

Issued: **5/17/2022**

Finaled: **11/18/2022**

City, State Zip Code: **HOLLY SPRINGS, NC 27540**

Status: **FINALED**

Applicant: **MULL DANIEL R**

Parent Permit:

Owner: **MULL DANIEL R**

Parent Project:

Contractor: **Howell Builders Inc**

Details:

NEED SITE PLAN

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			GAS PIPING	Unassigned		
Notes:						
			OPEN FLOOR	Unassigned		
Notes:						
			FOUNDATION SURVEY	CP Bucket		not needed
Notes:						
			ROUGH IN REINSPECT	Justin Ryan McLeod		
Notes:						
	2/8/2022	2/8/2022	ADDRESS	GIS Bucket	APPROVED	
Notes:						
142 FRED BURNS RD HOLLY SPRINGS 27540.						
	5/24/2022	5/24/2022	FOOTING	Justin Ryan McLeod	CANCELLED	
Notes:						
	5/27/2022	5/27/2022	T-POLE	Justin Ryan McLeod	APPROVED	
Notes:						
	6/28/2022	6/28/2022	FOOTING	Justin Ryan McLeod	APPROVED	letter in attach
Notes:						
letter in attach						
Per 3rd party						



Permit Inspections

Harnett County

	6/28/2022	6/28/2022	FOUNDATION	Justin Ryan McLeod	APPROVED	
Notes:						
	8/10/2022	8/10/2022	ROUGH IN	Justin Ryan McLeod	DISAPPROVED	
Notes: 1. Plumbing not on test. 2. Need hurricane clips on vaulted rafters. 3. Strap all columns 4 or more studs. 4. Missing hanger on ceiling joist in kitchen at Steel beam bolt area. 5. Rafters butt up to knee wall at back porch in mechanical room and above pantry instead of breaking on knee wall. 6. Missing 4 stud column under lvl in front right bed close to shower. 7. Missing square washer on 3 rd garage wing wall. 8.double joist missing in garage under point load per plan. 9.need tie backs on front porch rafters.						
	8/15/2022	8/15/2022	ROUGH IN REINSPECT	Justin Ryan McLeod	APPROVED W/EXC	
Notes: Engineer letter uploaded for framing issues. Need to see 2x4 ledger under rafters at left front attic per letter, this can be seen later						
	8/15/2022	8/15/2022	INSULATION	Justin Ryan McLeod	APPROVED	
Notes:						
	9/26/2022	9/26/2022	WATER CONNECTION	Justin Ryan McLeod	APPROVED	
Notes:						
	9/26/2022	9/26/2022	SEWER CONNECTION	Justin Ryan McLeod	APPROVED	
Notes:						
	11/10/2022	11/10/2022	TEMP POWER CERTIFICATION	Justin Ryan McLeod	APPROVED	
Notes:						
40	11/17/2022	11/17/2022	ENVIR OPERATIONS PERMIT	James Manhart	APPROVED	
Notes: Pump and Alarm Pending						
50	11/18/2022	11/18/2022	FINAL SFD CRAWL**	Justin Ryan McLeod	APPROVED	
Notes:						