



I-Joist Legend					
PlotID	Length	Product	Plies	Net Qty	Fab Type
IJ2	20' 8 3/4"	14" WI 40	1	9	FF
IJ3	17' 3 13/16"	14" WI 40	1	5	FF
IJ4	17' 2 3/8"	14" WI 40	1	1	FF
IJ5	7' 6 3/8"	14" WI 40	1	1	FF
IJ6	3' 5 1/2"	14" WI 40	1	1	FF
IJ1	23' 8 5/8"	16" NI-60	1	13	FF
RIM2	12' 0"	1 1/8" x 14" Rim Board	1	8	FF
RIM1	12' 0"	1 1/8" x 16" Rim Board	1	4	FF
BK1	2' 0"	14" WI 40	1	16	FF
BK1	2' 0"	16" NI-60	1	15	FF
	1' 8"	Backer Blocks (14" WI 40)	1	2	Other
	1' 1 1/4"	Backer Blocks (14" WI 40)	1	2	Other
	1' 0"	Backer Blocks (14" WI 40)	1	2	Other
		Web Stiffeners (14" WI 40)	1	4	Other
		Web Stiffeners (16" NI-60)	1	26	Other

Hatch Legend	
	Garage Walls Dropped 2"

**Truss Placement Plan**  
SCALE: 1/4" = 1'

HANGER LEGEND	
	= USP THD410 / Single Beam Hanger
	= USP THF25140 / Single I-Joist Hanger
	= USP THF25160 / Single I-Joist Hanger

Beam Legend					
PlotID	Length	Product	Plies	Net Qty	Fab Type
BM5	10' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	2	FF
BM4	6' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	2	FF
BM2	21' 0"	1-3/4"x 16" LVL Kerto-S	1	1	FF
GDH	21' 0"	1-3/4"x 18" LVL Kerto-S	3	3	FF
BM1	21' 0"	1-3/4"x 23-7/8" LVL Kerto-S	3	3	FF

LOAD CHART FOR JACK STUDS				
(BASED ON TABLES R502.5(1) & (2))				
NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADS/FOOT				
END REACTION (UP TO) (DOWN TO) HEADS	END REACTION (UP TO) (DOWN TO) HEADS	END REACTION (UP TO) (DOWN TO) HEADS	END REACTION (UP TO) (DOWN TO) HEADS	END REACTION (UP TO) (DOWN TO) HEADS
1700	2550	3400	4250	5100
3400	5100	6800	8500	10200
5100	7650	10200	12850	15500
6800	10200	13600	17000	20200
8500	12750	17000	21750	26500
10200	15300	20200	26500	32750
11900				
13600				
15300				

<b>BUILDER</b>	Caviness & Cates	<b>CITY / CO.</b>	Cameron / Harnett
<b>JOB NAME</b>	Lot 200 Anderson Creek	<b>ADDRESS</b>	218 Kensington Dr.
<b>PLAN</b>	CC-2652 / 2ND FLOOR I-JOIST	<b>MODEL</b>	31500
<b>SEAL DATE</b>	1/21/21	<b>DATE REV.</b>	02/15/22
<b>QUOTE #</b>	Quote #	<b>DRAWN BY</b>	Curtis Quick
<b>JOB #</b>	J0222-0563	<b>SALES REP.</b>	Not Assigned

**THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.**  
These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature: Curtis Quick  
Curtis Quick

**comTECH**

**ROOF & FLOOR TRUSSES & BEAMS**

Reilly Road Industrial Park  
Fayetteville, N.C. 28309  
Phone: (910) 864-8787  
Fax: (910) 864-4444