## Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 1238 Haves Rd (SR 2047) ISSUED TO: Weaver Homes NEW REPAIR T Type of Structure: 29' x 56' SFD EXPANSION Site Improvements required prior to Construction Authorization Issuance: Proposed Wastewater System Type: Pump to 25% reduction Projected Daily Flow: 360 GPD Number of Occupants: 6 Number of bedrooms: 3 Basement Yes X No May be required based on final location and elevations of facilities \_\_ No Pump Required: XYes X Five years Type of Water Supply: Community Public Well Distance from well \_\_\_\_\_\_feet Permit valid for: No expiration Permit conditions: Date: 03-08-22 SEE ATTACHED SITE SKETCH Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 1238 Hayes Rd (SR 2047) ISSUED TO: Weaver Homes LOT # 3 SUBDIVISION Facility Type: 29' x 56' SFD Expansion Basement? Yes Basement Fixtures? Yes X No X No Type of Wastewater System\*\* Pump to 25% reduction (Initial) Wastewater Flow: 360 (See note below, if applicable ) Pump to 25% reduction Number of trenches 1 Installation Requirements/Conditions Exact length of each trench \_\_\_ Trench Spacing: 9 Feet on Center Septic Tank Size 1000 Soil Cover: 6 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18 (Maximum soil cover shall not exceed inches 36" above the trench bottom) (Trench bottoms shall be level to +/-1/4" in all directions) inches below pipe Pump Requirements: \_\_\_\_\_\_ ft. TDH vs. \_\_ Aggregate Depth: inches above pipe Conditions: 36" Curtain Drain will be required to keep leteral ground water off The Drain Field inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 03-08-22 Construction Authorization Expiration Date: 03-08-27

## Harnett County Department of Public Health Site Sketch

Property Location: 1238 Hayes Rd (	SR 2047)	
Issued To: Weaver Homes	Subdivision	Lot # <u>3</u>
Authorized State Agent: Mal	a REHS	Date: 03-08-22
	Cortain Drain  Live Maria  ALTI  ALT	36" Curtain Drain will be required 10' upslope of Drain Field and 15 OFF The side of the Drain Field. Can Daylight TO Front of The Lot
This drawing is for illustrative pur	poses only. System installation must me	et all pertinent laws, rules, and regulations.

- Hayes Rd ->